

| DIII Net Port-2 | | | | | | | |
|-----------------|--|-----------|--------------------------------|------------------|----------------|--------------------|-----|
| 編碼 | point name | Object ID | Object Name | 小工具 Indoor_xx | Object Type | Instance Number | |
| 1-00 | ON/OFF (setting) 開/關(設定) | 16793601 | StartStopCommand_064 | _065 | 4 | 16385 | set |
| 1-00 | ON/OFF (status) 開/關(狀態) | 12599298 | StartStopStatus_064 | _065 | 3 | 16386 | Fb |
| 1-00 | Alarm Sign 鬧鐘通知 | 12599299 | Alarm_064 | _065 | 3 | 16387 | |
| 1-00 | Error Code 錯誤代碼 | 54542340 | MalfunctionCode_064 | _065 | 13 | 16388 | |
| 1-00 | Operation Mode (setting) 運轉模式(設定) | 58736645 | AirConModeCommand_064 | _065 | 14 | 16389 | set |
| 1-00 | Operation Mode (status) 運轉模式(狀態) | 54542342 | AirConModeStatus_064 | _065 | 13 | 16390 | Fb |
| 1-00 | Airflow Rate (setting) 氣流比率(設定) | 58736647 | AirFlowRateCommand_064 | _065 | 14 | 16391 | set |
| 1-00 | Airflow Rate (status) 氣流比率(狀態) | 54542344 | AirFlowRateStatus_064 | _065 | 13 | 16392 | Fb |
| 1-00 | Measured Room Temperature 測量房間溫度 | 16393 | RoomTemp_064 | _065 | 0 | 16393 | |
| 1-00 | Set Room Temperature 設定房間溫度 | 8405002 | TempAdjust_064 | _065 | 2 | 16394 | set |
| 1-00 | Filer Limit Sign 過濾限制通知 | 12599307 | FilterSign_064 | _065 | 3 | 16395 | |
| 1-00 | Filter Limit Sign Reset 重設過濾限制通知 | 20987916 | FilterSignReset_064 | _065 | 5 | 16396 | |
| 1-00 | Remote Control Operation (ON/OFF) 遙控器運轉(開/關) | 20987917 | RemoteControlStart_064 | _065 | 5 | 16397 | |
| 1-00 | Remote Control Operation (Operation Mode) 遙控器運轉(運轉模式) | 20987918 | RemoteControlAirConModeSet_064 | _065 | 5 | 16398 | |
| 1-00 | Remote Control Operation (Set Temperature) 遙控器運轉(設定溫度) | 20987920 | RemoteControlTempAdjust_064 | _065 | 5 | 16400 | |
| 1-00 | Remote Control Operation (Sub Group Address Control Rejection) 遙控器運轉(子組位置拒絕控制) | 20987921 | CL_Rejection_064 | _065 | 5 | 16401 | |
| 1-00 | Elec Total Power Elec總功率 | 96485395 | ElecTotalPower_064 | _065 | 23 | 16403 | |
| 1-00 | Communication Status 溝通狀態 | 12599316 | CommunicationStatus_064 | _065 | 3 | 16404 | |
| 1-00 | System Forced OFF 系統強制關閉 | 20987925 | SystemForcedOff_064 | _065 | 5 | 16405 | |
| 1-00 | Air Direction (setting) 風向(設定) | 8405014 | AirDirectionCommand_064 | _065 | 2 | 16406 | |
| 1-00 | Air Direction (status) 風向(狀態) | 16407 | AirDirectionStatus_064 | _065 | 0 | 16407 | |
| 1-00 | Forced Thermostat OFF (setting) 強制恆溫器關閉(設定) | 16793624 | ForcedThermoOFFCommand_064 | _065 | 4 | 16408 | |
| 1-00 | Forced Thermostat OFF (status) 強制恆溫器關閉(狀態) | 12599321 | ForcedThermoOFFStatus_064 | _065 | 3 | 16409 | |
| 1-00 | Energy Efficiency Command (setting) 能源效率指令(設定) | 16793626 | EnergyEfficiencyCommand_064 | _065 | 4 | 16410 | |
| 1-00 | Energy Efficiency Command (status) 能源效率指令(狀態) | 12599323 | EnergyEfficiencyStatus_064 | _065 | 3 | 16411 | |
| 1-00 | Thermostat Status 恆溫器狀態 | 12599324 | ThermoStatus_064 | _065 | 3 | 16412 | |
| 1-00 | Compressor Status 壓縮機狀態 | 12599325 | CompressorStatus_064 | _065 | 3 | 16413 | |
| 1-00 | Indoor Fan Status 室內風扇狀態 | 12599326 | IndoorFanStatus_064 | _065 | 3 | 16414 | |
| 1-00 | Heater Operation Status 暖氣運轉狀態 | 12599327 | HeaterStatus_064 | _065 | 3 | 16415 | |
| 1-00 | Ventilation Mode (setting) 通風模式(設定) | 58736672 | VentilationModeCommand_064 | _065 | 14 | 16416 | |
| 1-00 | Ventilation Mode (status) 通風模式(狀態) | 54542369 | VentilationModeStatus_064 | _065 | 13 | 16417 | |
| 1-00 | Ventilation Amount (setting) 通風總和(設定) | 58736674 | VentilationAmountCommand_064 | _065 | 14 | 16418 | |
| 1-00 | Ventilation Amount (status) 通風總和(狀態) | 54542371 | VentilationAmountStatus_064 | _065 | 13 | 16419 | |
| 1-01 | ON/OFF (setting) | 16793857 | StartStopCommand_065 | _066 | 4 | 16641 | set |
| 1-01 | ON/OFF (status) | 12599554 | StartStopStatus_065 | _066 | 3 | 16642 | Fb |
| 1-01 | Alarm Sign | 12599555 | Alarm_065 | _066 | 3 | 16643 | |
| 1-01 | Error Code | 54542596 | MalfunctionCode_065 | _066 | 13 | 16644 | |
| 1-01 | Operation Mode (setting) | 58736901 | AirConModeCommand_065 | _066 | 14 | 16645 | set |
| 1-01 | Operation Mode (status) | 54542598 | AirConModeStatus_065 | _066 | 13 | 16646 | Fb |
| 1-01 | Airflow Rate (setting) | 58736903 | AirFlowRateCommand_065 | _066 | 14 | 16647 | set |
| 1-01 | Airflow Rate (status) | 54542600 | AirFlowRateStatus_065 | _066 | 13 | 16648 | Fb |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 1-01 | Measured Room Temperature | 16649 | RoomTemp | _065 | _066 | 0 | 16649 | |
| 1-01 | Set Room Temperature | 8405258 | TempAdjust | _065 | _066 | 2 | 16650 | set |
| 1-01 | Filer Limit Sign | 12599563 | FilterSign | _065 | _066 | 3 | 16651 | |
| 1-01 | Filter Limit Sign Reset | 20988172 | FilterSignReset | _065 | _066 | 5 | 16652 | |
| 1-01 | Remote Control Operation (ON/OFF) | 20988173 | RemoteControlStart | _065 | _066 | 5 | 16653 | |
| 1-01 | Remote Control Operation (Operation Mode) | 20988174 | RemoteControlAirConModeSet | _065 | _066 | 5 | 16654 | |
| 1-01 | Remote Control Operation (Set Temperature) | 20988176 | RemoteControlTempAdjust | _065 | _066 | 5 | 16656 | |
| 1-01 | Remote Control Operation (Sub Group Address Control Rejecti | 20988177 | CL_Rejection | _065 | _066 | 5 | 16657 | |
| 1-01 | Elec Total Power | 96485651 | ElecTotalPower | _065 | _066 | 23 | 16659 | |
| 1-01 | Communication Status | 12599572 | CommunicationStatus | _065 | _066 | 3 | 16660 | |
| 1-01 | System Forced OFF | 20988181 | SystemForcedOff | _065 | _066 | 5 | 16661 | |
| 1-01 | Air Direction (setting) | 8405270 | AirDirectionCommand | _065 | _066 | 2 | 16662 | |
| 1-01 | Air Direction (status) | 16663 | AirDirectionStatus | _065 | _066 | 0 | 16663 | |
| 1-01 | Forced Thermostat OFF (setting) | 16793880 | ForcedThermoOFFCommand | _065 | _066 | 4 | 16664 | |
| 1-01 | Forced Thermostat OFF (status) | 12599577 | ForcedThermoOFFStatus | _065 | _066 | 3 | 16665 | |
| 1-01 | Energy Efficiency Command (setting) | 16793882 | EnergyEfficiencyCommand | _065 | _066 | 4 | 16666 | |
| 1-01 | Energy Efficiency Command (status) | 12599579 | EnergyEfficiencyStatus | _065 | _066 | 3 | 16667 | |
| 1-01 | Thermostat Status | 12599580 | ThermoStatus | _065 | _066 | 3 | 16668 | |
| 1-01 | Compressor Status | 12599581 | CompressorStatus | _065 | _066 | 3 | 16669 | |
| 1-01 | Indoor Fan Status | 12599582 | IndoorFanStatus | _065 | _066 | 3 | 16670 | |
| 1-01 | Heater Operation Status | 12599583 | HeaterStatus | _065 | _066 | 3 | 16671 | |
| 1-01 | Ventilation Mode (setting) | 58736928 | VentilationModeCommand | _065 | _066 | 14 | 16672 | |
| 1-01 | Ventilation Mode (status) | 54542625 | VentilationModeStatus | _065 | _066 | 13 | 16673 | |
| 1-01 | Ventilation Amount (setting) | 58736930 | VentilationAmountCommand | _065 | _066 | 14 | 16674 | |
| 1-01 | Ventilation Amount (status) | 54542627 | VentilationAmountStatus | _065 | _066 | 13 | 16675 | |
| 1-02 | ON/OFF (setting) | 16794113 | StartStopCommand | _066 | _067 | 4 | 16897 | set |
| 1-02 | ON/OFF (status) | 12599810 | StartStopStatus | _066 | _067 | 3 | 16898 | Fb |
| 1-02 | Alarm Sign | 12599811 | Alarm | _066 | _067 | 3 | 16899 | |
| 1-02 | Error Code | 54542852 | MalfunctionCode | _066 | _067 | 13 | 16900 | |
| 1-02 | Operation Mode (setting) | 58737157 | AirConModeCommand | _066 | _067 | 14 | 16901 | set |
| 1-02 | Operation Mode (status) | 54542854 | AirConModeStatus | _066 | _067 | 13 | 16902 | Fb |
| 1-02 | Airflow Rate (setting) | 58737159 | AirFlowRateCommand | _066 | _067 | 14 | 16903 | set |
| 1-02 | Airflow Rate (status) | 54542856 | AirFlowRateStatus | _066 | _067 | 13 | 16904 | Fb |
| 1-02 | Measured Room Temperature | 16905 | RoomTemp | _066 | _067 | 0 | 16905 | |
| 1-02 | Set Room Temperature | 8405514 | TempAdjust | _066 | _067 | 2 | 16906 | set |
| 1-02 | Filer Limit Sign | 12599819 | FilterSign | _066 | _067 | 3 | 16907 | |
| 1-02 | Filter Limit Sign Reset | 20988428 | FilterSignReset | _066 | _067 | 5 | 16908 | |
| 1-02 | Remote Control Operation (ON/OFF) | 20988429 | RemoteControlStart | _066 | _067 | 5 | 16909 | |
| 1-02 | Remote Control Operation (Operation Mode) | 20988430 | RemoteControlAirConModeSet | _066 | _067 | 5 | 16910 | |
| 1-02 | Remote Control Operation (Set Temperature) | 20988432 | RemoteControlTempAdjust | _066 | _067 | 5 | 16912 | |
| 1-02 | Remote Control Operation (Sub Group Address Control Rejecti | 20988433 | CL_Rejection | _066 | _067 | 5 | 16913 | |
| 1-02 | Elec Total Power | 96485907 | ElecTotalPower | _066 | _067 | 23 | 16915 | |
| 1-02 | Communication Status | 12599828 | CommunicationStatus | _066 | _067 | 3 | 16916 | |
| 1-02 | System Forced OFF | 20988437 | SystemForcedOff | _066 | _067 | 5 | 16917 | |
| 1-02 | Air Direction (setting) | 8405526 | AirDirectionCommand | _066 | _067 | 2 | 16918 | |
| 1-02 | Air Direction (status) | 16919 | AirDirectionStatus | _066 | _067 | 0 | 16919 | |
| 1-02 | Forced Thermostat OFF (setting) | 16794136 | ForcedThermoOFFCommand | _066 | _067 | 4 | 16920 | |
| 1-02 | Forced Thermostat OFF (status) | 12599833 | ForcedThermoOFFStatus | _066 | _067 | 3 | 16921 | |
| 1-02 | Energy Efficiency Command (setting) | 16794138 | EnergyEfficiencyCommand | _066 | _067 | 4 | 16922 | |
| 1-02 | Energy Efficiency Command (status) | 12599835 | EnergyEfficiencyStatus | _066 | _067 | 3 | 16923 | |
| 1-02 | Thermostat Status | 12599836 | ThermoStatus | _066 | _067 | 3 | 16924 | |
| 1-02 | Compressor Status | 12599837 | CompressorStatus | _066 | _067 | 3 | 16925 | |
| 1-02 | Indoor Fan Status | 12599838 | IndoorFanStatus | _066 | _067 | 3 | 16926 | |
| 1-02 | Heater Operation Status | 12599839 | HeaterStatus | _066 | _067 | 3 | 16927 | |
| 1-02 | Ventilation Mode (setting) | 58737184 | VentilationModeCommand | _066 | _067 | 14 | 16928 | |
| 1-02 | Ventilation Mode (status) | 54542881 | VentilationModeStatus | _066 | _067 | 13 | 16929 | |
| 1-02 | Ventilation Amount (setting) | 58737186 | VentilationAmountCommand | _066 | _067 | 14 | 16930 | |
| 1-02 | Ventilation Amount (status) | 54542883 | VentilationAmountStatus | _066 | _067 | 13 | 16931 | |
| 1-03 | ON/OFF (setting) | 16794369 | StartStopCommand | _067 | _068 | 4 | 17153 | set |
| 1-03 | ON/OFF (status) | 12600066 | StartStopStatus | _067 | _068 | 3 | 17154 | Fb |
| 1-03 | Alarm Sign | 12600067 | Alarm | _067 | _068 | 3 | 17155 | |
| 1-03 | Error Code | 54543108 | MalfunctionCode | _067 | _068 | 13 | 17156 | |
| 1-03 | Operation Mode (setting) | 58737413 | AirConModeCommand | _067 | _068 | 14 | 17157 | set |
| 1-03 | Operation Mode (status) | 54543110 | AirConModeStatus | _067 | _068 | 13 | 17158 | Fb |
| 1-03 | Airflow Rate (setting) | 58737415 | AirFlowRateCommand | _067 | _068 | 14 | 17159 | set |
| 1-03 | Airflow Rate (status) | 54543112 | AirFlowRateStatus | _067 | _068 | 13 | 17160 | Fb |
| 1-03 | Measured Room Temperature | 17161 | RoomTemp | _067 | _068 | 0 | 17161 | |
| 1-03 | Set Room Temperature | 8405770 | TempAdjust | _067 | _068 | 2 | 17162 | set |
| 1-03 | Filer Limit Sign | 12600075 | FilterSign | _067 | _068 | 3 | 17163 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 1-03 | Filter Limit Sign Reset | 20988684 | FilterSignReset | _067 | _068 | 5 | 17164 | |
| 1-03 | Remote Control Operation (ON/OFF) | 20988685 | RemoteControlStart | _067 | _068 | 5 | 17165 | |
| 1-03 | Remote Control Operation (Operation Mode) | 20988686 | RemoteControlAirConModeSet | _067 | _068 | 5 | 17166 | |
| 1-03 | Remote Control Operation (Set Temperature) | 20988688 | RemoteControlTempAdjust | _067 | _068 | 5 | 17168 | |
| 1-03 | Remote Control Operation (Sub Group Address Control Rejecti | 20988689 | CL_Rejection | _067 | _068 | 5 | 17169 | |
| 1-03 | Elec Total Power | 96486163 | ElecTotalPower | _067 | _068 | 23 | 17171 | |
| 1-03 | Communication Status | 12600084 | CommunicationStatus | _067 | _068 | 3 | 17172 | |
| 1-03 | System Forced OFF | 20988693 | SystemForcedOff | _067 | _068 | 5 | 17173 | |
| 1-03 | Air Direction (setting) | 8405782 | AirDirectionCommand | _067 | _068 | 2 | 17174 | |
| 1-03 | Air Direction (status) | 17175 | AirDirectionStatus | _067 | _068 | 0 | 17175 | |
| 1-03 | Forced Thermostat OFF (setting) | 16794392 | ForcedThermoOFFCommand | _067 | _068 | 4 | 17176 | |
| 1-03 | Forced Thermostat OFF (status) | 12600089 | ForcedThermoOFFStatus | _067 | _068 | 3 | 17177 | |
| 1-03 | Energy Efficiency Command (setting) | 16794394 | EnergyEfficiencyCommand | _067 | _068 | 4 | 17178 | |
| 1-03 | Energy Efficiency Command (status) | 12600091 | EnergyEfficiencyStatus | _067 | _068 | 3 | 17179 | |
| 1-03 | Thermostat Status | 12600092 | ThermoStatus | _067 | _068 | 3 | 17180 | |
| 1-03 | Compressor Status | 12600093 | CompressorStatus | _067 | _068 | 3 | 17181 | |
| 1-03 | Indoor Fan Status | 12600094 | IndoorFanStatus | _067 | _068 | 3 | 17182 | |
| 1-03 | Heater Operation Status | 12600095 | HeaterStatus | _067 | _068 | 3 | 17183 | |
| 1-03 | Ventilation Mode (setting) | 58737440 | VentilationModeCommand | _067 | _068 | 14 | 17184 | |
| 1-03 | Ventilation Mode (status) | 54543137 | VentilationModeStatus | _067 | _068 | 13 | 17185 | |
| 1-03 | Ventilation Amount (setting) | 58737442 | VentilationAmountCommand | _067 | _068 | 14 | 17186 | |
| 1-03 | Ventilation Amount (status) | 54543139 | VentilationAmountStatus | _067 | _068 | 13 | 17187 | |
| 1-04 | ON/OFF (setting) | 16794625 | StartStopCommand | _068 | _069 | 4 | 17409 | set |
| 1-04 | ON/OFF (status) | 12600322 | StartStopStatus | _068 | _069 | 3 | 17410 | Fb |
| 1-04 | Alarm Sign | 12600323 | Alarm | _068 | _069 | 3 | 17411 | |
| 1-04 | Error Code | 54543364 | MalfunctionCode | _068 | _069 | 13 | 17412 | |
| 1-04 | Operation Mode (setting) | 58737669 | AirConModeCommand | _068 | _069 | 14 | 17413 | set |
| 1-04 | Operation Mode (status) | 54543366 | AirConModeStatus | _068 | _069 | 13 | 17414 | Fb |
| 1-04 | Airflow Rate (setting) | 58737671 | AirFlowRateCommand | _068 | _069 | 14 | 17415 | set |
| 1-04 | Airflow Rate (status) | 54543368 | AirFlowRateStatus | _068 | _069 | 13 | 17416 | Fb |
| 1-04 | Measured Room Temperature | 17417 | RoomTemp | _068 | _069 | 0 | 17417 | |
| 1-04 | Set Room Temperature | 8406026 | TempAdjust | _068 | _069 | 2 | 17418 | set |
| 1-04 | Filer Limit Sign | 12600331 | FilterSign | _068 | _069 | 3 | 17419 | |
| 1-04 | Filter Limit Sign Reset | 20988940 | FilterSignReset | _068 | _069 | 5 | 17420 | |
| 1-04 | Remote Control Operation (ON/OFF) | 20988941 | RemoteControlStart | _068 | _069 | 5 | 17421 | |
| 1-04 | Remote Control Operation (Operation Mode) | 20988942 | RemoteControlAirConModeSet | _068 | _069 | 5 | 17422 | |
| 1-04 | Remote Control Operation (Set Temperature) | 20988944 | RemoteControlTempAdjust | _068 | _069 | 5 | 17424 | |
| 1-04 | Remote Control Operation (Sub Group Address Control Rejecti | 20988945 | CL_Rejection | _068 | _069 | 5 | 17425 | |
| 1-04 | Elec Total Power | 96486419 | ElecTotalPower | _068 | _069 | 23 | 17427 | |
| 1-04 | Communication Status | 12600340 | CommunicationStatus | _068 | _069 | 3 | 17428 | |
| 1-04 | System Forced OFF | 20988949 | SystemForcedOff | _068 | _069 | 5 | 17429 | |
| 1-04 | Air Direction (setting) | 8406038 | AirDirectionCommand | _068 | _069 | 2 | 17430 | |
| 1-04 | Air Direction (status) | 17431 | AirDirectionStatus | _068 | _069 | 0 | 17431 | |
| 1-04 | Forced Thermostat OFF (setting) | 16794648 | ForcedThermoOFFCommand | _068 | _069 | 4 | 17432 | |
| 1-04 | Forced Thermostat OFF (status) | 12600345 | ForcedThermoOFFStatus | _068 | _069 | 3 | 17433 | |
| 1-04 | Energy Efficiency Command (setting) | 16794650 | EnergyEfficiencyCommand | _068 | _069 | 4 | 17434 | |
| 1-04 | Energy Efficiency Command (status) | 12600347 | EnergyEfficiencyStatus | _068 | _069 | 3 | 17435 | |
| 1-04 | Thermostat Status | 12600348 | ThermoStatus | _068 | _069 | 3 | 17436 | |
| 1-04 | Compressor Status | 12600349 | CompressorStatus | _068 | _069 | 3 | 17437 | |
| 1-04 | Indoor Fan Status | 12600350 | IndoorFanStatus | _068 | _069 | 3 | 17438 | |
| 1-04 | Heater Operation Status | 12600351 | HeaterStatus | _068 | _069 | 3 | 17439 | |
| 1-04 | Ventilation Mode (setting) | 58737696 | VentilationModeCommand | _068 | _069 | 14 | 17440 | |
| 1-04 | Ventilation Mode (status) | 54543393 | VentilationModeStatus | _068 | _069 | 13 | 17441 | |
| 1-04 | Ventilation Amount (setting) | 58737698 | VentilationAmountCommand | _068 | _069 | 14 | 17442 | |
| 1-04 | Ventilation Amount (status) | 54543395 | VentilationAmountStatus | _068 | _069 | 13 | 17443 | |
| 1-05 | ON/OFF (setting) | 16794881 | StartStopCommand | _069 | _070 | 4 | 17665 | set |
| 1-05 | ON/OFF (status) | 12600578 | StartStopStatus | _069 | _070 | 3 | 17666 | Fb |
| 1-05 | Alarm Sign | 12600579 | Alarm | _069 | _070 | 3 | 17667 | |
| 1-05 | Error Code | 54543620 | MalfunctionCode | _069 | _070 | 13 | 17668 | |
| 1-05 | Operation Mode (setting) | 58737925 | AirConModeCommand | _069 | _070 | 14 | 17669 | set |
| 1-05 | Operation Mode (status) | 54543622 | AirConModeStatus | _069 | _070 | 13 | 17670 | Fb |
| 1-05 | Airflow Rate (setting) | 58737927 | AirFlowRateCommand | _069 | _070 | 14 | 17671 | set |
| 1-05 | Airflow Rate (status) | 54543624 | AirFlowRateStatus | _069 | _070 | 13 | 17672 | Fb |
| 1-05 | Measured Room Temperature | 17673 | RoomTemp | _069 | _070 | 0 | 17673 | |
| 1-05 | Set Room Temperature | 8406282 | TempAdjust | _069 | _070 | 2 | 17674 | set |
| 1-05 | Filer Limit Sign | 12600587 | FilterSign | _069 | _070 | 3 | 17675 | |
| 1-05 | Filter Limit Sign Reset | 20989196 | FilterSignReset | _069 | _070 | 5 | 17676 | |
| 1-05 | Remote Control Operation (ON/OFF) | 20989197 | RemoteControlStart | _069 | _070 | 5 | 17677 | |
| 1-05 | Remote Control Operation (Operation Mode) | 20989198 | RemoteControlAirConModeSet | _069 | _070 | 5 | 17678 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 1-05 | Remote Control Operation (Set Temperature) | 20989200 | RemoteControlTempAdjust | _069 | _070 | 5 | 17680 | |
| 1-05 | Remote Control Operation (Sub Group Address Control Rejecti | 20989201 | CL_Rejection | _069 | _070 | 5 | 17681 | |
| 1-05 | Elec Total Power | 96486675 | ElecTotalPower | _069 | _070 | 23 | 17683 | |
| 1-05 | Communication Status | 12600596 | CommunicationStatus | _069 | _070 | 3 | 17684 | |
| 1-05 | System Forced OFF | 20989205 | SystemForcedOff | _069 | _070 | 5 | 17685 | |
| 1-05 | Air Direction (setting) | 8406294 | AirDirectionCommand | _069 | _070 | 2 | 17686 | |
| 1-05 | Air Direction (status) | 17687 | AirDirectionStatus | _069 | _070 | 0 | 17687 | |
| 1-05 | Forced Thermostat OFF (setting) | 16794904 | ForcedThermoOFFCommand | _069 | _070 | 4 | 17688 | |
| 1-05 | Forced Thermostat OFF (status) | 12600601 | ForcedThermoOFFStatus | _069 | _070 | 3 | 17689 | |
| 1-05 | Energy Efficiency Command (setting) | 16794906 | EnergyEfficiencyCommand | _069 | _070 | 4 | 17690 | |
| 1-05 | Energy Efficiency Command (status) | 12600603 | EnergyEfficiencyStatus | _069 | _070 | 3 | 17691 | |
| 1-05 | Thermostat Status | 12600604 | ThermoStatus | _069 | _070 | 3 | 17692 | |
| 1-05 | Compressor Status | 12600605 | CompressorStatus | _069 | _070 | 3 | 17693 | |
| 1-05 | Indoor Fan Status | 12600606 | IndoorFanStatus | _069 | _070 | 3 | 17694 | |
| 1-05 | Heater Operation Status | 12600607 | HeaterStatus | _069 | _070 | 3 | 17695 | |
| 1-05 | Ventilation Mode (setting) | 58737952 | VentilationModeCommand | _069 | _070 | 14 | 17696 | |
| 1-05 | Ventilation Mode (status) | 54543649 | VentilationModeStatus | _069 | _070 | 13 | 17697 | |
| 1-05 | Ventilation Amount (setting) | 58737954 | VentilationAmountCommand | _069 | _070 | 14 | 17698 | |
| 1-05 | Ventilation Amount (status) | 54543651 | VentilationAmountStatus | _069 | _070 | 13 | 17699 | |
| 1-06 | ON/OFF (setting) | 16795137 | StartStopCommand | _070 | _071 | 4 | 17921 | set |
| 1-06 | ON/OFF (status) | 12600834 | StartStopStatus | _070 | _071 | 3 | 17922 | Fb |
| 1-06 | Alarm Sign | 12600835 | Alarm | _070 | _071 | 3 | 17923 | |
| 1-06 | Error Code | 54543876 | MalfunctionCode | _070 | _071 | 13 | 17924 | |
| 1-06 | Operation Mode (setting) | 58738181 | AirConModeCommand | _070 | _071 | 14 | 17925 | set |
| 1-06 | Operation Mode (status) | 54543878 | AirConModeStatus | _070 | _071 | 13 | 17926 | Fb |
| 1-06 | Airflow Rate (setting) | 58738183 | AirFlowRateCommand | _070 | _071 | 14 | 17927 | set |
| 1-06 | Airflow Rate (status) | 54543880 | AirFlowRateStatus | _070 | _071 | 13 | 17928 | Fb |
| 1-06 | Measured Room Temperature | 17929 | RoomTemp | _070 | _071 | 0 | 17929 | |
| 1-06 | Set Room Temperature | 8406538 | TempAdjust | _070 | _071 | 2 | 17930 | set |
| 1-06 | Filer Limit Sign | 12600843 | FilterSign | _070 | _071 | 3 | 17931 | |
| 1-06 | Filter Limit Sign Reset | 20989452 | FilterSignReset | _070 | _071 | 5 | 17932 | |
| 1-06 | Remote Control Operation (ON/OFF) | 20989453 | RemoteControlStart | _070 | _071 | 5 | 17933 | |
| 1-06 | Remote Control Operation (Operation Mode) | 20989454 | RemoteControlAirConModeSet | _070 | _071 | 5 | 17934 | |
| 1-06 | Remote Control Operation (Set Temperature) | 20989456 | RemoteControlTempAdjust | _070 | _071 | 5 | 17936 | |
| 1-06 | Remote Control Operation (Sub Group Address Control Rejecti | 20989457 | CL_Rejection | _070 | _071 | 5 | 17937 | |
| 1-06 | Elec Total Power | 96486931 | ElecTotalPower | _070 | _071 | 23 | 17939 | |
| 1-06 | Communication Status | 12600852 | CommunicationStatus | _070 | _071 | 3 | 17940 | |
| 1-06 | System Forced OFF | 20989461 | SystemForcedOff | _070 | _071 | 5 | 17941 | |
| 1-06 | Air Direction (setting) | 8406550 | AirDirectionCommand | _070 | _071 | 2 | 17942 | |
| 1-06 | Air Direction (status) | 17943 | AirDirectionStatus | _070 | _071 | 0 | 17943 | |
| 1-06 | Forced Thermostat OFF (setting) | 16795160 | ForcedThermoOFFCommand | _070 | _071 | 4 | 17944 | |
| 1-06 | Forced Thermostat OFF (status) | 12600857 | ForcedThermoOFFStatus | _070 | _071 | 3 | 17945 | |
| 1-06 | Energy Efficiency Command (setting) | 16795162 | EnergyEfficiencyCommand | _070 | _071 | 4 | 17946 | |
| 1-06 | Energy Efficiency Command (status) | 12600859 | EnergyEfficiencyStatus | _070 | _071 | 3 | 17947 | |
| 1-06 | Thermostat Status | 12600860 | ThermoStatus | _070 | _071 | 3 | 17948 | |
| 1-06 | Compressor Status | 12600861 | CompressorStatus | _070 | _071 | 3 | 17949 | |
| 1-06 | Indoor Fan Status | 12600862 | IndoorFanStatus | _070 | _071 | 3 | 17950 | |
| 1-06 | Heater Operation Status | 12600863 | HeaterStatus | _070 | _071 | 3 | 17951 | |
| 1-06 | Ventilation Mode (setting) | 58738208 | VentilationModeCommand | _070 | _071 | 14 | 17952 | |
| 1-06 | Ventilation Mode (status) | 54543905 | VentilationModeStatus | _070 | _071 | 13 | 17953 | |
| 1-06 | Ventilation Amount (setting) | 58738210 | VentilationAmountCommand | _070 | _071 | 14 | 17954 | |
| 1-06 | Ventilation Amount (status) | 54543907 | VentilationAmountStatus | _070 | _071 | 13 | 17955 | |
| 1-07 | ON/OFF (setting) | 16795393 | StartStopCommand | _071 | _072 | 4 | 18177 | set |
| 1-07 | ON/OFF (status) | 12601090 | StartStopStatus | _071 | _072 | 3 | 18178 | Fb |
| 1-07 | Alarm Sign | 12601091 | Alarm | _071 | _072 | 3 | 18179 | |
| 1-07 | Error Code | 54544132 | MalfunctionCode | _071 | _072 | 13 | 18180 | |
| 1-07 | Operation Mode (setting) | 58738437 | AirConModeCommand | _071 | _072 | 14 | 18181 | set |
| 1-07 | Operation Mode (status) | 54544134 | AirConModeStatus | _071 | _072 | 13 | 18182 | Fb |
| 1-07 | Airflow Rate (setting) | 58738439 | AirFlowRateCommand | _071 | _072 | 14 | 18183 | set |
| 1-07 | Airflow Rate (status) | 54544136 | AirFlowRateStatus | _071 | _072 | 13 | 18184 | Fb |
| 1-07 | Measured Room Temperature | 18185 | RoomTemp | _071 | _072 | 0 | 18185 | |
| 1-07 | Set Room Temperature | 8406794 | TempAdjust | _071 | _072 | 2 | 18186 | set |
| 1-07 | Filer Limit Sign | 12601099 | FilterSign | _071 | _072 | 3 | 18187 | |
| 1-07 | Filter Limit Sign Reset | 20989708 | FilterSignReset | _071 | _072 | 5 | 18188 | |
| 1-07 | Remote Control Operation (ON/OFF) | 20989709 | RemoteControlStart | _071 | _072 | 5 | 18189 | |
| 1-07 | Remote Control Operation (Operation Mode) | 20989710 | RemoteControlAirConModeSet | _071 | _072 | 5 | 18190 | |
| 1-07 | Remote Control Operation (Set Temperature) | 20989712 | RemoteControlTempAdjust | _071 | _072 | 5 | 18192 | |
| 1-07 | Remote Control Operation (Sub Group Address Control Rejecti | 20989713 | CL_Rejection | _071 | _072 | 5 | 18193 | |
| 1-07 | Elec Total Power | 96487187 | ElecTotalPower | _071 | _072 | 23 | 18195 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 1-07 | Communication Status | 12601108 | CommunicationStatus | _071 | _072 | 3 | 18196 | |
| 1-07 | System Forced OFF | 20989717 | SystemForcedOff | _071 | _072 | 5 | 18197 | |
| 1-07 | Air Direction (setting) | 8406806 | AirDirectionCommand | _071 | _072 | 2 | 18198 | |
| 1-07 | Air Direction (status) | 18199 | AirDirectionStatus | _071 | _072 | 0 | 18199 | |
| 1-07 | Forced Thermostat OFF (setting) | 16795416 | ForcedThermoOFFCommand | _071 | _072 | 4 | 18200 | |
| 1-07 | Forced Thermostat OFF (status) | 12601113 | ForcedThermoOFFStatus | _071 | _072 | 3 | 18201 | |
| 1-07 | Energy Efficiency Command (setting) | 16795418 | EnergyEfficiencyCommand | _071 | _072 | 4 | 18202 | |
| 1-07 | Energy Efficiency Command (status) | 12601115 | EnergyEfficiencyStatus | _071 | _072 | 3 | 18203 | |
| 1-07 | Thermostat Status | 12601116 | ThermoStatus | _071 | _072 | 3 | 18204 | |
| 1-07 | Compressor Status | 12601117 | CompressorStatus | _071 | _072 | 3 | 18205 | |
| 1-07 | Indoor Fan Status | 12601118 | IndoorFanStatus | _071 | _072 | 3 | 18206 | |
| 1-07 | Heater Operation Status | 12601119 | HeaterStatus | _071 | _072 | 3 | 18207 | |
| 1-07 | Ventilation Mode (setting) | 58738464 | VentilationModeCommand | _071 | _072 | 14 | 18208 | |
| 1-07 | Ventilation Mode (status) | 54544161 | VentilationModeStatus | _071 | _072 | 13 | 18209 | |
| 1-07 | Ventilation Amount (setting) | 58738466 | VentilationAmountCommand | _071 | _072 | 14 | 18210 | |
| 1-07 | Ventilation Amount (status) | 54544163 | VentilationAmountStatus | _071 | _072 | 13 | 18211 | |
| 1-08 | ON/OFF (setting) | 16795649 | StartStopCommand | _072 | _073 | 4 | 18433 | set |
| 1-08 | ON/OFF (status) | 12601346 | StartStopStatus | _072 | _073 | 3 | 18434 | Fb |
| 1-08 | Alarm Sign | 12601347 | Alarm | _072 | _073 | 3 | 18435 | |
| 1-08 | Error Code | 54544388 | MalfunctionCode | _072 | _073 | 13 | 18436 | |
| 1-08 | Operation Mode (setting) | 58738693 | AirConModeCommand | _072 | _073 | 14 | 18437 | set |
| 1-08 | Operation Mode (status) | 54544390 | AirConModeStatus | _072 | _073 | 13 | 18438 | Fb |
| 1-08 | Airflow Rate (setting) | 58738695 | AirFlowRateCommand | _072 | _073 | 14 | 18439 | set |
| 1-08 | Airflow Rate (status) | 54544392 | AirFlowRateStatus | _072 | _073 | 13 | 18440 | Fb |
| 1-08 | Measured Room Temperature | 18441 | RoomTemp | _072 | _073 | 0 | 18441 | |
| 1-08 | Set Room Temperature | 8407050 | TempAdjust | _072 | _073 | 2 | 18442 | set |
| 1-08 | Filer Limit Sign | 12601355 | FilterSign | _072 | _073 | 3 | 18443 | |
| 1-08 | Filter Limit Sign Reset | 20989964 | FilterSignReset | _072 | _073 | 5 | 18444 | |
| 1-08 | Remote Control Operation (ON/OFF) | 20989965 | RemoteControlStart | _072 | _073 | 5 | 18445 | |
| 1-08 | Remote Control Operation (Operation Mode) | 20989966 | RemoteControlAirConModeSet | _072 | _073 | 5 | 18446 | |
| 1-08 | Remote Control Operation (Set Temperature) | 20989968 | RemoteControlTempAdjust | _072 | _073 | 5 | 18448 | |
| 1-08 | Remote Control Operation (Sub Group Address Control Reject) | 20989969 | CL_Rejection | _072 | _073 | 5 | 18449 | |
| 1-08 | Elec Total Power | 96487443 | ElecTotalPower | _072 | _073 | 23 | 18451 | |
| 1-08 | Communication Status | 12601364 | CommunicationStatus | _072 | _073 | 3 | 18452 | |
| 1-08 | System Forced OFF | 20989973 | SystemForcedOff | _072 | _073 | 5 | 18453 | |
| 1-08 | Air Direction (setting) | 8407062 | AirDirectionCommand | _072 | _073 | 2 | 18454 | |
| 1-08 | Air Direction (status) | 18455 | AirDirectionStatus | _072 | _073 | 0 | 18455 | |
| 1-08 | Forced Thermostat OFF (setting) | 16795672 | ForcedThermoOFFCommand | _072 | _073 | 4 | 18456 | |
| 1-08 | Forced Thermostat OFF (status) | 12601369 | ForcedThermoOFFStatus | _072 | _073 | 3 | 18457 | |
| 1-08 | Energy Efficiency Command (setting) | 16795674 | EnergyEfficiencyCommand | _072 | _073 | 4 | 18458 | |
| 1-08 | Energy Efficiency Command (status) | 12601371 | EnergyEfficiencyStatus | _072 | _073 | 3 | 18459 | |
| 1-08 | Thermostat Status | 12601372 | ThermoStatus | _072 | _073 | 3 | 18460 | |
| 1-08 | Compressor Status | 12601373 | CompressorStatus | _072 | _073 | 3 | 18461 | |
| 1-08 | Indoor Fan Status | 12601374 | IndoorFanStatus | _072 | _073 | 3 | 18462 | |
| 1-08 | Heater Operation Status | 12601375 | HeaterStatus | _072 | _073 | 3 | 18463 | |
| 1-08 | Ventilation Mode (setting) | 58738720 | VentilationModeCommand | _072 | _073 | 14 | 18464 | |
| 1-08 | Ventilation Mode (status) | 54544417 | VentilationModeStatus | _072 | _073 | 13 | 18465 | |
| 1-08 | Ventilation Amount (setting) | 58738722 | VentilationAmountCommand | _072 | _073 | 14 | 18466 | |
| 1-08 | Ventilation Amount (status) | 54544419 | VentilationAmountStatus | _072 | _073 | 13 | 18467 | |
| 1-09 | ON/OFF (setting) | 16795905 | StartStopCommand | _073 | _074 | 4 | 18689 | set |
| 1-09 | ON/OFF (status) | 12601602 | StartStopStatus | _073 | _074 | 3 | 18690 | Fb |
| 1-09 | Alarm Sign | 12601603 | Alarm | _073 | _074 | 3 | 18691 | |
| 1-09 | Error Code | 54544644 | MalfunctionCode | _073 | _074 | 13 | 18692 | |
| 1-09 | Operation Mode (setting) | 58738949 | AirConModeCommand | _073 | _074 | 14 | 18693 | set |
| 1-09 | Operation Mode (status) | 54544646 | AirConModeStatus | _073 | _074 | 13 | 18694 | Fb |
| 1-09 | Airflow Rate (setting) | 58738951 | AirFlowRateCommand | _073 | _074 | 14 | 18695 | set |
| 1-09 | Airflow Rate (status) | 54544648 | AirFlowRateStatus | _073 | _074 | 13 | 18696 | Fb |
| 1-09 | Measured Room Temperature | 18697 | RoomTemp | _073 | _074 | 0 | 18697 | |
| 1-09 | Set Room Temperature | 8407306 | TempAdjust | _073 | _074 | 2 | 18698 | set |
| 1-09 | Filer Limit Sign | 12601611 | FilterSign | _073 | _074 | 3 | 18699 | |
| 1-09 | Filter Limit Sign Reset | 20990220 | FilterSignReset | _073 | _074 | 5 | 18700 | |
| 1-09 | Remote Control Operation (ON/OFF) | 20990221 | RemoteControlStart | _073 | _074 | 5 | 18701 | |
| 1-09 | Remote Control Operation (Operation Mode) | 20990222 | RemoteControlAirConModeSet | _073 | _074 | 5 | 18702 | |
| 1-09 | Remote Control Operation (Set Temperature) | 20990224 | RemoteControlTempAdjust | _073 | _074 | 5 | 18704 | |
| 1-09 | Remote Control Operation (Sub Group Address Control Reject) | 20990225 | CL_Rejection | _073 | _074 | 5 | 18705 | |
| 1-09 | Elec Total Power | 96487699 | ElecTotalPower | _073 | _074 | 23 | 18707 | |
| 1-09 | Communication Status | 12601620 | CommunicationStatus | _073 | _074 | 3 | 18708 | |
| 1-09 | System Forced OFF | 20990229 | SystemForcedOff | _073 | _074 | 5 | 18709 | |
| 1-09 | Air Direction (setting) | 8407318 | AirDirectionCommand | _073 | _074 | 2 | 18710 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 1-09 | Air Direction (status) | 18711 | AirDirectionStatus | _073 | _074 | 0 | 18711 | |
| 1-09 | Forced Thermostat OFF (setting) | 16795928 | ForcedThermoOFFCommand | _073 | _074 | 4 | 18712 | |
| 1-09 | Forced Thermostat OFF (status) | 12601625 | ForcedThermoOFFStatus | _073 | _074 | 3 | 18713 | |
| 1-09 | Energy Efficiency Command (setting) | 16795930 | EnergyEfficiencyCommand | _073 | _074 | 4 | 18714 | |
| 1-09 | Energy Efficiency Command (status) | 12601627 | EnergyEfficiencyStatus | _073 | _074 | 3 | 18715 | |
| 1-09 | Thermostat Status | 12601628 | ThermoStatus | _073 | _074 | 3 | 18716 | |
| 1-09 | Compressor Status | 12601629 | CompressorStatus | _073 | _074 | 3 | 18717 | |
| 1-09 | Indoor Fan Status | 12601630 | IndoorFanStatus | _073 | _074 | 3 | 18718 | |
| 1-09 | Heater Operation Status | 12601631 | HeaterStatus | _073 | _074 | 3 | 18719 | |
| 1-09 | Ventilation Mode (setting) | 58738976 | VentilationModeCommand | _073 | _074 | 14 | 18720 | |
| 1-09 | Ventilation Mode (status) | 54544673 | VentilationModeStatus | _073 | _074 | 13 | 18721 | |
| 1-09 | Ventilation Amount (setting) | 58738978 | VentilationAmountCommand | _073 | _074 | 14 | 18722 | |
| 1-09 | Ventilation Amount (status) | 54544675 | VentilationAmountStatus | _073 | _074 | 13 | 18723 | |
| 1-10 | ON/OFF (setting) | 16796161 | StartStopCommand | _074 | _075 | 4 | 18945 | set |
| 1-10 | ON/OFF (status) | 12601858 | StartStopStatus | _074 | _075 | 3 | 18946 | Fb |
| 1-10 | Alarm Sign | 12601859 | Alarm | _074 | _075 | 3 | 18947 | |
| 1-10 | Error Code | 54544900 | MalfunctionCode | _074 | _075 | 13 | 18948 | |
| 1-10 | Operation Mode (setting) | 58739205 | AirConModeCommand | _074 | _075 | 14 | 18949 | set |
| 1-10 | Operation Mode (status) | 54544902 | AirConModeStatus | _074 | _075 | 13 | 18950 | Fb |
| 1-10 | Airflow Rate (setting) | 58739207 | AirFlowRateCommand | _074 | _075 | 14 | 18951 | set |
| 1-10 | Airflow Rate (status) | 54544904 | AirFlowRateStatus | _074 | _075 | 13 | 18952 | Fb |
| 1-10 | Measured Room Temperature | 18953 | RoomTemp | _074 | _075 | 0 | 18953 | |
| 1-10 | Set Room Temperature | 8407562 | TempAdjust | _074 | _075 | 2 | 18954 | set |
| 1-10 | Filer Limit Sign | 12601867 | FilterSign | _074 | _075 | 3 | 18955 | |
| 1-10 | Filter Limit Sign Reset | 20990476 | FilterSignReset | _074 | _075 | 5 | 18956 | |
| 1-10 | Remote Control Operation (ON/OFF) | 20990477 | RemoteControlStart | _074 | _075 | 5 | 18957 | |
| 1-10 | Remote Control Operation (Operation Mode) | 20990478 | RemoteControlAirConModeSet | _074 | _075 | 5 | 18958 | |
| 1-10 | Remote Control Operation (Set Temperature) | 20990480 | RemoteControlTempAdjust | _074 | _075 | 5 | 18960 | |
| 1-10 | Remote Control Operation (Sub Group Address Control Reject) | 20990481 | CL_Rejection | _074 | _075 | 5 | 18961 | |
| 1-10 | Elec Total Power | 96487955 | ElecTotalPower | _074 | _075 | 23 | 18963 | |
| 1-10 | Communication Status | 12601876 | CommunicationStatus | _074 | _075 | 3 | 18964 | |
| 1-10 | System Forced OFF | 20990485 | SystemForcedOff | _074 | _075 | 5 | 18965 | |
| 1-10 | Air Direction (setting) | 8407574 | AirDirectionCommand | _074 | _075 | 2 | 18966 | |
| 1-10 | Air Direction (status) | 18967 | AirDirectionStatus | _074 | _075 | 0 | 18967 | |
| 1-10 | Forced Thermostat OFF (setting) | 16796184 | ForcedThermoOFFCommand | _074 | _075 | 4 | 18968 | |
| 1-10 | Forced Thermostat OFF (status) | 12601881 | ForcedThermoOFFStatus | _074 | _075 | 3 | 18969 | |
| 1-10 | Energy Efficiency Command (setting) | 16796186 | EnergyEfficiencyCommand | _074 | _075 | 4 | 18970 | |
| 1-10 | Energy Efficiency Command (status) | 12601883 | EnergyEfficiencyStatus | _074 | _075 | 3 | 18971 | |
| 1-10 | Thermostat Status | 12601884 | ThermoStatus | _074 | _075 | 3 | 18972 | |
| 1-10 | Compressor Status | 12601885 | CompressorStatus | _074 | _075 | 3 | 18973 | |
| 1-10 | Indoor Fan Status | 12601886 | IndoorFanStatus | _074 | _075 | 3 | 18974 | |
| 1-10 | Heater Operation Status | 12601887 | HeaterStatus | _074 | _075 | 3 | 18975 | |
| 1-10 | Ventilation Mode (setting) | 58739232 | VentilationModeCommand | _074 | _075 | 14 | 18976 | |
| 1-10 | Ventilation Mode (status) | 54544929 | VentilationModeStatus | _074 | _075 | 13 | 18977 | |
| 1-10 | Ventilation Amount (setting) | 58739234 | VentilationAmountCommand | _074 | _075 | 14 | 18978 | |
| 1-10 | Ventilation Amount (status) | 54544931 | VentilationAmountStatus | _074 | _075 | 13 | 18979 | |
| 1-11 | ON/OFF (setting) | 16796417 | StartStopCommand | _075 | _076 | 4 | 19201 | set |
| 1-11 | ON/OFF (status) | 12602114 | StartStopStatus | _075 | _076 | 3 | 19202 | Fb |
| 1-11 | Alarm Sign | 12602115 | Alarm | _075 | _076 | 3 | 19203 | |
| 1-11 | Error Code | 54545156 | MalfunctionCode | _075 | _076 | 13 | 19204 | |
| 1-11 | Operation Mode (setting) | 58739461 | AirConModeCommand | _075 | _076 | 14 | 19205 | set |
| 1-11 | Operation Mode (status) | 54545158 | AirConModeStatus | _075 | _076 | 13 | 19206 | Fb |
| 1-11 | Airflow Rate (setting) | 58739463 | AirFlowRateCommand | _075 | _076 | 14 | 19207 | set |
| 1-11 | Airflow Rate (status) | 54545160 | AirFlowRateStatus | _075 | _076 | 13 | 19208 | Fb |
| 1-11 | Measured Room Temperature | 19209 | RoomTemp | _075 | _076 | 0 | 19209 | |
| 1-11 | Set Room Temperature | 8407818 | TempAdjust | _075 | _076 | 2 | 19210 | set |
| 1-11 | Filer Limit Sign | 12602123 | FilterSign | _075 | _076 | 3 | 19211 | |
| 1-11 | Filter Limit Sign Reset | 20990732 | FilterSignReset | _075 | _076 | 5 | 19212 | |
| 1-11 | Remote Control Operation (ON/OFF) | 20990733 | RemoteControlStart | _075 | _076 | 5 | 19213 | |
| 1-11 | Remote Control Operation (Operation Mode) | 20990734 | RemoteControlAirConModeSet | _075 | _076 | 5 | 19214 | |
| 1-11 | Remote Control Operation (Set Temperature) | 20990736 | RemoteControlTempAdjust | _075 | _076 | 5 | 19216 | |
| 1-11 | Remote Control Operation (Sub Group Address Control Reject) | 20990737 | CL_Rejection | _075 | _076 | 5 | 19217 | |
| 1-11 | Elec Total Power | 96488211 | ElecTotalPower | _075 | _076 | 23 | 19219 | |
| 1-11 | Communication Status | 12602132 | CommunicationStatus | _075 | _076 | 3 | 19220 | |
| 1-11 | System Forced OFF | 20990741 | SystemForcedOff | _075 | _076 | 5 | 19221 | |
| 1-11 | Air Direction (setting) | 8407830 | AirDirectionCommand | _075 | _076 | 2 | 19222 | |
| 1-11 | Air Direction (status) | 19223 | AirDirectionStatus | _075 | _076 | 0 | 19223 | |
| 1-11 | Forced Thermostat OFF (setting) | 16796440 | ForcedThermoOFFCommand | _075 | _076 | 4 | 19224 | |
| 1-11 | Forced Thermostat OFF (status) | 12602137 | ForcedThermoOFFStatus | _075 | _076 | 3 | 19225 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 1-11 | Energy Efficiency Command (setting) | 16796442 | EnergyEfficiencyCommand | _075 | _076 | 4 | 19226 | |
| 1-11 | Energy Efficiency Command (status) | 12602139 | EnergyEfficiencyStatus | _075 | _076 | 3 | 19227 | |
| 1-11 | Thermostat Status | 12602140 | ThermoStatus | _075 | _076 | 3 | 19228 | |
| 1-11 | Compressor Status | 12602141 | CompressorStatus | _075 | _076 | 3 | 19229 | |
| 1-11 | Indoor Fan Status | 12602142 | IndoorFanStatus | _075 | _076 | 3 | 19230 | |
| 1-11 | Heater Operation Status | 12602143 | HeaterStatus | _075 | _076 | 3 | 19231 | |
| 1-11 | Ventilation Mode (setting) | 58739488 | VentilationModeCommand | _075 | _076 | 14 | 19232 | |
| 1-11 | Ventilation Mode (status) | 54545185 | VentilationModeStatus | _075 | _076 | 13 | 19233 | |
| 1-11 | Ventilation Amount (setting) | 58739490 | VentilationAmountCommand | _075 | _076 | 14 | 19234 | |
| 1-11 | Ventilation Amount (status) | 54545187 | VentilationAmountStatus | _075 | _076 | 13 | 19235 | |
| 1-12 | ON/OFF (setting) | 16796673 | StartStopCommand | _076 | _077 | 4 | 19457 | set |
| 1-12 | ON/OFF (status) | 12602370 | StartStopStatus | _076 | _077 | 3 | 19458 | Fb |
| 1-12 | Alarm Sign | 12602371 | Alarm | _076 | _077 | 3 | 19459 | |
| 1-12 | Error Code | 54545412 | MalfunctionCode | _076 | _077 | 13 | 19460 | |
| 1-12 | Operation Mode (setting) | 58739717 | AirConModeCommand | _076 | _077 | 14 | 19461 | set |
| 1-12 | Operation Mode (status) | 54545414 | AirConModeStatus | _076 | _077 | 13 | 19462 | Fb |
| 1-12 | Airflow Rate (setting) | 58739719 | AirFlowRateCommand | _076 | _077 | 14 | 19463 | set |
| 1-12 | Airflow Rate (status) | 54545416 | AirFlowRateStatus | _076 | _077 | 13 | 19464 | Fb |
| 1-12 | Measured Room Temperature | 19465 | RoomTemp | _076 | _077 | 0 | 19465 | |
| 1-12 | Set Room Temperature | 8408074 | TempAdjust | _076 | _077 | 2 | 19466 | set |
| 1-12 | Filer Limit Sign | 12602379 | FilterSign | _076 | _077 | 3 | 19467 | |
| 1-12 | Filter Limit Sign Reset | 20990988 | FilterSignReset | _076 | _077 | 5 | 19468 | |
| 1-12 | Remote Control Operation (ON/OFF) | 20990989 | RemoteControlStart | _076 | _077 | 5 | 19469 | |
| 1-12 | Remote Control Operation (Operation Mode) | 20990990 | RemoteControlAirConModeSet | _076 | _077 | 5 | 19470 | |
| 1-12 | Remote Control Operation (Set Temperature) | 20990992 | RemoteControlTempAdjust | _076 | _077 | 5 | 19472 | |
| 1-12 | Remote Control Operation (Sub Group Address Control Reject) | 20990993 | CL_Rejection | _076 | _077 | 5 | 19473 | |
| 1-12 | Elec Total Power | 96488467 | ElecTotalPower | _076 | _077 | 23 | 19475 | |
| 1-12 | Communication Status | 12602388 | CommunicationStatus | _076 | _077 | 3 | 19476 | |
| 1-12 | System Forced OFF | 20990997 | SystemForcedOff | _076 | _077 | 5 | 19477 | |
| 1-12 | Air Direction (setting) | 8408086 | AirDirectionCommand | _076 | _077 | 2 | 19478 | |
| 1-12 | Air Direction (status) | 19479 | AirDirectionStatus | _076 | _077 | 0 | 19479 | |
| 1-12 | Forced Thermostat OFF (setting) | 16796696 | ForcedThermoOFFCommand | _076 | _077 | 4 | 19480 | |
| 1-12 | Forced Thermostat OFF (status) | 12602393 | ForcedThermoOFFStatus | _076 | _077 | 3 | 19481 | |
| 1-12 | Energy Efficiency Command (setting) | 16796698 | EnergyEfficiencyCommand | _076 | _077 | 4 | 19482 | |
| 1-12 | Energy Efficiency Command (status) | 12602395 | EnergyEfficiencyStatus | _076 | _077 | 3 | 19483 | |
| 1-12 | Thermostat Status | 12602396 | ThermoStatus | _076 | _077 | 3 | 19484 | |
| 1-12 | Compressor Status | 12602397 | CompressorStatus | _076 | _077 | 3 | 19485 | |
| 1-12 | Indoor Fan Status | 12602398 | IndoorFanStatus | _076 | _077 | 3 | 19486 | |
| 1-12 | Heater Operation Status | 12602399 | HeaterStatus | _076 | _077 | 3 | 19487 | |
| 1-12 | Ventilation Mode (setting) | 58739744 | VentilationModeCommand | _076 | _077 | 14 | 19488 | |
| 1-12 | Ventilation Mode (status) | 54545441 | VentilationModeStatus | _076 | _077 | 13 | 19489 | |
| 1-12 | Ventilation Amount (setting) | 58739746 | VentilationAmountCommand | _076 | _077 | 14 | 19490 | |
| 1-12 | Ventilation Amount (status) | 54545443 | VentilationAmountStatus | _076 | _077 | 13 | 19491 | |
| 1-13 | ON/OFF (setting) | 16796929 | StartStopCommand | _077 | _078 | 4 | 19713 | set |
| 1-13 | ON/OFF (status) | 12602626 | StartStopStatus | _077 | _078 | 3 | 19714 | Fb |
| 1-13 | Alarm Sign | 12602627 | Alarm | _077 | _078 | 3 | 19715 | |
| 1-13 | Error Code | 54545668 | MalfunctionCode | _077 | _078 | 13 | 19716 | |
| 1-13 | Operation Mode (setting) | 58739973 | AirConModeCommand | _077 | _078 | 14 | 19717 | set |
| 1-13 | Operation Mode (status) | 54545670 | AirConModeStatus | _077 | _078 | 13 | 19718 | Fb |
| 1-13 | Airflow Rate (setting) | 58739975 | AirFlowRateCommand | _077 | _078 | 14 | 19719 | set |
| 1-13 | Airflow Rate (status) | 54545672 | AirFlowRateStatus | _077 | _078 | 13 | 19720 | Fb |
| 1-13 | Measured Room Temperature | 19721 | RoomTemp | _077 | _078 | 0 | 19721 | |
| 1-13 | Set Room Temperature | 8408330 | TempAdjust | _077 | _078 | 2 | 19722 | set |
| 1-13 | Filer Limit Sign | 12602635 | FilterSign | _077 | _078 | 3 | 19723 | |
| 1-13 | Filter Limit Sign Reset | 20991244 | FilterSignReset | _077 | _078 | 5 | 19724 | |
| 1-13 | Remote Control Operation (ON/OFF) | 20991245 | RemoteControlStart | _077 | _078 | 5 | 19725 | |
| 1-13 | Remote Control Operation (Operation Mode) | 20991246 | RemoteControlAirConModeSet | _077 | _078 | 5 | 19726 | |
| 1-13 | Remote Control Operation (Set Temperature) | 20991248 | RemoteControlTempAdjust | _077 | _078 | 5 | 19728 | |
| 1-13 | Remote Control Operation (Sub Group Address Control Reject) | 20991249 | CL_Rejection | _077 | _078 | 5 | 19729 | |
| 1-13 | Elec Total Power | 96488723 | ElecTotalPower | _077 | _078 | 23 | 19731 | |
| 1-13 | Communication Status | 12602644 | CommunicationStatus | _077 | _078 | 3 | 19732 | |
| 1-13 | System Forced OFF | 20991253 | SystemForcedOff | _077 | _078 | 5 | 19733 | |
| 1-13 | Air Direction (setting) | 8408342 | AirDirectionCommand | _077 | _078 | 2 | 19734 | |
| 1-13 | Air Direction (status) | 19735 | AirDirectionStatus | _077 | _078 | 0 | 19735 | |
| 1-13 | Forced Thermostat OFF (setting) | 16796952 | ForcedThermoOFFCommand | _077 | _078 | 4 | 19736 | |
| 1-13 | Forced Thermostat OFF (status) | 12602649 | ForcedThermoOFFStatus | _077 | _078 | 3 | 19737 | |
| 1-13 | Energy Efficiency Command (setting) | 16796954 | EnergyEfficiencyCommand | _077 | _078 | 4 | 19738 | |
| 1-13 | Energy Efficiency Command (status) | 12602651 | EnergyEfficiencyStatus | _077 | _078 | 3 | 19739 | |
| 1-13 | Thermostat Status | 12602652 | ThermoStatus | _077 | _078 | 3 | 19740 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 1-13 | Compressor Status | 12602653 | CompressorStatus | _077 | _078 | 3 | 19741 | |
| 1-13 | Indoor Fan Status | 12602654 | IndoorFanStatus | _077 | _078 | 3 | 19742 | |
| 1-13 | Heater Operation Status | 12602655 | HeaterStatus | _077 | _078 | 3 | 19743 | |
| 1-13 | Ventilation Mode (setting) | 58740000 | VentilationModeCommand | _077 | _078 | 14 | 19744 | |
| 1-13 | Ventilation Mode (status) | 54545697 | VentilationModeStatus | _077 | _078 | 13 | 19745 | |
| 1-13 | Ventilation Amount (setting) | 58740002 | VentilationAmountCommand | _077 | _078 | 14 | 19746 | |
| 1-13 | Ventilation Amount (status) | 54545699 | VentilationAmountStatus | _077 | _078 | 13 | 19747 | |
| 1-14 | ON/OFF (setting) | 16797185 | StartStopCommand | _078 | _079 | 4 | 19969 | set |
| 1-14 | ON/OFF (status) | 12602882 | StartStopStatus | _078 | _079 | 3 | 19970 | Fb |
| 1-14 | Alarm Sign | 12602883 | Alarm | _078 | _079 | 3 | 19971 | |
| 1-14 | Error Code | 54545924 | MalfunctionCode | _078 | _079 | 13 | 19972 | |
| 1-14 | Operation Mode (setting) | 58740229 | AirConModeCommand | _078 | _079 | 14 | 19973 | set |
| 1-14 | Operation Mode (status) | 54545926 | AirConModeStatus | _078 | _079 | 13 | 19974 | Fb |
| 1-14 | Airflow Rate (setting) | 58740231 | AirFlowRateCommand | _078 | _079 | 14 | 19975 | set |
| 1-14 | Airflow Rate (status) | 54545928 | AirFlowRateStatus | _078 | _079 | 13 | 19976 | Fb |
| 1-14 | Measured Room Temperature | 19977 | RoomTemp | _078 | _079 | 0 | 19977 | |
| 1-14 | Set Room Temperature | 8408586 | TempAdjust | _078 | _079 | 2 | 19978 | set |
| 1-14 | Filer Limit Sign | 12602891 | FilterSign | _078 | _079 | 3 | 19979 | |
| 1-14 | Filter Limit Sign Reset | 20991500 | FilterSignReset | _078 | _079 | 5 | 19980 | |
| 1-14 | Remote Control Operation (ON/OFF) | 20991501 | RemoteControlStart | _078 | _079 | 5 | 19981 | |
| 1-14 | Remote Control Operation (Operation Mode) | 20991502 | RemoteControlAirConModeSet | _078 | _079 | 5 | 19982 | |
| 1-14 | Remote Control Operation (Set Temperature) | 20991504 | RemoteControlTempAdjust | _078 | _079 | 5 | 19984 | |
| 1-14 | Remote Control Operation (Sub Group Address Control Reject) | 20991505 | CL_Rejection | _078 | _079 | 5 | 19985 | |
| 1-14 | Elec Total Power | 96488979 | ElecTotalPower | _078 | _079 | 23 | 19987 | |
| 1-14 | Communication Status | 12602900 | CommunicationStatus | _078 | _079 | 3 | 19988 | |
| 1-14 | System Forced OFF | 20991509 | SystemForcedOff | _078 | _079 | 5 | 19989 | |
| 1-14 | Air Direction (setting) | 8408598 | AirDirectionCommand | _078 | _079 | 2 | 19990 | |
| 1-14 | Air Direction (status) | 19991 | AirDirectionStatus | _078 | _079 | 0 | 19991 | |
| 1-14 | Forced Thermostat OFF (setting) | 16797208 | ForcedThermoOFFCommand | _078 | _079 | 4 | 19992 | |
| 1-14 | Forced Thermostat OFF (status) | 12602905 | ForcedThermoOFFStatus | _078 | _079 | 3 | 19993 | |
| 1-14 | Energy Efficiency Command (setting) | 16797210 | EnergyEfficiencyCommand | _078 | _079 | 4 | 19994 | |
| 1-14 | Energy Efficiency Command (status) | 12602907 | EnergyEfficiencyStatus | _078 | _079 | 3 | 19995 | |
| 1-14 | Thermostat Status | 12602908 | ThermoStatus | _078 | _079 | 3 | 19996 | |
| 1-14 | Compressor Status | 12602909 | CompressorStatus | _078 | _079 | 3 | 19997 | |
| 1-14 | Indoor Fan Status | 12602910 | IndoorFanStatus | _078 | _079 | 3 | 19998 | |
| 1-14 | Heater Operation Status | 12602911 | HeaterStatus | _078 | _079 | 3 | 19999 | |
| 1-14 | Ventilation Mode (setting) | 58740256 | VentilationModeCommand | _078 | _079 | 14 | 20000 | |
| 1-14 | Ventilation Mode (status) | 54545953 | VentilationModeStatus | _078 | _079 | 13 | 20001 | |
| 1-14 | Ventilation Amount (setting) | 58740258 | VentilationAmountCommand | _078 | _079 | 14 | 20002 | |
| 1-14 | Ventilation Amount (status) | 54545955 | VentilationAmountStatus | _078 | _079 | 13 | 20003 | |
| 1-15 | ON/OFF (setting) | 16797441 | StartStopCommand | _079 | _080 | 4 | 20225 | set |
| 1-15 | ON/OFF (status) | 12603138 | StartStopStatus | _079 | _080 | 3 | 20226 | Fb |
| 1-15 | Alarm Sign | 12603139 | Alarm | _079 | _080 | 3 | 20227 | |
| 1-15 | Error Code | 54546180 | MalfunctionCode | _079 | _080 | 13 | 20228 | |
| 1-15 | Operation Mode (setting) | 58740485 | AirConModeCommand | _079 | _080 | 14 | 20229 | set |
| 1-15 | Operation Mode (status) | 54546182 | AirConModeStatus | _079 | _080 | 13 | 20230 | Fb |
| 1-15 | Airflow Rate (setting) | 58740487 | AirFlowRateCommand | _079 | _080 | 14 | 20231 | set |
| 1-15 | Airflow Rate (status) | 54546184 | AirFlowRateStatus | _079 | _080 | 13 | 20232 | Fb |
| 1-15 | Measured Room Temperature | 20233 | RoomTemp | _079 | _080 | 0 | 20233 | |
| 1-15 | Set Room Temperature | 8408842 | TempAdjust | _079 | _080 | 2 | 20234 | set |
| 1-15 | Filer Limit Sign | 12603147 | FilterSign | _079 | _080 | 3 | 20235 | |
| 1-15 | Filter Limit Sign Reset | 20991756 | FilterSignReset | _079 | _080 | 5 | 20236 | |
| 1-15 | Remote Control Operation (ON/OFF) | 20991757 | RemoteControlStart | _079 | _080 | 5 | 20237 | |
| 1-15 | Remote Control Operation (Operation Mode) | 20991758 | RemoteControlAirConModeSet | _079 | _080 | 5 | 20238 | |
| 1-15 | Remote Control Operation (Set Temperature) | 20991760 | RemoteControlTempAdjust | _079 | _080 | 5 | 20240 | |
| 1-15 | Remote Control Operation (Sub Group Address Control Reject) | 20991761 | CL_Rejection | _079 | _080 | 5 | 20241 | |
| 1-15 | Elec Total Power | 96489235 | ElecTotalPower | _079 | _080 | 23 | 20243 | |
| 1-15 | Communication Status | 12603156 | CommunicationStatus | _079 | _080 | 3 | 20244 | |
| 1-15 | System Forced OFF | 20991765 | SystemForcedOff | _079 | _080 | 5 | 20245 | |
| 1-15 | Air Direction (setting) | 8408854 | AirDirectionCommand | _079 | _080 | 2 | 20246 | |
| 1-15 | Air Direction (status) | 20247 | AirDirectionStatus | _079 | _080 | 0 | 20247 | |
| 1-15 | Forced Thermostat OFF (setting) | 16797464 | ForcedThermoOFFCommand | _079 | _080 | 4 | 20248 | |
| 1-15 | Forced Thermostat OFF (status) | 12603161 | ForcedThermoOFFStatus | _079 | _080 | 3 | 20249 | |
| 1-15 | Energy Efficiency Command (setting) | 16797466 | EnergyEfficiencyCommand | _079 | _080 | 4 | 20250 | |
| 1-15 | Energy Efficiency Command (status) | 12603163 | EnergyEfficiencyStatus | _079 | _080 | 3 | 20251 | |
| 1-15 | Thermostat Status | 12603164 | ThermoStatus | _079 | _080 | 3 | 20252 | |
| 1-15 | Compressor Status | 12603165 | CompressorStatus | _079 | _080 | 3 | 20253 | |
| 1-15 | Indoor Fan Status | 12603166 | IndoorFanStatus | _079 | _080 | 3 | 20254 | |
| 1-15 | Heater Operation Status | 12603167 | HeaterStatus | _079 | _080 | 3 | 20255 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 1-15 | Ventilation Mode (setting) | 58740512 | VentilationModeCommand | _079 | _080 | 14 | 20256 | |
| 1-15 | Ventilation Mode (status) | 54546209 | VentilationModeStatus | _079 | _080 | 13 | 20257 | |
| 1-15 | Ventilation Amount (setting) | 58740514 | VentilationAmountCommand | _079 | _080 | 14 | 20258 | |
| 1-15 | Ventilation Amount (status) | 54546211 | VentilationAmountStatus | _079 | _080 | 13 | 20259 | |
| 2-00 | ON/OFF (setting) | 16797697 | StartStopCommand | _080 | _081 | 4 | 20481 | set |
| 2-00 | ON/OFF (status) | 12603394 | StartStopStatus | _080 | _081 | 3 | 20482 | Fb |
| 2-00 | Alarm Sign | 12603395 | Alarm | _080 | _081 | 3 | 20483 | |
| 2-00 | Error Code | 54546436 | MalfunctionCode | _080 | _081 | 13 | 20484 | |
| 2-00 | Operation Mode (setting) | 58740741 | AirConModeCommand | _080 | _081 | 14 | 20485 | set |
| 2-00 | Operation Mode (status) | 54546438 | AirConModeStatus | _080 | _081 | 13 | 20486 | Fb |
| 2-00 | Airflow Rate (setting) | 58740743 | AirFlowRateCommand | _080 | _081 | 14 | 20487 | set |
| 2-00 | Airflow Rate (status) | 54546440 | AirFlowRateStatus | _080 | _081 | 13 | 20488 | Fb |
| 2-00 | Measured Room Temperature | 20489 | RoomTemp | _080 | _081 | 0 | 20489 | |
| 2-00 | Set Room Temperature | 8409098 | TempAdjust | _080 | _081 | 2 | 20490 | set |
| 2-00 | Filer Limit Sign | 12603403 | FilterSign | _080 | _081 | 3 | 20491 | |
| 2-00 | Filter Limit Sign Reset | 20992012 | FilterSignReset | _080 | _081 | 5 | 20492 | |
| 2-00 | Remote Control Operation (ON/OFF) | 20992013 | RemoteControlStart | _080 | _081 | 5 | 20493 | |
| 2-00 | Remote Control Operation (Operation Mode) | 20992014 | RemoteControlAirConModeSet | _080 | _081 | 5 | 20494 | |
| 2-00 | Remote Control Operation (Set Temperature) | 20992016 | RemoteControlTempAdjust | _080 | _081 | 5 | 20496 | |
| 2-00 | Remote Control Operation (Sub Group Address Control Reject) | 20992017 | CL_Rejection | _080 | _081 | 5 | 20497 | |
| 2-00 | Elec Total Power | 96489491 | ElecTotalPower | _080 | _081 | 23 | 20499 | |
| 2-00 | Communication Status | 12603412 | CommunicationStatus | _080 | _081 | 3 | 20500 | |
| 2-00 | System Forced OFF | 20992021 | SystemForcedOff | _080 | _081 | 5 | 20501 | |
| 2-00 | Air Direction (setting) | 8409110 | AirDirectionCommand | _080 | _081 | 2 | 20502 | |
| 2-00 | Air Direction (status) | 20503 | AirDirectionStatus | _080 | _081 | 0 | 20503 | |
| 2-00 | Forced Thermostat OFF (setting) | 16797720 | ForcedThermoOFFCommand | _080 | _081 | 4 | 20504 | |
| 2-00 | Forced Thermostat OFF (status) | 12603417 | ForcedThermoOFFStatus | _080 | _081 | 3 | 20505 | |
| 2-00 | Energy Efficiency Command (setting) | 16797722 | EnergyEfficiencyCommand | _080 | _081 | 4 | 20506 | |
| 2-00 | Energy Efficiency Command (status) | 12603419 | EnergyEfficiencyStatus | _080 | _081 | 3 | 20507 | |
| 2-00 | Thermostat Status | 12603420 | ThermoStatus | _080 | _081 | 3 | 20508 | |
| 2-00 | Compressor Status | 12603421 | CompressorStatus | _080 | _081 | 3 | 20509 | |
| 2-00 | Indoor Fan Status | 12603422 | IndoorFanStatus | _080 | _081 | 3 | 20510 | |
| 2-00 | Heater Operation Status | 12603423 | HeaterStatus | _080 | _081 | 3 | 20511 | |
| 2-00 | Ventilation Mode (setting) | 58740768 | VentilationModeCommand | _080 | _081 | 14 | 20512 | |
| 2-00 | Ventilation Mode (status) | 54546465 | VentilationModeStatus | _080 | _081 | 13 | 20513 | |
| 2-00 | Ventilation Amount (setting) | 58740770 | VentilationAmountCommand | _080 | _081 | 14 | 20514 | |
| 2-00 | Ventilation Amount (status) | 54546467 | VentilationAmountStatus | _080 | _081 | 13 | 20515 | |
| 2-01 | ON/OFF (setting) | 16797953 | StartStopCommand | _081 | _082 | 4 | 20737 | set |
| 2-01 | ON/OFF (status) | 12603650 | StartStopStatus | _081 | _082 | 3 | 20738 | Fb |
| 2-01 | Alarm Sign | 12603651 | Alarm | _081 | _082 | 3 | 20739 | |
| 2-01 | Error Code | 54546692 | MalfunctionCode | _081 | _082 | 13 | 20740 | |
| 2-01 | Operation Mode (setting) | 58740997 | AirConModeCommand | _081 | _082 | 14 | 20741 | set |
| 2-01 | Operation Mode (status) | 54546694 | AirConModeStatus | _081 | _082 | 13 | 20742 | Fb |
| 2-01 | Airflow Rate (setting) | 58740999 | AirFlowRateCommand | _081 | _082 | 14 | 20743 | set |
| 2-01 | Airflow Rate (status) | 54546696 | AirFlowRateStatus | _081 | _082 | 13 | 20744 | Fb |
| 2-01 | Measured Room Temperature | 20745 | RoomTemp | _081 | _082 | 0 | 20745 | |
| 2-01 | Set Room Temperature | 8409354 | TempAdjust | _081 | _082 | 2 | 20746 | set |
| 2-01 | Filer Limit Sign | 12603659 | FilterSign | _081 | _082 | 3 | 20747 | |
| 2-01 | Filter Limit Sign Reset | 20992268 | FilterSignReset | _081 | _082 | 5 | 20748 | |
| 2-01 | Remote Control Operation (ON/OFF) | 20992269 | RemoteControlStart | _081 | _082 | 5 | 20749 | |
| 2-01 | Remote Control Operation (Operation Mode) | 20992270 | RemoteControlAirConModeSet | _081 | _082 | 5 | 20750 | |
| 2-01 | Remote Control Operation (Set Temperature) | 20992272 | RemoteControlTempAdjust | _081 | _082 | 5 | 20752 | |
| 2-01 | Remote Control Operation (Sub Group Address Control Reject) | 20992273 | CL_Rejection | _081 | _082 | 5 | 20753 | |
| 2-01 | Elec Total Power | 96489747 | ElecTotalPower | _081 | _082 | 23 | 20755 | |
| 2-01 | Communication Status | 12603668 | CommunicationStatus | _081 | _082 | 3 | 20756 | |
| 2-01 | System Forced OFF | 20992277 | SystemForcedOff | _081 | _082 | 5 | 20757 | |
| 2-01 | Air Direction (setting) | 8409366 | AirDirectionCommand | _081 | _082 | 2 | 20758 | |
| 2-01 | Air Direction (status) | 20759 | AirDirectionStatus | _081 | _082 | 0 | 20759 | |
| 2-01 | Forced Thermostat OFF (setting) | 16797976 | ForcedThermoOFFCommand | _081 | _082 | 4 | 20760 | |
| 2-01 | Forced Thermostat OFF (status) | 12603673 | ForcedThermoOFFStatus | _081 | _082 | 3 | 20761 | |
| 2-01 | Energy Efficiency Command (setting) | 16797978 | EnergyEfficiencyCommand | _081 | _082 | 4 | 20762 | |
| 2-01 | Energy Efficiency Command (status) | 12603675 | EnergyEfficiencyStatus | _081 | _082 | 3 | 20763 | |
| 2-01 | Thermostat Status | 12603676 | ThermoStatus | _081 | _082 | 3 | 20764 | |
| 2-01 | Compressor Status | 12603677 | CompressorStatus | _081 | _082 | 3 | 20765 | |
| 2-01 | Indoor Fan Status | 12603678 | IndoorFanStatus | _081 | _082 | 3 | 20766 | |
| 2-01 | Heater Operation Status | 12603679 | HeaterStatus | _081 | _082 | 3 | 20767 | |
| 2-01 | Ventilation Mode (setting) | 58741024 | VentilationModeCommand | _081 | _082 | 14 | 20768 | |
| 2-01 | Ventilation Mode (status) | 54546721 | VentilationModeStatus | _081 | _082 | 13 | 20769 | |
| 2-01 | Ventilation Amount (setting) | 58741026 | VentilationAmountCommand | _081 | _082 | 14 | 20770 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 2-01 | Ventilation Amount (status) | 54546723 | VentilationAmountStatus | _081 | _082 | 13 | 20771 | |
| 2-02 | ON/OFF (setting) | 16798209 | StartStopCommand | _082 | _083 | 4 | 20993 | set |
| 2-02 | ON/OFF (status) | 12603906 | StartStopStatus | _082 | _083 | 3 | 20994 | Fb |
| 2-02 | Alarm Sign | 12603907 | Alarm | _082 | _083 | 3 | 20995 | |
| 2-02 | Error Code | 54546948 | MalfunctionCode | _082 | _083 | 13 | 20996 | |
| 2-02 | Operation Mode (setting) | 58741253 | AirConModeCommand | _082 | _083 | 14 | 20997 | set |
| 2-02 | Operation Mode (status) | 54546950 | AirConModeStatus | _082 | _083 | 13 | 20998 | Fb |
| 2-02 | Airflow Rate (setting) | 58741255 | AirFlowRateCommand | _082 | _083 | 14 | 20999 | set |
| 2-02 | Airflow Rate (status) | 54546952 | AirFlowRateStatus | _082 | _083 | 13 | 21000 | Fb |
| 2-02 | Measured Room Temperature | 21001 | RoomTemp | _082 | _083 | 0 | 21001 | |
| 2-02 | Set Room Temperature | 8409610 | TempAdjust | _082 | _083 | 2 | 21002 | set |
| 2-02 | Filer Limit Sign | 12603915 | FilterSign | _082 | _083 | 3 | 21003 | |
| 2-02 | Filter Limit Sign Reset | 20992524 | FilterSignReset | _082 | _083 | 5 | 21004 | |
| 2-02 | Remote Control Operation (ON/OFF) | 20992525 | RemoteControlStart | _082 | _083 | 5 | 21005 | |
| 2-02 | Remote Control Operation (Operation Mode) | 20992526 | RemoteControlAirConModeSet | _082 | _083 | 5 | 21006 | |
| 2-02 | Remote Control Operation (Set Temperature) | 20992528 | RemoteControlTempAdjust | _082 | _083 | 5 | 21008 | |
| 2-02 | Remote Control Operation (Sub Group Address Control Reject) | 20992529 | CL_Rejection | _082 | _083 | 5 | 21009 | |
| 2-02 | Elec Total Power | 96490003 | ElecTotalPower | _082 | _083 | 23 | 21011 | |
| 2-02 | Communication Status | 12603924 | CommunicationStatus | _082 | _083 | 3 | 21012 | |
| 2-02 | System Forced OFF | 20992533 | SystemForcedOff | _082 | _083 | 5 | 21013 | |
| 2-02 | Air Direction (setting) | 8409622 | AirDirectionCommand | _082 | _083 | 2 | 21014 | |
| 2-02 | Air Direction (status) | 21015 | AirDirectionStatus | _082 | _083 | 0 | 21015 | |
| 2-02 | Forced Thermostat OFF (setting) | 16798232 | ForcedThermoOFFCommand | _082 | _083 | 4 | 21016 | |
| 2-02 | Forced Thermostat OFF (status) | 12603929 | ForcedThermoOFFStatus | _082 | _083 | 3 | 21017 | |
| 2-02 | Energy Efficiency Command (setting) | 16798234 | EnergyEfficiencyCommand | _082 | _083 | 4 | 21018 | |
| 2-02 | Energy Efficiency Command (status) | 12603931 | EnergyEfficiencyStatus | _082 | _083 | 3 | 21019 | |
| 2-02 | Thermostat Status | 12603932 | ThermoStatus | _082 | _083 | 3 | 21020 | |
| 2-02 | Compressor Status | 12603933 | CompressorStatus | _082 | _083 | 3 | 21021 | |
| 2-02 | Indoor Fan Status | 12603934 | IndoorFanStatus | _082 | _083 | 3 | 21022 | |
| 2-02 | Heater Operation Status | 12603935 | HeaterStatus | _082 | _083 | 3 | 21023 | |
| 2-02 | Ventilation Mode (setting) | 58741280 | VentilationModeCommand | _082 | _083 | 14 | 21024 | |
| 2-02 | Ventilation Mode (status) | 54546977 | VentilationModeStatus | _082 | _083 | 13 | 21025 | |
| 2-02 | Ventilation Amount (setting) | 58741282 | VentilationAmountCommand | _082 | _083 | 14 | 21026 | |
| 2-02 | Ventilation Amount (status) | 54546979 | VentilationAmountStatus | _082 | _083 | 13 | 21027 | |
| 2-03 | ON/OFF (setting) | 16798465 | StartStopCommand | _083 | _084 | 4 | 21249 | set |
| 2-03 | ON/OFF (status) | 12604162 | StartStopStatus | _083 | _084 | 3 | 21250 | Fb |
| 2-03 | Alarm Sign | 12604163 | Alarm | _083 | _084 | 3 | 21251 | |
| 2-03 | Error Code | 54547204 | MalfunctionCode | _083 | _084 | 13 | 21252 | |
| 2-03 | Operation Mode (setting) | 58741509 | AirConModeCommand | _083 | _084 | 14 | 21253 | set |
| 2-03 | Operation Mode (status) | 54547206 | AirConModeStatus | _083 | _084 | 13 | 21254 | Fb |
| 2-03 | Airflow Rate (setting) | 58741511 | AirFlowRateCommand | _083 | _084 | 14 | 21255 | set |
| 2-03 | Airflow Rate (status) | 54547208 | AirFlowRateStatus | _083 | _084 | 13 | 21256 | Fb |
| 2-03 | Measured Room Temperature | 21257 | RoomTemp | _083 | _084 | 0 | 21257 | |
| 2-03 | Set Room Temperature | 8409866 | TempAdjust | _083 | _084 | 2 | 21258 | set |
| 2-03 | Filer Limit Sign | 12604171 | FilterSign | _083 | _084 | 3 | 21259 | |
| 2-03 | Filter Limit Sign Reset | 20992780 | FilterSignReset | _083 | _084 | 5 | 21260 | |
| 2-03 | Remote Control Operation (ON/OFF) | 20992781 | RemoteControlStart | _083 | _084 | 5 | 21261 | |
| 2-03 | Remote Control Operation (Operation Mode) | 20992782 | RemoteControlAirConModeSet | _083 | _084 | 5 | 21262 | |
| 2-03 | Remote Control Operation (Set Temperature) | 20992784 | RemoteControlTempAdjust | _083 | _084 | 5 | 21264 | |
| 2-03 | Remote Control Operation (Sub Group Address Control Reject) | 20992785 | CL_Rejection | _083 | _084 | 5 | 21265 | |
| 2-03 | Elec Total Power | 96490259 | ElecTotalPower | _083 | _084 | 23 | 21267 | |
| 2-03 | Communication Status | 12604180 | CommunicationStatus | _083 | _084 | 3 | 21268 | |
| 2-03 | System Forced OFF | 20992789 | SystemForcedOff | _083 | _084 | 5 | 21269 | |
| 2-03 | Air Direction (setting) | 8409878 | AirDirectionCommand | _083 | _084 | 2 | 21270 | |
| 2-03 | Air Direction (status) | 21271 | AirDirectionStatus | _083 | _084 | 0 | 21271 | |
| 2-03 | Forced Thermostat OFF (setting) | 16798488 | ForcedThermoOFFCommand | _083 | _084 | 4 | 21272 | |
| 2-03 | Forced Thermostat OFF (status) | 12604185 | ForcedThermoOFFStatus | _083 | _084 | 3 | 21273 | |
| 2-03 | Energy Efficiency Command (setting) | 16798490 | EnergyEfficiencyCommand | _083 | _084 | 4 | 21274 | |
| 2-03 | Energy Efficiency Command (status) | 12604187 | EnergyEfficiencyStatus | _083 | _084 | 3 | 21275 | |
| 2-03 | Thermostat Status | 12604188 | ThermoStatus | _083 | _084 | 3 | 21276 | |
| 2-03 | Compressor Status | 12604189 | CompressorStatus | _083 | _084 | 3 | 21277 | |
| 2-03 | Indoor Fan Status | 12604190 | IndoorFanStatus | _083 | _084 | 3 | 21278 | |
| 2-03 | Heater Operation Status | 12604191 | HeaterStatus | _083 | _084 | 3 | 21279 | |
| 2-03 | Ventilation Mode (setting) | 58741536 | VentilationModeCommand | _083 | _084 | 14 | 21280 | |
| 2-03 | Ventilation Mode (status) | 54547233 | VentilationModeStatus | _083 | _084 | 13 | 21281 | |
| 2-03 | Ventilation Amount (setting) | 58741538 | VentilationAmountCommand | _083 | _084 | 14 | 21282 | |
| 2-03 | Ventilation Amount (status) | 54547235 | VentilationAmountStatus | _083 | _084 | 13 | 21283 | |
| 2-04 | ON/OFF (setting) | 16798721 | StartStopCommand | _084 | _085 | 4 | 21505 | set |
| 2-04 | ON/OFF (status) | 12604418 | StartStopStatus | _084 | _085 | 3 | 21506 | Fb |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 2-04 | Alarm Sign | 12604419 | Alarm | _084 | _085 | 3 | 21507 | |
| 2-04 | Error Code | 54547460 | MalfunctionCode | _084 | _085 | 13 | 21508 | |
| 2-04 | Operation Mode (setting) | 58741765 | AirConModeCommand | _084 | _085 | 14 | 21509 | set |
| 2-04 | Operation Mode (status) | 54547462 | AirConModeStatus | _084 | _085 | 13 | 21510 | Fb |
| 2-04 | Airflow Rate (setting) | 58741767 | AirFlowRateCommand | _084 | _085 | 14 | 21511 | set |
| 2-04 | Airflow Rate (status) | 54547464 | AirFlowRateStatus | _084 | _085 | 13 | 21512 | Fb |
| 2-04 | Measured Room Temperature | 21513 | RoomTemp | _084 | _085 | 0 | 21513 | |
| 2-04 | Set Room Temperature | 8410122 | TempAdjust | _084 | _085 | 2 | 21514 | set |
| 2-04 | Filer Limit Sign | 12604427 | FilterSign | _084 | _085 | 3 | 21515 | |
| 2-04 | Filter Limit Sign Reset | 20993036 | FilterSignReset | _084 | _085 | 5 | 21516 | |
| 2-04 | Remote Control Operation (ON/OFF) | 20993037 | RemoteControlStart | _084 | _085 | 5 | 21517 | |
| 2-04 | Remote Control Operation (Operation Mode) | 20993038 | RemoteControlAirConModeSet | _084 | _085 | 5 | 21518 | |
| 2-04 | Remote Control Operation (Set Temperature) | 20993040 | RemoteControlTempAdjust | _084 | _085 | 5 | 21520 | |
| 2-04 | Remote Control Operation (Sub Group Address Control Reject) | 20993041 | CL_Rejection | _084 | _085 | 5 | 21521 | |
| 2-04 | Elec Total Power | 96490515 | ElecTotalPower | _084 | _085 | 23 | 21523 | |
| 2-04 | Communication Status | 12604436 | CommunicationStatus | _084 | _085 | 3 | 21524 | |
| 2-04 | System Forced OFF | 20993045 | SystemForcedOff | _084 | _085 | 5 | 21525 | |
| 2-04 | Air Direction (setting) | 8410134 | AirDirectionCommand | _084 | _085 | 2 | 21526 | |
| 2-04 | Air Direction (status) | 21527 | AirDirectionStatus | _084 | _085 | 0 | 21527 | |
| 2-04 | Forced Thermostat OFF (setting) | 16798744 | ForcedThermoOFFCommand | _084 | _085 | 4 | 21528 | |
| 2-04 | Forced Thermostat OFF (status) | 12604441 | ForcedThermoOFFStatus | _084 | _085 | 3 | 21529 | |
| 2-04 | Energy Efficiency Command (setting) | 16798746 | EnergyEfficiencyCommand | _084 | _085 | 4 | 21530 | |
| 2-04 | Energy Efficiency Command (status) | 12604443 | EnergyEfficiencyStatus | _084 | _085 | 3 | 21531 | |
| 2-04 | Thermostat Status | 12604444 | ThermoStatus | _084 | _085 | 3 | 21532 | |
| 2-04 | Compressor Status | 12604445 | CompressorStatus | _084 | _085 | 3 | 21533 | |
| 2-04 | Indoor Fan Status | 12604446 | IndoorFanStatus | _084 | _085 | 3 | 21534 | |
| 2-04 | Heater Operation Status | 12604447 | HeaterStatus | _084 | _085 | 3 | 21535 | |
| 2-04 | Ventilation Mode (setting) | 58741792 | VentilationModeCommand | _084 | _085 | 14 | 21536 | |
| 2-04 | Ventilation Mode (status) | 54547489 | VentilationModeStatus | _084 | _085 | 13 | 21537 | |
| 2-04 | Ventilation Amount (setting) | 58741794 | VentilationAmountCommand | _084 | _085 | 14 | 21538 | |
| 2-04 | Ventilation Amount (status) | 54547491 | VentilationAmountStatus | _084 | _085 | 13 | 21539 | |
| 2-05 | ON/OFF (setting) | 16798977 | StartStopCommand | _085 | _086 | 4 | 21761 | set |
| 2-05 | ON/OFF (status) | 12604674 | StartStopStatus | _085 | _086 | 3 | 21762 | Fb |
| 2-05 | Alarm Sign | 12604675 | Alarm | _085 | _086 | 3 | 21763 | |
| 2-05 | Error Code | 54547716 | MalfunctionCode | _085 | _086 | 13 | 21764 | |
| 2-05 | Operation Mode (setting) | 58742021 | AirConModeCommand | _085 | _086 | 14 | 21765 | set |
| 2-05 | Operation Mode (status) | 54547718 | AirConModeStatus | _085 | _086 | 13 | 21766 | Fb |
| 2-05 | Airflow Rate (setting) | 58742023 | AirFlowRateCommand | _085 | _086 | 14 | 21767 | set |
| 2-05 | Airflow Rate (status) | 54547720 | AirFlowRateStatus | _085 | _086 | 13 | 21768 | Fb |
| 2-05 | Measured Room Temperature | 21769 | RoomTemp | _085 | _086 | 0 | 21769 | |
| 2-05 | Set Room Temperature | 8410378 | TempAdjust | _085 | _086 | 2 | 21770 | set |
| 2-05 | Filer Limit Sign | 12604683 | FilterSign | _085 | _086 | 3 | 21771 | |
| 2-05 | Filter Limit Sign Reset | 20993292 | FilterSignReset | _085 | _086 | 5 | 21772 | |
| 2-05 | Remote Control Operation (ON/OFF) | 20993293 | RemoteControlStart | _085 | _086 | 5 | 21773 | |
| 2-05 | Remote Control Operation (Operation Mode) | 20993294 | RemoteControlAirConModeSet | _085 | _086 | 5 | 21774 | |
| 2-05 | Remote Control Operation (Set Temperature) | 20993296 | RemoteControlTempAdjust | _085 | _086 | 5 | 21776 | |
| 2-05 | Remote Control Operation (Sub Group Address Control Reject) | 20993297 | CL_Rejection | _085 | _086 | 5 | 21777 | |
| 2-05 | Elec Total Power | 96490771 | ElecTotalPower | _085 | _086 | 23 | 21779 | |
| 2-05 | Communication Status | 12604692 | CommunicationStatus | _085 | _086 | 3 | 21780 | |
| 2-05 | System Forced OFF | 20993301 | SystemForcedOff | _085 | _086 | 5 | 21781 | |
| 2-05 | Air Direction (setting) | 8410390 | AirDirectionCommand | _085 | _086 | 2 | 21782 | |
| 2-05 | Air Direction (status) | 21783 | AirDirectionStatus | _085 | _086 | 0 | 21783 | |
| 2-05 | Forced Thermostat OFF (setting) | 16799000 | ForcedThermoOFFCommand | _085 | _086 | 4 | 21784 | |
| 2-05 | Forced Thermostat OFF (status) | 12604697 | ForcedThermoOFFStatus | _085 | _086 | 3 | 21785 | |
| 2-05 | Energy Efficiency Command (setting) | 16799002 | EnergyEfficiencyCommand | _085 | _086 | 4 | 21786 | |
| 2-05 | Energy Efficiency Command (status) | 12604699 | EnergyEfficiencyStatus | _085 | _086 | 3 | 21787 | |
| 2-05 | Thermostat Status | 12604700 | ThermoStatus | _085 | _086 | 3 | 21788 | |
| 2-05 | Compressor Status | 12604701 | CompressorStatus | _085 | _086 | 3 | 21789 | |
| 2-05 | Indoor Fan Status | 12604702 | IndoorFanStatus | _085 | _086 | 3 | 21790 | |
| 2-05 | Heater Operation Status | 12604703 | HeaterStatus | _085 | _086 | 3 | 21791 | |
| 2-05 | Ventilation Mode (setting) | 58742048 | VentilationModeCommand | _085 | _086 | 14 | 21792 | |
| 2-05 | Ventilation Mode (status) | 54547745 | VentilationModeStatus | _085 | _086 | 13 | 21793 | |
| 2-05 | Ventilation Amount (setting) | 58742050 | VentilationAmountCommand | _085 | _086 | 14 | 21794 | |
| 2-05 | Ventilation Amount (status) | 54547747 | VentilationAmountStatus | _085 | _086 | 13 | 21795 | |
| 2-06 | ON/OFF (setting) | 16799233 | StartStopCommand | _086 | _087 | 4 | 22017 | set |
| 2-06 | ON/OFF (status) | 12604930 | StartStopStatus | _086 | _087 | 3 | 22018 | Fb |
| 2-06 | Alarm Sign | 12604931 | Alarm | _086 | _087 | 3 | 22019 | |
| 2-06 | Error Code | 54547972 | MalfunctionCode | _086 | _087 | 13 | 22020 | |
| 2-06 | Operation Mode (setting) | 58742277 | AirConModeCommand | _086 | _087 | 14 | 22021 | set |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 2-06 | Operation Mode (status) | 54547974 | AirConModeStatus | _086 | _087 | 13 | 22022 | Fb |
| 2-06 | Airflow Rate (setting) | 58742279 | AirFlowRateCommand | _086 | _087 | 14 | 22023 | set |
| 2-06 | Airflow Rate (status) | 54547976 | AirFlowRateStatus | _086 | _087 | 13 | 22024 | Fb |
| 2-06 | Measured Room Temperature | 22025 | RoomTemp | _086 | _087 | 0 | 22025 | |
| 2-06 | Set Room Temperature | 8410634 | TempAdjust | _086 | _087 | 2 | 22026 | set |
| 2-06 | Filer Limit Sign | 12604939 | FilterSign | _086 | _087 | 3 | 22027 | |
| 2-06 | Filter Limit Sign Reset | 20993548 | FilterSignReset | _086 | _087 | 5 | 22028 | |
| 2-06 | Remote Control Operation (ON/OFF) | 20993549 | RemoteControlStart | _086 | _087 | 5 | 22029 | |
| 2-06 | Remote Control Operation (Operation Mode) | 20993550 | RemoteControlAirConModeSet | _086 | _087 | 5 | 22030 | |
| 2-06 | Remote Control Operation (Set Temperature) | 20993552 | RemoteControlTempAdjust | _086 | _087 | 5 | 22032 | |
| 2-06 | Remote Control Operation (Sub Group Address Control Reject) | 20993553 | CL_Rejection | _086 | _087 | 5 | 22033 | |
| 2-06 | Elec Total Power | 96491027 | ElecTotalPower | _086 | _087 | 23 | 22035 | |
| 2-06 | Communication Status | 12604948 | CommunicationStatus | _086 | _087 | 3 | 22036 | |
| 2-06 | System Forced OFF | 20993557 | SystemForcedOff | _086 | _087 | 5 | 22037 | |
| 2-06 | Air Direction (setting) | 8410646 | AirDirectionCommand | _086 | _087 | 2 | 22038 | |
| 2-06 | Air Direction (status) | 22039 | AirDirectionStatus | _086 | _087 | 0 | 22039 | |
| 2-06 | Forced Thermostat OFF (setting) | 16799256 | ForcedThermoOFFCommand | _086 | _087 | 4 | 22040 | |
| 2-06 | Forced Thermostat OFF (status) | 12604953 | ForcedThermoOFFStatus | _086 | _087 | 3 | 22041 | |
| 2-06 | Energy Efficiency Command (setting) | 16799258 | EnergyEfficiencyCommand | _086 | _087 | 4 | 22042 | |
| 2-06 | Energy Efficiency Command (status) | 12604955 | EnergyEfficiencyStatus | _086 | _087 | 3 | 22043 | |
| 2-06 | Thermostat Status | 12604956 | ThermoStatus | _086 | _087 | 3 | 22044 | |
| 2-06 | Compressor Status | 12604957 | CompressorStatus | _086 | _087 | 3 | 22045 | |
| 2-06 | Indoor Fan Status | 12604958 | IndoorFanStatus | _086 | _087 | 3 | 22046 | |
| 2-06 | Heater Operation Status | 12604959 | HeaterStatus | _086 | _087 | 3 | 22047 | |
| 2-06 | Ventilation Mode (setting) | 58742304 | VentilationModeCommand | _086 | _087 | 14 | 22048 | |
| 2-06 | Ventilation Mode (status) | 54548001 | VentilationModeStatus | _086 | _087 | 13 | 22049 | |
| 2-06 | Ventilation Amount (setting) | 58742306 | VentilationAmountCommand | _086 | _087 | 14 | 22050 | |
| 2-06 | Ventilation Amount (status) | 54548003 | VentilationAmountStatus | _086 | _087 | 13 | 22051 | |
| 2-07 | ON/OFF (setting) | 16799489 | StartStopCommand | _087 | _088 | 4 | 22273 | set |
| 2-07 | ON/OFF (status) | 12605186 | StartStopStatus | _087 | _088 | 3 | 22274 | Fb |
| 2-07 | Alarm Sign | 12605187 | Alarm | _087 | _088 | 3 | 22275 | |
| 2-07 | Error Code | 54548228 | MalfunctionCode | _087 | _088 | 13 | 22276 | |
| 2-07 | Operation Mode (setting) | 58742533 | AirConModeCommand | _087 | _088 | 14 | 22277 | set |
| 2-07 | Operation Mode (status) | 54548230 | AirConModeStatus | _087 | _088 | 13 | 22278 | Fb |
| 2-07 | Airflow Rate (setting) | 58742535 | AirFlowRateCommand | _087 | _088 | 14 | 22279 | set |
| 2-07 | Airflow Rate (status) | 54548232 | AirFlowRateStatus | _087 | _088 | 13 | 22280 | Fb |
| 2-07 | Measured Room Temperature | 22281 | RoomTemp | _087 | _088 | 0 | 22281 | |
| 2-07 | Set Room Temperature | 8410890 | TempAdjust | _087 | _088 | 2 | 22282 | set |
| 2-07 | Filer Limit Sign | 12605195 | FilterSign | _087 | _088 | 3 | 22283 | |
| 2-07 | Filter Limit Sign Reset | 20993804 | FilterSignReset | _087 | _088 | 5 | 22284 | |
| 2-07 | Remote Control Operation (ON/OFF) | 20993805 | RemoteControlStart | _087 | _088 | 5 | 22285 | |
| 2-07 | Remote Control Operation (Operation Mode) | 20993806 | RemoteControlAirConModeSet | _087 | _088 | 5 | 22286 | |
| 2-07 | Remote Control Operation (Set Temperature) | 20993808 | RemoteControlTempAdjust | _087 | _088 | 5 | 22288 | |
| 2-07 | Remote Control Operation (Sub Group Address Control Reject) | 20993809 | CL_Rejection | _087 | _088 | 5 | 22289 | |
| 2-07 | Elec Total Power | 96491283 | ElecTotalPower | _087 | _088 | 23 | 22291 | |
| 2-07 | Communication Status | 12605204 | CommunicationStatus | _087 | _088 | 3 | 22292 | |
| 2-07 | System Forced OFF | 20993813 | SystemForcedOff | _087 | _088 | 5 | 22293 | |
| 2-07 | Air Direction (setting) | 8410902 | AirDirectionCommand | _087 | _088 | 2 | 22294 | |
| 2-07 | Air Direction (status) | 22295 | AirDirectionStatus | _087 | _088 | 0 | 22295 | |
| 2-07 | Forced Thermostat OFF (setting) | 16799512 | ForcedThermoOFFCommand | _087 | _088 | 4 | 22296 | |
| 2-07 | Forced Thermostat OFF (status) | 12605209 | ForcedThermoOFFStatus | _087 | _088 | 3 | 22297 | |
| 2-07 | Energy Efficiency Command (setting) | 16799514 | EnergyEfficiencyCommand | _087 | _088 | 4 | 22298 | |
| 2-07 | Energy Efficiency Command (status) | 12605211 | EnergyEfficiencyStatus | _087 | _088 | 3 | 22299 | |
| 2-07 | Thermostat Status | 12605212 | ThermoStatus | _087 | _088 | 3 | 22300 | |
| 2-07 | Compressor Status | 12605213 | CompressorStatus | _087 | _088 | 3 | 22301 | |
| 2-07 | Indoor Fan Status | 12605214 | IndoorFanStatus | _087 | _088 | 3 | 22302 | |
| 2-07 | Heater Operation Status | 12605215 | HeaterStatus | _087 | _088 | 3 | 22303 | |
| 2-07 | Ventilation Mode (setting) | 58742560 | VentilationModeCommand | _087 | _088 | 14 | 22304 | |
| 2-07 | Ventilation Mode (status) | 54548257 | VentilationModeStatus | _087 | _088 | 13 | 22305 | |
| 2-07 | Ventilation Amount (setting) | 58742562 | VentilationAmountCommand | _087 | _088 | 14 | 22306 | |
| 2-07 | Ventilation Amount (status) | 54548259 | VentilationAmountStatus | _087 | _088 | 13 | 22307 | |
| 2-08 | ON/OFF (setting) | 16799745 | StartStopCommand | _088 | _089 | 4 | 22529 | set |
| 2-08 | ON/OFF (status) | 12605442 | StartStopStatus | _088 | _089 | 3 | 22530 | Fb |
| 2-08 | Alarm Sign | 12605443 | Alarm | _088 | _089 | 3 | 22531 | |
| 2-08 | Error Code | 54548484 | MalfunctionCode | _088 | _089 | 13 | 22532 | |
| 2-08 | Operation Mode (setting) | 58742789 | AirConModeCommand | _088 | _089 | 14 | 22533 | set |
| 2-08 | Operation Mode (status) | 54548486 | AirConModeStatus | _088 | _089 | 13 | 22534 | Fb |
| 2-08 | Airflow Rate (setting) | 58742791 | AirFlowRateCommand | _088 | _089 | 14 | 22535 | set |
| 2-08 | Airflow Rate (status) | 54548488 | AirFlowRateStatus | _088 | _089 | 13 | 22536 | Fb |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 2-08 | Measured Room Temperature | 22537 | RoomTemp | _088 | _089 | 0 | 22537 | |
| 2-08 | Set Room Temperature | 8411146 | TempAdjust | _088 | _089 | 2 | 22538 | set |
| 2-08 | Filer Limit Sign | 12605451 | FilterSign | _088 | _089 | 3 | 22539 | |
| 2-08 | Filter Limit Sign Reset | 20994060 | FilterSignReset | _088 | _089 | 5 | 22540 | |
| 2-08 | Remote Control Operation (ON/OFF) | 20994061 | RemoteControlStart | _088 | _089 | 5 | 22541 | |
| 2-08 | Remote Control Operation (Operation Mode) | 20994062 | RemoteControlAirConModeSet | _088 | _089 | 5 | 22542 | |
| 2-08 | Remote Control Operation (Set Temperature) | 20994064 | RemoteControlTempAdjust | _088 | _089 | 5 | 22544 | |
| 2-08 | Remote Control Operation (Sub Group Address Control Rejecti | 20994065 | CL_Rejection | _088 | _089 | 5 | 22545 | |
| 2-08 | Elec Total Power | 96491539 | ElecTotalPower | _088 | _089 | 23 | 22547 | |
| 2-08 | Communication Status | 12605460 | CommunicationStatus | _088 | _089 | 3 | 22548 | |
| 2-08 | System Forced OFF | 20994069 | SystemForcedOff | _088 | _089 | 5 | 22549 | |
| 2-08 | Air Direction (setting) | 8411158 | AirDirectionCommand | _088 | _089 | 2 | 22550 | |
| 2-08 | Air Direction (status) | 22551 | AirDirectionStatus | _088 | _089 | 0 | 22551 | |
| 2-08 | Forced Thermostat OFF (setting) | 16799768 | ForcedThermoOFFCommand | _088 | _089 | 4 | 22552 | |
| 2-08 | Forced Thermostat OFF (status) | 12605465 | ForcedThermoOFFStatus | _088 | _089 | 3 | 22553 | |
| 2-08 | Energy Efficiency Command (setting) | 16799770 | EnergyEfficiencyCommand | _088 | _089 | 4 | 22554 | |
| 2-08 | Energy Efficiency Command (status) | 12605467 | EnergyEfficiencyStatus | _088 | _089 | 3 | 22555 | |
| 2-08 | Thermostat Status | 12605468 | ThermoStatus | _088 | _089 | 3 | 22556 | |
| 2-08 | Compressor Status | 12605469 | CompressorStatus | _088 | _089 | 3 | 22557 | |
| 2-08 | Indoor Fan Status | 12605470 | IndoorFanStatus | _088 | _089 | 3 | 22558 | |
| 2-08 | Heater Operation Status | 12605471 | HeaterStatus | _088 | _089 | 3 | 22559 | |
| 2-08 | Ventilation Mode (setting) | 58742816 | VentilationModeCommand | _088 | _089 | 14 | 22560 | |
| 2-08 | Ventilation Mode (status) | 54548513 | VentilationModeStatus | _088 | _089 | 13 | 22561 | |
| 2-08 | Ventilation Amount (setting) | 58742818 | VentilationAmountCommand | _088 | _089 | 14 | 22562 | |
| 2-08 | Ventilation Amount (status) | 54548515 | VentilationAmountStatus | _088 | _089 | 13 | 22563 | |
| 2-09 | ON/OFF (setting) | 16800001 | StartStopCommand | _089 | _090 | 4 | 22785 | set |
| 2-09 | ON/OFF (status) | 12605698 | StartStopStatus | _089 | _090 | 3 | 22786 | Fb |
| 2-09 | Alarm Sign | 12605699 | Alarm | _089 | _090 | 3 | 22787 | |
| 2-09 | Error Code | 54548740 | MalfunctionCode | _089 | _090 | 13 | 22788 | |
| 2-09 | Operation Mode (setting) | 58743045 | AirConModeCommand | _089 | _090 | 14 | 22789 | set |
| 2-09 | Operation Mode (status) | 54548742 | AirConModeStatus | _089 | _090 | 13 | 22790 | Fb |
| 2-09 | Airflow Rate (setting) | 58743047 | AirFlowRateCommand | _089 | _090 | 14 | 22791 | set |
| 2-09 | Airflow Rate (status) | 54548744 | AirFlowRateStatus | _089 | _090 | 13 | 22792 | Fb |
| 2-09 | Measured Room Temperature | 22793 | RoomTemp | _089 | _090 | 0 | 22793 | |
| 2-09 | Set Room Temperature | 8411402 | TempAdjust | _089 | _090 | 2 | 22794 | set |
| 2-09 | Filer Limit Sign | 12605707 | FilterSign | _089 | _090 | 3 | 22795 | |
| 2-09 | Filter Limit Sign Reset | 20994316 | FilterSignReset | _089 | _090 | 5 | 22796 | |
| 2-09 | Remote Control Operation (ON/OFF) | 20994317 | RemoteControlStart | _089 | _090 | 5 | 22797 | |
| 2-09 | Remote Control Operation (Operation Mode) | 20994318 | RemoteControlAirConModeSet | _089 | _090 | 5 | 22798 | |
| 2-09 | Remote Control Operation (Set Temperature) | 20994320 | RemoteControlTempAdjust | _089 | _090 | 5 | 22800 | |
| 2-09 | Remote Control Operation (Sub Group Address Control Rejecti | 20994321 | CL_Rejection | _089 | _090 | 5 | 22801 | |
| 2-09 | Elec Total Power | 96491795 | ElecTotalPower | _089 | _090 | 23 | 22803 | |
| 2-09 | Communication Status | 12605716 | CommunicationStatus | _089 | _090 | 3 | 22804 | |
| 2-09 | System Forced OFF | 20994325 | SystemForcedOff | _089 | _090 | 5 | 22805 | |
| 2-09 | Air Direction (setting) | 8411414 | AirDirectionCommand | _089 | _090 | 2 | 22806 | |
| 2-09 | Air Direction (status) | 22807 | AirDirectionStatus | _089 | _090 | 0 | 22807 | |
| 2-09 | Forced Thermostat OFF (setting) | 16800024 | ForcedThermoOFFCommand | _089 | _090 | 4 | 22808 | |
| 2-09 | Forced Thermostat OFF (status) | 12605721 | ForcedThermoOFFStatus | _089 | _090 | 3 | 22809 | |
| 2-09 | Energy Efficiency Command (setting) | 16800026 | EnergyEfficiencyCommand | _089 | _090 | 4 | 22810 | |
| 2-09 | Energy Efficiency Command (status) | 12605723 | EnergyEfficiencyStatus | _089 | _090 | 3 | 22811 | |
| 2-09 | Thermostat Status | 12605724 | ThermoStatus | _089 | _090 | 3 | 22812 | |
| 2-09 | Compressor Status | 12605725 | CompressorStatus | _089 | _090 | 3 | 22813 | |
| 2-09 | Indoor Fan Status | 12605726 | IndoorFanStatus | _089 | _090 | 3 | 22814 | |
| 2-09 | Heater Operation Status | 12605727 | HeaterStatus | _089 | _090 | 3 | 22815 | |
| 2-09 | Ventilation Mode (setting) | 58743072 | VentilationModeCommand | _089 | _090 | 14 | 22816 | |
| 2-09 | Ventilation Mode (status) | 54548769 | VentilationModeStatus | _089 | _090 | 13 | 22817 | |
| 2-09 | Ventilation Amount (setting) | 58743074 | VentilationAmountCommand | _089 | _090 | 14 | 22818 | |
| 2-09 | Ventilation Amount (status) | 54548771 | VentilationAmountStatus | _089 | _090 | 13 | 22819 | |
| 2-10 | ON/OFF (setting) | 16800257 | StartStopCommand | _090 | _091 | 4 | 23041 | set |
| 2-10 | ON/OFF (status) | 12605954 | StartStopStatus | _090 | _091 | 3 | 23042 | Fb |
| 2-10 | Alarm Sign | 12605955 | Alarm | _090 | _091 | 3 | 23043 | |
| 2-10 | Error Code | 54548996 | MalfunctionCode | _090 | _091 | 13 | 23044 | |
| 2-10 | Operation Mode (setting) | 58743301 | AirConModeCommand | _090 | _091 | 14 | 23045 | set |
| 2-10 | Operation Mode (status) | 54548998 | AirConModeStatus | _090 | _091 | 13 | 23046 | Fb |
| 2-10 | Airflow Rate (setting) | 58743303 | AirFlowRateCommand | _090 | _091 | 14 | 23047 | set |
| 2-10 | Airflow Rate (status) | 54549000 | AirFlowRateStatus | _090 | _091 | 13 | 23048 | Fb |
| 2-10 | Measured Room Temperature | 23049 | RoomTemp | _090 | _091 | 0 | 23049 | |
| 2-10 | Set Room Temperature | 8411658 | TempAdjust | _090 | _091 | 2 | 23050 | set |
| 2-10 | Filer Limit Sign | 12605963 | FilterSign | _090 | _091 | 3 | 23051 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 2-10 | Filter Limit Sign Reset | 20994572 | FilterSignReset | _090 | _091 | 5 | 23052 | |
| 2-10 | Remote Control Operation (ON/OFF) | 20994573 | RemoteControlStart | _090 | _091 | 5 | 23053 | |
| 2-10 | Remote Control Operation (Operation Mode) | 20994574 | RemoteControlAirConModeSet | _090 | _091 | 5 | 23054 | |
| 2-10 | Remote Control Operation (Set Temperature) | 20994576 | RemoteControlTempAdjust | _090 | _091 | 5 | 23056 | |
| 2-10 | Remote Control Operation (Sub Group Address Control Rejecti | 20994577 | CL_Rejection | _090 | _091 | 5 | 23057 | |
| 2-10 | Elec Total Power | 96492051 | ElecTotalPower | _090 | _091 | 23 | 23059 | |
| 2-10 | Communication Status | 12605972 | CommunicationStatus | _090 | _091 | 3 | 23060 | |
| 2-10 | System Forced OFF | 20994581 | SystemForcedOff | _090 | _091 | 5 | 23061 | |
| 2-10 | Air Direction (setting) | 8411670 | AirDirectionCommand | _090 | _091 | 2 | 23062 | |
| 2-10 | Air Direction (status) | 23063 | AirDirectionStatus | _090 | _091 | 0 | 23063 | |
| 2-10 | Forced Thermostat OFF (setting) | 16800280 | ForcedThermoOFFCommand | _090 | _091 | 4 | 23064 | |
| 2-10 | Forced Thermostat OFF (status) | 12605977 | ForcedThermoOFFStatus | _090 | _091 | 3 | 23065 | |
| 2-10 | Energy Efficiency Command (setting) | 16800282 | EnergyEfficiencyCommand | _090 | _091 | 4 | 23066 | |
| 2-10 | Energy Efficiency Command (status) | 12605979 | EnergyEfficiencyStatus | _090 | _091 | 3 | 23067 | |
| 2-10 | Thermostat Status | 12605980 | ThermoStatus | _090 | _091 | 3 | 23068 | |
| 2-10 | Compressor Status | 12605981 | CompressorStatus | _090 | _091 | 3 | 23069 | |
| 2-10 | Indoor Fan Status | 12605982 | IndoorFanStatus | _090 | _091 | 3 | 23070 | |
| 2-10 | Heater Operation Status | 12605983 | HeaterStatus | _090 | _091 | 3 | 23071 | |
| 2-10 | Ventilation Mode (setting) | 58743328 | VentilationModeCommand | _090 | _091 | 14 | 23072 | |
| 2-10 | Ventilation Mode (status) | 54549025 | VentilationModeStatus | _090 | _091 | 13 | 23073 | |
| 2-10 | Ventilation Amount (setting) | 58743330 | VentilationAmountCommand | _090 | _091 | 14 | 23074 | |
| 2-10 | Ventilation Amount (status) | 54549027 | VentilationAmountStatus | _090 | _091 | 13 | 23075 | |
| 2-11 | ON/OFF (setting) | 16800513 | StartStopCommand | _091 | _092 | 4 | 23297 | set |
| 2-11 | ON/OFF (status) | 12606210 | StartStopStatus | _091 | _092 | 3 | 23298 | Fb |
| 2-11 | Alarm Sign | 12606211 | Alarm | _091 | _092 | 3 | 23299 | |
| 2-11 | Error Code | 54549252 | MalfunctionCode | _091 | _092 | 13 | 23300 | |
| 2-11 | Operation Mode (setting) | 58743557 | AirConModeCommand | _091 | _092 | 14 | 23301 | set |
| 2-11 | Operation Mode (status) | 54549254 | AirConModeStatus | _091 | _092 | 13 | 23302 | Fb |
| 2-11 | Airflow Rate (setting) | 58743559 | AirFlowRateCommand | _091 | _092 | 14 | 23303 | set |
| 2-11 | Airflow Rate (status) | 54549256 | AirFlowRateStatus | _091 | _092 | 13 | 23304 | Fb |
| 2-11 | Measured Room Temperature | 23305 | RoomTemp | _091 | _092 | 0 | 23305 | |
| 2-11 | Set Room Temperature | 8411914 | TempAdjust | _091 | _092 | 2 | 23306 | set |
| 2-11 | Filer Limit Sign | 12606219 | FilterSign | _091 | _092 | 3 | 23307 | |
| 2-11 | Filter Limit Sign Reset | 20994828 | FilterSignReset | _091 | _092 | 5 | 23308 | |
| 2-11 | Remote Control Operation (ON/OFF) | 20994829 | RemoteControlStart | _091 | _092 | 5 | 23309 | |
| 2-11 | Remote Control Operation (Operation Mode) | 20994830 | RemoteControlAirConModeSet | _091 | _092 | 5 | 23310 | |
| 2-11 | Remote Control Operation (Set Temperature) | 20994832 | RemoteControlTempAdjust | _091 | _092 | 5 | 23312 | |
| 2-11 | Remote Control Operation (Sub Group Address Control Rejecti | 20994833 | CL_Rejection | _091 | _092 | 5 | 23313 | |
| 2-11 | Elec Total Power | 96492307 | ElecTotalPower | _091 | _092 | 23 | 23315 | |
| 2-11 | Communication Status | 12606228 | CommunicationStatus | _091 | _092 | 3 | 23316 | |
| 2-11 | System Forced OFF | 20994837 | SystemForcedOff | _091 | _092 | 5 | 23317 | |
| 2-11 | Air Direction (setting) | 8411926 | AirDirectionCommand | _091 | _092 | 2 | 23318 | |
| 2-11 | Air Direction (status) | 23319 | AirDirectionStatus | _091 | _092 | 0 | 23319 | |
| 2-11 | Forced Thermostat OFF (setting) | 16800536 | ForcedThermoOFFCommand | _091 | _092 | 4 | 23320 | |
| 2-11 | Forced Thermostat OFF (status) | 12606233 | ForcedThermoOFFStatus | _091 | _092 | 3 | 23321 | |
| 2-11 | Energy Efficiency Command (setting) | 16800538 | EnergyEfficiencyCommand | _091 | _092 | 4 | 23322 | |
| 2-11 | Energy Efficiency Command (status) | 12606235 | EnergyEfficiencyStatus | _091 | _092 | 3 | 23323 | |
| 2-11 | Thermostat Status | 12606236 | ThermoStatus | _091 | _092 | 3 | 23324 | |
| 2-11 | Compressor Status | 12606237 | CompressorStatus | _091 | _092 | 3 | 23325 | |
| 2-11 | Indoor Fan Status | 12606238 | IndoorFanStatus | _091 | _092 | 3 | 23326 | |
| 2-11 | Heater Operation Status | 12606239 | HeaterStatus | _091 | _092 | 3 | 23327 | |
| 2-11 | Ventilation Mode (setting) | 58743584 | VentilationModeCommand | _091 | _092 | 14 | 23328 | |
| 2-11 | Ventilation Mode (status) | 54549281 | VentilationModeStatus | _091 | _092 | 13 | 23329 | |
| 2-11 | Ventilation Amount (setting) | 58743586 | VentilationAmountCommand | _091 | _092 | 14 | 23330 | |
| 2-11 | Ventilation Amount (status) | 54549283 | VentilationAmountStatus | _091 | _092 | 13 | 23331 | |
| 2-12 | ON/OFF (setting) | 16800769 | StartStopCommand | _092 | _093 | 4 | 23553 | set |
| 2-12 | ON/OFF (status) | 12606466 | StartStopStatus | _092 | _093 | 3 | 23554 | Fb |
| 2-12 | Alarm Sign | 12606467 | Alarm | _092 | _093 | 3 | 23555 | |
| 2-12 | Error Code | 54549508 | MalfunctionCode | _092 | _093 | 13 | 23556 | |
| 2-12 | Operation Mode (setting) | 58743813 | AirConModeCommand | _092 | _093 | 14 | 23557 | set |
| 2-12 | Operation Mode (status) | 54549510 | AirConModeStatus | _092 | _093 | 13 | 23558 | Fb |
| 2-12 | Airflow Rate (setting) | 58743815 | AirFlowRateCommand | _092 | _093 | 14 | 23559 | set |
| 2-12 | Airflow Rate (status) | 54549512 | AirFlowRateStatus | _092 | _093 | 13 | 23560 | Fb |
| 2-12 | Measured Room Temperature | 23561 | RoomTemp | _092 | _093 | 0 | 23561 | |
| 2-12 | Set Room Temperature | 8412170 | TempAdjust | _092 | _093 | 2 | 23562 | set |
| 2-12 | Filer Limit Sign | 12606475 | FilterSign | _092 | _093 | 3 | 23563 | |
| 2-12 | Filter Limit Sign Reset | 20995084 | FilterSignReset | _092 | _093 | 5 | 23564 | |
| 2-12 | Remote Control Operation (ON/OFF) | 20995085 | RemoteControlStart | _092 | _093 | 5 | 23565 | |
| 2-12 | Remote Control Operation (Operation Mode) | 20995086 | RemoteControlAirConModeSet | _092 | _093 | 5 | 23566 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 2-12 | Remote Control Operation (Set Temperature) | 20995088 | RemoteControlTempAdjust | _092 | _093 | 5 | 23568 | |
| 2-12 | Remote Control Operation (Sub Group Address Control Rejecti | 20995089 | CL_Rejection | _092 | _093 | 5 | 23569 | |
| 2-12 | Elec Total Power | 96492563 | ElecTotalPower | _092 | _093 | 23 | 23571 | |
| 2-12 | Communication Status | 12606484 | CommunicationStatus | _092 | _093 | 3 | 23572 | |
| 2-12 | System Forced OFF | 20995093 | SystemForcedOff | _092 | _093 | 5 | 23573 | |
| 2-12 | Air Direction (setting) | 8412182 | AirDirectionCommand | _092 | _093 | 2 | 23574 | |
| 2-12 | Air Direction (status) | 23575 | AirDirectionStatus | _092 | _093 | 0 | 23575 | |
| 2-12 | Forced Thermostat OFF (setting) | 16800792 | ForcedThermoOFFCommand | _092 | _093 | 4 | 23576 | |
| 2-12 | Forced Thermostat OFF (status) | 12606489 | ForcedThermoOFFStatus | _092 | _093 | 3 | 23577 | |
| 2-12 | Energy Efficiency Command (setting) | 16800794 | EnergyEfficiencyCommand | _092 | _093 | 4 | 23578 | |
| 2-12 | Energy Efficiency Command (status) | 12606491 | EnergyEfficiencyStatus | _092 | _093 | 3 | 23579 | |
| 2-12 | Thermostat Status | 12606492 | ThermoStatus | _092 | _093 | 3 | 23580 | |
| 2-12 | Compressor Status | 12606493 | CompressorStatus | _092 | _093 | 3 | 23581 | |
| 2-12 | Indoor Fan Status | 12606494 | IndoorFanStatus | _092 | _093 | 3 | 23582 | |
| 2-12 | Heater Operation Status | 12606495 | HeaterStatus | _092 | _093 | 3 | 23583 | |
| 2-12 | Ventilation Mode (setting) | 58743840 | VentilationModeCommand | _092 | _093 | 14 | 23584 | |
| 2-12 | Ventilation Mode (status) | 54549537 | VentilationModeStatus | _092 | _093 | 13 | 23585 | |
| 2-12 | Ventilation Amount (setting) | 58743842 | VentilationAmountCommand | _092 | _093 | 14 | 23586 | |
| 2-12 | Ventilation Amount (status) | 54549539 | VentilationAmountStatus | _092 | _093 | 13 | 23587 | |
| 2-13 | ON/OFF (setting) | 16801025 | StartStopCommand | _093 | _094 | 4 | 23809 | set |
| 2-13 | ON/OFF (status) | 12606722 | StartStopStatus | _093 | _094 | 3 | 23810 | Fb |
| 2-13 | Alarm Sign | 12606723 | Alarm | _093 | _094 | 3 | 23811 | |
| 2-13 | Error Code | 54549764 | MalfunctionCode | _093 | _094 | 13 | 23812 | |
| 2-13 | Operation Mode (setting) | 58744069 | AirConModeCommand | _093 | _094 | 14 | 23813 | set |
| 2-13 | Operation Mode (status) | 54549766 | AirConModeStatus | _093 | _094 | 13 | 23814 | Fb |
| 2-13 | Airflow Rate (setting) | 58744071 | AirFlowRateCommand | _093 | _094 | 14 | 23815 | set |
| 2-13 | Airflow Rate (status) | 54549768 | AirFlowRateStatus | _093 | _094 | 13 | 23816 | Fb |
| 2-13 | Measured Room Temperature | 23817 | RoomTemp | _093 | _094 | 0 | 23817 | |
| 2-13 | Set Room Temperature | 8412426 | TempAdjust | _093 | _094 | 2 | 23818 | set |
| 2-13 | Filer Limit Sign | 12606731 | FilterSign | _093 | _094 | 3 | 23819 | |
| 2-13 | Filter Limit Sign Reset | 20995340 | FilterSignReset | _093 | _094 | 5 | 23820 | |
| 2-13 | Remote Control Operation (ON/OFF) | 20995341 | RemoteControlStart | _093 | _094 | 5 | 23821 | |
| 2-13 | Remote Control Operation (Operation Mode) | 20995342 | RemoteControlAirConModeSet | _093 | _094 | 5 | 23822 | |
| 2-13 | Remote Control Operation (Set Temperature) | 20995344 | RemoteControlTempAdjust | _093 | _094 | 5 | 23824 | |
| 2-13 | Remote Control Operation (Sub Group Address Control Rejecti | 20995345 | CL_Rejection | _093 | _094 | 5 | 23825 | |
| 2-13 | Elec Total Power | 96492819 | ElecTotalPower | _093 | _094 | 23 | 23827 | |
| 2-13 | Communication Status | 12606740 | CommunicationStatus | _093 | _094 | 3 | 23828 | |
| 2-13 | System Forced OFF | 20995349 | SystemForcedOff | _093 | _094 | 5 | 23829 | |
| 2-13 | Air Direction (setting) | 8412438 | AirDirectionCommand | _093 | _094 | 2 | 23830 | |
| 2-13 | Air Direction (status) | 23831 | AirDirectionStatus | _093 | _094 | 0 | 23831 | |
| 2-13 | Forced Thermostat OFF (setting) | 16801048 | ForcedThermoOFFCommand | _093 | _094 | 4 | 23832 | |
| 2-13 | Forced Thermostat OFF (status) | 12606745 | ForcedThermoOFFStatus | _093 | _094 | 3 | 23833 | |
| 2-13 | Energy Efficiency Command (setting) | 16801050 | EnergyEfficiencyCommand | _093 | _094 | 4 | 23834 | |
| 2-13 | Energy Efficiency Command (status) | 12606747 | EnergyEfficiencyStatus | _093 | _094 | 3 | 23835 | |
| 2-13 | Thermostat Status | 12606748 | ThermoStatus | _093 | _094 | 3 | 23836 | |
| 2-13 | Compressor Status | 12606749 | CompressorStatus | _093 | _094 | 3 | 23837 | |
| 2-13 | Indoor Fan Status | 12606750 | IndoorFanStatus | _093 | _094 | 3 | 23838 | |
| 2-13 | Heater Operation Status | 12606751 | HeaterStatus | _093 | _094 | 3 | 23839 | |
| 2-13 | Ventilation Mode (setting) | 58744096 | VentilationModeCommand | _093 | _094 | 14 | 23840 | |
| 2-13 | Ventilation Mode (status) | 54549793 | VentilationModeStatus | _093 | _094 | 13 | 23841 | |
| 2-13 | Ventilation Amount (setting) | 58744098 | VentilationAmountCommand | _093 | _094 | 14 | 23842 | |
| 2-13 | Ventilation Amount (status) | 54549795 | VentilationAmountStatus | _093 | _094 | 13 | 23843 | |
| 2-14 | ON/OFF (setting) | 16801281 | StartStopCommand | _094 | _095 | 4 | 24065 | set |
| 2-14 | ON/OFF (status) | 12606978 | StartStopStatus | _094 | _095 | 3 | 24066 | Fb |
| 2-14 | Alarm Sign | 12606979 | Alarm | _094 | _095 | 3 | 24067 | |
| 2-14 | Error Code | 54550020 | MalfunctionCode | _094 | _095 | 13 | 24068 | |
| 2-14 | Operation Mode (setting) | 58744325 | AirConModeCommand | _094 | _095 | 14 | 24069 | set |
| 2-14 | Operation Mode (status) | 54550022 | AirConModeStatus | _094 | _095 | 13 | 24070 | Fb |
| 2-14 | Airflow Rate (setting) | 58744327 | AirFlowRateCommand | _094 | _095 | 14 | 24071 | set |
| 2-14 | Airflow Rate (status) | 54550024 | AirFlowRateStatus | _094 | _095 | 13 | 24072 | Fb |
| 2-14 | Measured Room Temperature | 24073 | RoomTemp | _094 | _095 | 0 | 24073 | |
| 2-14 | Set Room Temperature | 8412682 | TempAdjust | _094 | _095 | 2 | 24074 | set |
| 2-14 | Filer Limit Sign | 12606987 | FilterSign | _094 | _095 | 3 | 24075 | |
| 2-14 | Filter Limit Sign Reset | 20995596 | FilterSignReset | _094 | _095 | 5 | 24076 | |
| 2-14 | Remote Control Operation (ON/OFF) | 20995597 | RemoteControlStart | _094 | _095 | 5 | 24077 | |
| 2-14 | Remote Control Operation (Operation Mode) | 20995598 | RemoteControlAirConModeSet | _094 | _095 | 5 | 24078 | |
| 2-14 | Remote Control Operation (Set Temperature) | 20995600 | RemoteControlTempAdjust | _094 | _095 | 5 | 24080 | |
| 2-14 | Remote Control Operation (Sub Group Address Control Rejecti | 20995601 | CL_Rejection | _094 | _095 | 5 | 24081 | |
| 2-14 | Elec Total Power | 96493075 | ElecTotalPower | _094 | _095 | 23 | 24083 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 2-14 | Communication Status | 12606996 | CommunicationStatus | _094 | _095 | 3 | 24084 | |
| 2-14 | System Forced OFF | 20995605 | SystemForcedOff | _094 | _095 | 5 | 24085 | |
| 2-14 | Air Direction (setting) | 8412694 | AirDirectionCommand | _094 | _095 | 2 | 24086 | |
| 2-14 | Air Direction (status) | 24087 | AirDirectionStatus | _094 | _095 | 0 | 24087 | |
| 2-14 | Forced Thermostat OFF (setting) | 16801304 | ForcedThermoOFFCommand | _094 | _095 | 4 | 24088 | |
| 2-14 | Forced Thermostat OFF (status) | 12607001 | ForcedThermoOFFStatus | _094 | _095 | 3 | 24089 | |
| 2-14 | Energy Efficiency Command (setting) | 16801306 | EnergyEfficiencyCommand | _094 | _095 | 4 | 24090 | |
| 2-14 | Energy Efficiency Command (status) | 12607003 | EnergyEfficiencyStatus | _094 | _095 | 3 | 24091 | |
| 2-14 | Thermostat Status | 12607004 | ThermoStatus | _094 | _095 | 3 | 24092 | |
| 2-14 | Compressor Status | 12607005 | CompressorStatus | _094 | _095 | 3 | 24093 | |
| 2-14 | Indoor Fan Status | 12607006 | IndoorFanStatus | _094 | _095 | 3 | 24094 | |
| 2-14 | Heater Operation Status | 12607007 | HeaterStatus | _094 | _095 | 3 | 24095 | |
| 2-14 | Ventilation Mode (setting) | 58744352 | VentilationModeCommand | _094 | _095 | 14 | 24096 | |
| 2-14 | Ventilation Mode (status) | 54550049 | VentilationModeStatus | _094 | _095 | 13 | 24097 | |
| 2-14 | Ventilation Amount (setting) | 58744354 | VentilationAmountCommand | _094 | _095 | 14 | 24098 | |
| 2-14 | Ventilation Amount (status) | 54550051 | VentilationAmountStatus | _094 | _095 | 13 | 24099 | |
| 2-15 | ON/OFF (setting) | 16801537 | StartStopCommand | _095 | _096 | 4 | 24321 | set |
| 2-15 | ON/OFF (status) | 12607234 | StartStopStatus | _095 | _096 | 3 | 24322 | Fb |
| 2-15 | Alarm Sign | 12607235 | Alarm | _095 | _096 | 3 | 24323 | |
| 2-15 | Error Code | 54550276 | MalfunctionCode | _095 | _096 | 13 | 24324 | |
| 2-15 | Operation Mode (setting) | 58744581 | AirConModeCommand | _095 | _096 | 14 | 24325 | set |
| 2-15 | Operation Mode (status) | 54550278 | AirConModeStatus | _095 | _096 | 13 | 24326 | Fb |
| 2-15 | Airflow Rate (setting) | 58744583 | AirFlowRateCommand | _095 | _096 | 14 | 24327 | set |
| 2-15 | Airflow Rate (status) | 54550280 | AirFlowRateStatus | _095 | _096 | 13 | 24328 | Fb |
| 2-15 | Measured Room Temperature | 24329 | RoomTemp | _095 | _096 | 0 | 24329 | |
| 2-15 | Set Room Temperature | 8412938 | TempAdjust | _095 | _096 | 2 | 24330 | set |
| 2-15 | Filer Limit Sign | 12607243 | FilterSign | _095 | _096 | 3 | 24331 | |
| 2-15 | Filter Limit Sign Reset | 20995852 | FilterSignReset | _095 | _096 | 5 | 24332 | |
| 2-15 | Remote Control Operation (ON/OFF) | 20995853 | RemoteControlStart | _095 | _096 | 5 | 24333 | |
| 2-15 | Remote Control Operation (Operation Mode) | 20995854 | RemoteControlAirConModeSet | _095 | _096 | 5 | 24334 | |
| 2-15 | Remote Control Operation (Set Temperature) | 20995856 | RemoteControlTempAdjust | _095 | _096 | 5 | 24336 | |
| 2-15 | Remote Control Operation (Sub Group Address Control Reject) | 20995857 | CL_Rejection | _095 | _096 | 5 | 24337 | |
| 2-15 | Elec Total Power | 96493331 | ElecTotalPower | _095 | _096 | 23 | 24339 | |
| 2-15 | Communication Status | 12607252 | CommunicationStatus | _095 | _096 | 3 | 24340 | |
| 2-15 | System Forced OFF | 20995861 | SystemForcedOff | _095 | _096 | 5 | 24341 | |
| 2-15 | Air Direction (setting) | 8412950 | AirDirectionCommand | _095 | _096 | 2 | 24342 | |
| 2-15 | Air Direction (status) | 24343 | AirDirectionStatus | _095 | _096 | 0 | 24343 | |
| 2-15 | Forced Thermostat OFF (setting) | 16801560 | ForcedThermoOFFCommand | _095 | _096 | 4 | 24344 | |
| 2-15 | Forced Thermostat OFF (status) | 12607257 | ForcedThermoOFFStatus | _095 | _096 | 3 | 24345 | |
| 2-15 | Energy Efficiency Command (setting) | 16801562 | EnergyEfficiencyCommand | _095 | _096 | 4 | 24346 | |
| 2-15 | Energy Efficiency Command (status) | 12607259 | EnergyEfficiencyStatus | _095 | _096 | 3 | 24347 | |
| 2-15 | Thermostat Status | 12607260 | ThermoStatus | _095 | _096 | 3 | 24348 | |
| 2-15 | Compressor Status | 12607261 | CompressorStatus | _095 | _096 | 3 | 24349 | |
| 2-15 | Indoor Fan Status | 12607262 | IndoorFanStatus | _095 | _096 | 3 | 24350 | |
| 2-15 | Heater Operation Status | 12607263 | HeaterStatus | _095 | _096 | 3 | 24351 | |
| 2-15 | Ventilation Mode (setting) | 58744608 | VentilationModeCommand | _095 | _096 | 14 | 24352 | |
| 2-15 | Ventilation Mode (status) | 54550305 | VentilationModeStatus | _095 | _096 | 13 | 24353 | |
| 2-15 | Ventilation Amount (setting) | 58744610 | VentilationAmountCommand | _095 | _096 | 14 | 24354 | |
| 2-15 | Ventilation Amount (status) | 54550307 | VentilationAmountStatus | _095 | _096 | 13 | 24355 | |
| 3-00 | ON/OFF (setting) | 16801793 | StartStopCommand | _096 | _097 | 4 | 24577 | set |
| 3-00 | ON/OFF (status) | 12607490 | StartStopStatus | _096 | _097 | 3 | 24578 | Fb |
| 3-00 | Alarm Sign | 12607491 | Alarm | _096 | _097 | 3 | 24579 | |
| 3-00 | Error Code | 54550532 | MalfunctionCode | _096 | _097 | 13 | 24580 | |
| 3-00 | Operation Mode (setting) | 58744837 | AirConModeCommand | _096 | _097 | 14 | 24581 | set |
| 3-00 | Operation Mode (status) | 54550534 | AirConModeStatus | _096 | _097 | 13 | 24582 | Fb |
| 3-00 | Airflow Rate (setting) | 58744839 | AirFlowRateCommand | _096 | _097 | 14 | 24583 | set |
| 3-00 | Airflow Rate (status) | 54550536 | AirFlowRateStatus | _096 | _097 | 13 | 24584 | Fb |
| 3-00 | Measured Room Temperature | 24585 | RoomTemp | _096 | _097 | 0 | 24585 | |
| 3-00 | Set Room Temperature | 8413194 | TempAdjust | _096 | _097 | 2 | 24586 | set |
| 3-00 | Filer Limit Sign | 12607499 | FilterSign | _096 | _097 | 3 | 24587 | |
| 3-00 | Filter Limit Sign Reset | 20996108 | FilterSignReset | _096 | _097 | 5 | 24588 | |
| 3-00 | Remote Control Operation (ON/OFF) | 20996109 | RemoteControlStart | _096 | _097 | 5 | 24589 | |
| 3-00 | Remote Control Operation (Operation Mode) | 20996110 | RemoteControlAirConModeSet | _096 | _097 | 5 | 24590 | |
| 3-00 | Remote Control Operation (Set Temperature) | 20996112 | RemoteControlTempAdjust | _096 | _097 | 5 | 24592 | |
| 3-00 | Remote Control Operation (Sub Group Address Control Reject) | 20996113 | CL_Rejection | _096 | _097 | 5 | 24593 | |
| 3-00 | Elec Total Power | 96493587 | ElecTotalPower | _096 | _097 | 23 | 24595 | |
| 3-00 | Communication Status | 12607508 | CommunicationStatus | _096 | _097 | 3 | 24596 | |
| 3-00 | System Forced OFF | 20996117 | SystemForcedOff | _096 | _097 | 5 | 24597 | |
| 3-00 | Air Direction (setting) | 8413206 | AirDirectionCommand | _096 | _097 | 2 | 24598 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 3-00 | Air Direction (status) | 24599 | AirDirectionStatus | _096 | _097 | 0 | 24599 | |
| 3-00 | Forced Thermostat OFF (setting) | 16801816 | ForcedThermoOFFCommand | _096 | _097 | 4 | 24600 | |
| 3-00 | Forced Thermostat OFF (status) | 12607513 | ForcedThermoOFFStatus | _096 | _097 | 3 | 24601 | |
| 3-00 | Energy Efficiency Command (setting) | 16801818 | EnergyEfficiencyCommand | _096 | _097 | 4 | 24602 | |
| 3-00 | Energy Efficiency Command (status) | 12607515 | EnergyEfficiencyStatus | _096 | _097 | 3 | 24603 | |
| 3-00 | Thermostat Status | 12607516 | ThermoStatus | _096 | _097 | 3 | 24604 | |
| 3-00 | Compressor Status | 12607517 | CompressorStatus | _096 | _097 | 3 | 24605 | |
| 3-00 | Indoor Fan Status | 12607518 | IndoorFanStatus | _096 | _097 | 3 | 24606 | |
| 3-00 | Heater Operation Status | 12607519 | HeaterStatus | _096 | _097 | 3 | 24607 | |
| 3-00 | Ventilation Mode (setting) | 58744864 | VentilationModeCommand | _096 | _097 | 14 | 24608 | |
| 3-00 | Ventilation Mode (status) | 54550561 | VentilationModeStatus | _096 | _097 | 13 | 24609 | |
| 3-00 | Ventilation Amount (setting) | 58744866 | VentilationAmountCommand | _096 | _097 | 14 | 24610 | |
| 3-00 | Ventilation Amount (status) | 54550563 | VentilationAmountStatus | _096 | _097 | 13 | 24611 | |
| 3-01 | ON/OFF (setting) | 16802049 | StartStopCommand | _097 | _098 | 4 | 24833 | set |
| 3-01 | ON/OFF (status) | 12607746 | StartStopStatus | _097 | _098 | 3 | 24834 | Fb |
| 3-01 | Alarm Sign | 12607747 | Alarm | _097 | _098 | 3 | 24835 | |
| 3-01 | Error Code | 54550788 | MalfunctionCode | _097 | _098 | 13 | 24836 | |
| 3-01 | Operation Mode (setting) | 58745093 | AirConModeCommand | _097 | _098 | 14 | 24837 | set |
| 3-01 | Operation Mode (status) | 54550790 | AirConModeStatus | _097 | _098 | 13 | 24838 | Fb |
| 3-01 | Airflow Rate (setting) | 58745095 | AirFlowRateCommand | _097 | _098 | 14 | 24839 | set |
| 3-01 | Airflow Rate (status) | 54550792 | AirFlowRateStatus | _097 | _098 | 13 | 24840 | Fb |
| 3-01 | Measured Room Temperature | 24841 | RoomTemp | _097 | _098 | 0 | 24841 | |
| 3-01 | Set Room Temperature | 8413450 | TempAdjust | _097 | _098 | 2 | 24842 | set |
| 3-01 | Filer Limit Sign | 12607755 | FilterSign | _097 | _098 | 3 | 24843 | |
| 3-01 | Filter Limit Sign Reset | 20996364 | FilterSignReset | _097 | _098 | 5 | 24844 | |
| 3-01 | Remote Control Operation (ON/OFF) | 20996365 | RemoteControlStart | _097 | _098 | 5 | 24845 | |
| 3-01 | Remote Control Operation (Operation Mode) | 20996366 | RemoteControlAirConModeSet | _097 | _098 | 5 | 24846 | |
| 3-01 | Remote Control Operation (Set Temperature) | 20996368 | RemoteControlTempAdjust | _097 | _098 | 5 | 24848 | |
| 3-01 | Remote Control Operation (Sub Group Address Control Reject) | 20996369 | CL_Rejection | _097 | _098 | 5 | 24849 | |
| 3-01 | Elec Total Power | 96493843 | ElecTotalPower | _097 | _098 | 23 | 24851 | |
| 3-01 | Communication Status | 12607764 | CommunicationStatus | _097 | _098 | 3 | 24852 | |
| 3-01 | System Forced OFF | 20996373 | SystemForcedOff | _097 | _098 | 5 | 24853 | |
| 3-01 | Air Direction (setting) | 8413462 | AirDirectionCommand | _097 | _098 | 2 | 24854 | |
| 3-01 | Air Direction (status) | 24855 | AirDirectionStatus | _097 | _098 | 0 | 24855 | |
| 3-01 | Forced Thermostat OFF (setting) | 16802072 | ForcedThermoOFFCommand | _097 | _098 | 4 | 24856 | |
| 3-01 | Forced Thermostat OFF (status) | 12607769 | ForcedThermoOFFStatus | _097 | _098 | 3 | 24857 | |
| 3-01 | Energy Efficiency Command (setting) | 16802074 | EnergyEfficiencyCommand | _097 | _098 | 4 | 24858 | |
| 3-01 | Energy Efficiency Command (status) | 12607771 | EnergyEfficiencyStatus | _097 | _098 | 3 | 24859 | |
| 3-01 | Thermostat Status | 12607772 | ThermoStatus | _097 | _098 | 3 | 24860 | |
| 3-01 | Compressor Status | 12607773 | CompressorStatus | _097 | _098 | 3 | 24861 | |
| 3-01 | Indoor Fan Status | 12607774 | IndoorFanStatus | _097 | _098 | 3 | 24862 | |
| 3-01 | Heater Operation Status | 12607775 | HeaterStatus | _097 | _098 | 3 | 24863 | |
| 3-01 | Ventilation Mode (setting) | 58745120 | VentilationModeCommand | _097 | _098 | 14 | 24864 | |
| 3-01 | Ventilation Mode (status) | 54550817 | VentilationModeStatus | _097 | _098 | 13 | 24865 | |
| 3-01 | Ventilation Amount (setting) | 58745122 | VentilationAmountCommand | _097 | _098 | 14 | 24866 | |
| 3-01 | Ventilation Amount (status) | 54550819 | VentilationAmountStatus | _097 | _098 | 13 | 24867 | |
| 3-02 | ON/OFF (setting) | 16802305 | StartStopCommand | _098 | _099 | 4 | 25089 | set |
| 3-02 | ON/OFF (status) | 12608002 | StartStopStatus | _098 | _099 | 3 | 25090 | Fb |
| 3-02 | Alarm Sign | 12608003 | Alarm | _098 | _099 | 3 | 25091 | |
| 3-02 | Error Code | 54551044 | MalfunctionCode | _098 | _099 | 13 | 25092 | |
| 3-02 | Operation Mode (setting) | 58745349 | AirConModeCommand | _098 | _099 | 14 | 25093 | set |
| 3-02 | Operation Mode (status) | 54551046 | AirConModeStatus | _098 | _099 | 13 | 25094 | Fb |
| 3-02 | Airflow Rate (setting) | 58745351 | AirFlowRateCommand | _098 | _099 | 14 | 25095 | set |
| 3-02 | Airflow Rate (status) | 54551048 | AirFlowRateStatus | _098 | _099 | 13 | 25096 | Fb |
| 3-02 | Measured Room Temperature | 25097 | RoomTemp | _098 | _099 | 0 | 25097 | |
| 3-02 | Set Room Temperature | 8413706 | TempAdjust | _098 | _099 | 2 | 25098 | set |
| 3-02 | Filer Limit Sign | 12608011 | FilterSign | _098 | _099 | 3 | 25099 | |
| 3-02 | Filter Limit Sign Reset | 20996620 | FilterSignReset | _098 | _099 | 5 | 25100 | |
| 3-02 | Remote Control Operation (ON/OFF) | 20996621 | RemoteControlStart | _098 | _099 | 5 | 25101 | |
| 3-02 | Remote Control Operation (Operation Mode) | 20996622 | RemoteControlAirConModeSet | _098 | _099 | 5 | 25102 | |
| 3-02 | Remote Control Operation (Set Temperature) | 20996624 | RemoteControlTempAdjust | _098 | _099 | 5 | 25104 | |
| 3-02 | Remote Control Operation (Sub Group Address Control Reject) | 20996625 | CL_Rejection | _098 | _099 | 5 | 25105 | |
| 3-02 | Elec Total Power | 96494099 | ElecTotalPower | _098 | _099 | 23 | 25107 | |
| 3-02 | Communication Status | 12608020 | CommunicationStatus | _098 | _099 | 3 | 25108 | |
| 3-02 | System Forced OFF | 20996629 | SystemForcedOff | _098 | _099 | 5 | 25109 | |
| 3-02 | Air Direction (setting) | 8413718 | AirDirectionCommand | _098 | _099 | 2 | 25110 | |
| 3-02 | Air Direction (status) | 25111 | AirDirectionStatus | _098 | _099 | 0 | 25111 | |
| 3-02 | Forced Thermostat OFF (setting) | 16802328 | ForcedThermoOFFCommand | _098 | _099 | 4 | 25112 | |
| 3-02 | Forced Thermostat OFF (status) | 12608025 | ForcedThermoOFFStatus | _098 | _099 | 3 | 25113 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 3-02 | Energy Efficiency Command (setting) | 16802330 | EnergyEfficiencyCommand | _098 | _099 | 4 | 25114 | |
| 3-02 | Energy Efficiency Command (status) | 12608027 | EnergyEfficiencyStatus | _098 | _099 | 3 | 25115 | |
| 3-02 | Thermostat Status | 12608028 | ThermoStatus | _098 | _099 | 3 | 25116 | |
| 3-02 | Compressor Status | 12608029 | CompressorStatus | _098 | _099 | 3 | 25117 | |
| 3-02 | Indoor Fan Status | 12608030 | IndoorFanStatus | _098 | _099 | 3 | 25118 | |
| 3-02 | Heater Operation Status | 12608031 | HeaterStatus | _098 | _099 | 3 | 25119 | |
| 3-02 | Ventilation Mode (setting) | 58745376 | VentilationModeCommand | _098 | _099 | 14 | 25120 | |
| 3-02 | Ventilation Mode (status) | 54551073 | VentilationModeStatus | _098 | _099 | 13 | 25121 | |
| 3-02 | Ventilation Amount (setting) | 58745378 | VentilationAmountCommand | _098 | _099 | 14 | 25122 | |
| 3-02 | Ventilation Amount (status) | 54551075 | VentilationAmountStatus | _098 | _099 | 13 | 25123 | |
| 3-03 | ON/OFF (setting) | 16802561 | StartStopCommand | _099 | _100 | 4 | 25345 | set |
| 3-03 | ON/OFF (status) | 12608258 | StartStopStatus | _099 | _100 | 3 | 25346 | Fb |
| 3-03 | Alarm Sign | 12608259 | Alarm | _099 | _100 | 3 | 25347 | |
| 3-03 | Error Code | 54551300 | MalfunctionCode | _099 | _100 | 13 | 25348 | |
| 3-03 | Operation Mode (setting) | 58745605 | AirConModeCommand | _099 | _100 | 14 | 25349 | set |
| 3-03 | Operation Mode (status) | 54551302 | AirConModeStatus | _099 | _100 | 13 | 25350 | Fb |
| 3-03 | Airflow Rate (setting) | 58745607 | AirFlowRateCommand | _099 | _100 | 14 | 25351 | set |
| 3-03 | Airflow Rate (status) | 54551304 | AirFlowRateStatus | _099 | _100 | 13 | 25352 | Fb |
| 3-03 | Measured Room Temperature | 25353 | RoomTemp | _099 | _100 | 0 | 25353 | |
| 3-03 | Set Room Temperature | 8413962 | TempAdjust | _099 | _100 | 2 | 25354 | set |
| 3-03 | Filer Limit Sign | 12608267 | FilterSign | _099 | _100 | 3 | 25355 | |
| 3-03 | Filter Limit Sign Reset | 20996876 | FilterSignReset | _099 | _100 | 5 | 25356 | |
| 3-03 | Remote Control Operation (ON/OFF) | 20996877 | RemoteControlStart | _099 | _100 | 5 | 25357 | |
| 3-03 | Remote Control Operation (Operation Mode) | 20996878 | RemoteControlAirConModeSet | _099 | _100 | 5 | 25358 | |
| 3-03 | Remote Control Operation (Set Temperature) | 20996880 | RemoteControlTempAdjust | _099 | _100 | 5 | 25360 | |
| 3-03 | Remote Control Operation (Sub Group Address Control Reject) | 20996881 | CL_Rejection | _099 | _100 | 5 | 25361 | |
| 3-03 | Elec Total Power | 96494355 | ElecTotalPower | _099 | _100 | 23 | 25363 | |
| 3-03 | Communication Status | 12608276 | CommunicationStatus | _099 | _100 | 3 | 25364 | |
| 3-03 | System Forced OFF | 20996885 | SystemForcedOff | _099 | _100 | 5 | 25365 | |
| 3-03 | Air Direction (setting) | 8413974 | AirDirectionCommand | _099 | _100 | 2 | 25366 | |
| 3-03 | Air Direction (status) | 25367 | AirDirectionStatus | _099 | _100 | 0 | 25367 | |
| 3-03 | Forced Thermostat OFF (setting) | 16802584 | ForcedThermoOFFCommand | _099 | _100 | 4 | 25368 | |
| 3-03 | Forced Thermostat OFF (status) | 12608281 | ForcedThermoOFFStatus | _099 | _100 | 3 | 25369 | |
| 3-03 | Energy Efficiency Command (setting) | 16802586 | EnergyEfficiencyCommand | _099 | _100 | 4 | 25370 | |
| 3-03 | Energy Efficiency Command (status) | 12608283 | EnergyEfficiencyStatus | _099 | _100 | 3 | 25371 | |
| 3-03 | Thermostat Status | 12608284 | ThermoStatus | _099 | _100 | 3 | 25372 | |
| 3-03 | Compressor Status | 12608285 | CompressorStatus | _099 | _100 | 3 | 25373 | |
| 3-03 | Indoor Fan Status | 12608286 | IndoorFanStatus | _099 | _100 | 3 | 25374 | |
| 3-03 | Heater Operation Status | 12608287 | HeaterStatus | _099 | _100 | 3 | 25375 | |
| 3-03 | Ventilation Mode (setting) | 58745632 | VentilationModeCommand | _099 | _100 | 14 | 25376 | |
| 3-03 | Ventilation Mode (status) | 54551329 | VentilationModeStatus | _099 | _100 | 13 | 25377 | |
| 3-03 | Ventilation Amount (setting) | 58745634 | VentilationAmountCommand | _099 | _100 | 14 | 25378 | |
| 3-03 | Ventilation Amount (status) | 54551331 | VentilationAmountStatus | _099 | _100 | 13 | 25379 | |
| 3-04 | ON/OFF (setting) | 16802817 | StartStopCommand | _100 | _101 | 4 | 25601 | set |
| 3-04 | ON/OFF (status) | 12608514 | StartStopStatus | _100 | _101 | 3 | 25602 | Fb |
| 3-04 | Alarm Sign | 12608515 | Alarm | _100 | _101 | 3 | 25603 | |
| 3-04 | Error Code | 54551556 | MalfunctionCode | _100 | _101 | 13 | 25604 | |
| 3-04 | Operation Mode (setting) | 58745861 | AirConModeCommand | _100 | _101 | 14 | 25605 | set |
| 3-04 | Operation Mode (status) | 54551558 | AirConModeStatus | _100 | _101 | 13 | 25606 | Fb |
| 3-04 | Airflow Rate (setting) | 58745863 | AirFlowRateCommand | _100 | _101 | 14 | 25607 | set |
| 3-04 | Airflow Rate (status) | 54551560 | AirFlowRateStatus | _100 | _101 | 13 | 25608 | Fb |
| 3-04 | Measured Room Temperature | 25609 | RoomTemp | _100 | _101 | 0 | 25609 | |
| 3-04 | Set Room Temperature | 8414218 | TempAdjust | _100 | _101 | 2 | 25610 | set |
| 3-04 | Filer Limit Sign | 12608523 | FilterSign | _100 | _101 | 3 | 25611 | |
| 3-04 | Filter Limit Sign Reset | 20997132 | FilterSignReset | _100 | _101 | 5 | 25612 | |
| 3-04 | Remote Control Operation (ON/OFF) | 20997133 | RemoteControlStart | _100 | _101 | 5 | 25613 | |
| 3-04 | Remote Control Operation (Operation Mode) | 20997134 | RemoteControlAirConModeSet | _100 | _101 | 5 | 25614 | |
| 3-04 | Remote Control Operation (Set Temperature) | 20997136 | RemoteControlTempAdjust | _100 | _101 | 5 | 25616 | |
| 3-04 | Remote Control Operation (Sub Group Address Control Reject) | 20997137 | CL_Rejection | _100 | _101 | 5 | 25617 | |
| 3-04 | Elec Total Power | 96494611 | ElecTotalPower | _100 | _101 | 23 | 25619 | |
| 3-04 | Communication Status | 12608532 | CommunicationStatus | _100 | _101 | 3 | 25620 | |
| 3-04 | System Forced OFF | 20997141 | SystemForcedOff | _100 | _101 | 5 | 25621 | |
| 3-04 | Air Direction (setting) | 8414230 | AirDirectionCommand | _100 | _101 | 2 | 25622 | |
| 3-04 | Air Direction (status) | 25623 | AirDirectionStatus | _100 | _101 | 0 | 25623 | |
| 3-04 | Forced Thermostat OFF (setting) | 16802840 | ForcedThermoOFFCommand | _100 | _101 | 4 | 25624 | |
| 3-04 | Forced Thermostat OFF (status) | 12608537 | ForcedThermoOFFStatus | _100 | _101 | 3 | 25625 | |
| 3-04 | Energy Efficiency Command (setting) | 16802842 | EnergyEfficiencyCommand | _100 | _101 | 4 | 25626 | |
| 3-04 | Energy Efficiency Command (status) | 12608539 | EnergyEfficiencyStatus | _100 | _101 | 3 | 25627 | |
| 3-04 | Thermostat Status | 12608540 | ThermoStatus | _100 | _101 | 3 | 25628 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 3-04 | Compressor Status | 12608541 | CompressorStatus | _100 | _101 | 3 | 25629 | |
| 3-04 | Indoor Fan Status | 12608542 | IndoorFanStatus | _100 | _101 | 3 | 25630 | |
| 3-04 | Heater Operation Status | 12608543 | HeaterStatus | _100 | _101 | 3 | 25631 | |
| 3-04 | Ventilation Mode (setting) | 58745888 | VentilationModeCommand | _100 | _101 | 14 | 25632 | |
| 3-04 | Ventilation Mode (status) | 54551585 | VentilationModeStatus | _100 | _101 | 13 | 25633 | |
| 3-04 | Ventilation Amount (setting) | 58745890 | VentilationAmountCommand | _100 | _101 | 14 | 25634 | |
| 3-04 | Ventilation Amount (status) | 54551587 | VentilationAmountStatus | _100 | _101 | 13 | 25635 | |
| 3-05 | ON/OFF (setting) | 16803073 | StartStopCommand | _101 | _102 | 4 | 25857 | set |
| 3-05 | ON/OFF (status) | 12608770 | StartStopStatus | _101 | _102 | 3 | 25858 | Fb |
| 3-05 | Alarm Sign | 12608771 | Alarm | _101 | _102 | 3 | 25859 | |
| 3-05 | Error Code | 54551812 | MalfunctionCode | _101 | _102 | 13 | 25860 | |
| 3-05 | Operation Mode (setting) | 58746117 | AirConModeCommand | _101 | _102 | 14 | 25861 | set |
| 3-05 | Operation Mode (status) | 54551814 | AirConModeStatus | _101 | _102 | 13 | 25862 | Fb |
| 3-05 | Airflow Rate (setting) | 58746119 | AirFlowRateCommand | _101 | _102 | 14 | 25863 | set |
| 3-05 | Airflow Rate (status) | 54551816 | AirFlowRateStatus | _101 | _102 | 13 | 25864 | Fb |
| 3-05 | Measured Room Temperature | 25865 | RoomTemp | _101 | _102 | 0 | 25865 | |
| 3-05 | Set Room Temperature | 8414474 | TempAdjust | _101 | _102 | 2 | 25866 | set |
| 3-05 | Filer Limit Sign | 12608779 | FilterSign | _101 | _102 | 3 | 25867 | |
| 3-05 | Filter Limit Sign Reset | 20997388 | FilterSignReset | _101 | _102 | 5 | 25868 | |
| 3-05 | Remote Control Operation (ON/OFF) | 20997389 | RemoteControlStart | _101 | _102 | 5 | 25869 | |
| 3-05 | Remote Control Operation (Operation Mode) | 20997390 | RemoteControlAirConModeSet | _101 | _102 | 5 | 25870 | |
| 3-05 | Remote Control Operation (Set Temperature) | 20997392 | RemoteControlTempAdjust | _101 | _102 | 5 | 25872 | |
| 3-05 | Remote Control Operation (Sub Group Address Control Reject) | 20997393 | CL_Rejection | _101 | _102 | 5 | 25873 | |
| 3-05 | Elec Total Power | 96494867 | ElecTotalPower | _101 | _102 | 23 | 25875 | |
| 3-05 | Communication Status | 12608788 | CommunicationStatus | _101 | _102 | 3 | 25876 | |
| 3-05 | System Forced OFF | 20997397 | SystemForcedOff | _101 | _102 | 5 | 25877 | |
| 3-05 | Air Direction (setting) | 8414486 | AirDirectionCommand | _101 | _102 | 2 | 25878 | |
| 3-05 | Air Direction (status) | 25879 | AirDirectionStatus | _101 | _102 | 0 | 25879 | |
| 3-05 | Forced Thermostat OFF (setting) | 16803096 | ForcedThermoOFFCommand | _101 | _102 | 4 | 25880 | |
| 3-05 | Forced Thermostat OFF (status) | 12608793 | ForcedThermoOFFStatus | _101 | _102 | 3 | 25881 | |
| 3-05 | Energy Efficiency Command (setting) | 16803098 | EnergyEfficiencyCommand | _101 | _102 | 4 | 25882 | |
| 3-05 | Energy Efficiency Command (status) | 12608795 | EnergyEfficiencyStatus | _101 | _102 | 3 | 25883 | |
| 3-05 | Thermostat Status | 12608796 | ThermoStatus | _101 | _102 | 3 | 25884 | |
| 3-05 | Compressor Status | 12608797 | CompressorStatus | _101 | _102 | 3 | 25885 | |
| 3-05 | Indoor Fan Status | 12608798 | IndoorFanStatus | _101 | _102 | 3 | 25886 | |
| 3-05 | Heater Operation Status | 12608799 | HeaterStatus | _101 | _102 | 3 | 25887 | |
| 3-05 | Ventilation Mode (setting) | 58746144 | VentilationModeCommand | _101 | _102 | 14 | 25888 | |
| 3-05 | Ventilation Mode (status) | 54551841 | VentilationModeStatus | _101 | _102 | 13 | 25889 | |
| 3-05 | Ventilation Amount (setting) | 58746146 | VentilationAmountCommand | _101 | _102 | 14 | 25890 | |
| 3-05 | Ventilation Amount (status) | 54551843 | VentilationAmountStatus | _101 | _102 | 13 | 25891 | |
| 3-06 | ON/OFF (setting) | 16803329 | StartStopCommand | _102 | _103 | 4 | 26113 | set |
| 3-06 | ON/OFF (status) | 12609026 | StartStopStatus | _102 | _103 | 3 | 26114 | Fb |
| 3-06 | Alarm Sign | 12609027 | Alarm | _102 | _103 | 3 | 26115 | |
| 3-06 | Error Code | 54552068 | MalfunctionCode | _102 | _103 | 13 | 26116 | |
| 3-06 | Operation Mode (setting) | 58746373 | AirConModeCommand | _102 | _103 | 14 | 26117 | set |
| 3-06 | Operation Mode (status) | 54552070 | AirConModeStatus | _102 | _103 | 13 | 26118 | Fb |
| 3-06 | Airflow Rate (setting) | 58746375 | AirFlowRateCommand | _102 | _103 | 14 | 26119 | set |
| 3-06 | Airflow Rate (status) | 54552072 | AirFlowRateStatus | _102 | _103 | 13 | 26120 | Fb |
| 3-06 | Measured Room Temperature | 26121 | RoomTemp | _102 | _103 | 0 | 26121 | |
| 3-06 | Set Room Temperature | 8414730 | TempAdjust | _102 | _103 | 2 | 26122 | set |
| 3-06 | Filer Limit Sign | 12609035 | FilterSign | _102 | _103 | 3 | 26123 | |
| 3-06 | Filter Limit Sign Reset | 20997644 | FilterSignReset | _102 | _103 | 5 | 26124 | |
| 3-06 | Remote Control Operation (ON/OFF) | 20997645 | RemoteControlStart | _102 | _103 | 5 | 26125 | |
| 3-06 | Remote Control Operation (Operation Mode) | 20997646 | RemoteControlAirConModeSet | _102 | _103 | 5 | 26126 | |
| 3-06 | Remote Control Operation (Set Temperature) | 20997648 | RemoteControlTempAdjust | _102 | _103 | 5 | 26128 | |
| 3-06 | Remote Control Operation (Sub Group Address Control Reject) | 20997649 | CL_Rejection | _102 | _103 | 5 | 26129 | |
| 3-06 | Elec Total Power | 96495123 | ElecTotalPower | _102 | _103 | 23 | 26131 | |
| 3-06 | Communication Status | 12609044 | CommunicationStatus | _102 | _103 | 3 | 26132 | |
| 3-06 | System Forced OFF | 20997653 | SystemForcedOff | _102 | _103 | 5 | 26133 | |
| 3-06 | Air Direction (setting) | 8414742 | AirDirectionCommand | _102 | _103 | 2 | 26134 | |
| 3-06 | Air Direction (status) | 26135 | AirDirectionStatus | _102 | _103 | 0 | 26135 | |
| 3-06 | Forced Thermostat OFF (setting) | 16803352 | ForcedThermoOFFCommand | _102 | _103 | 4 | 26136 | |
| 3-06 | Forced Thermostat OFF (status) | 12609049 | ForcedThermoOFFStatus | _102 | _103 | 3 | 26137 | |
| 3-06 | Energy Efficiency Command (setting) | 16803354 | EnergyEfficiencyCommand | _102 | _103 | 4 | 26138 | |
| 3-06 | Energy Efficiency Command (status) | 12609051 | EnergyEfficiencyStatus | _102 | _103 | 3 | 26139 | |
| 3-06 | Thermostat Status | 12609052 | ThermoStatus | _102 | _103 | 3 | 26140 | |
| 3-06 | Compressor Status | 12609053 | CompressorStatus | _102 | _103 | 3 | 26141 | |
| 3-06 | Indoor Fan Status | 12609054 | IndoorFanStatus | _102 | _103 | 3 | 26142 | |
| 3-06 | Heater Operation Status | 12609055 | HeaterStatus | _102 | _103 | 3 | 26143 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 3-06 | Ventilation Mode (setting) | 58746400 | VentilationModeCommand | _102 | _103 | 14 | 26144 | |
| 3-06 | Ventilation Mode (status) | 54552097 | VentilationModeStatus | _102 | _103 | 13 | 26145 | |
| 3-06 | Ventilation Amount (setting) | 58746402 | VentilationAmountCommand | _102 | _103 | 14 | 26146 | |
| 3-06 | Ventilation Amount (status) | 54552099 | VentilationAmountStatus | _102 | _103 | 13 | 26147 | |
| 3-07 | ON/OFF (setting) | 16803585 | StartStopCommand | _103 | _104 | 4 | 26369 | set |
| 3-07 | ON/OFF (status) | 12609282 | StartStopStatus | _103 | _104 | 3 | 26370 | Fb |
| 3-07 | Alarm Sign | 12609283 | Alarm | _103 | _104 | 3 | 26371 | |
| 3-07 | Error Code | 54552324 | MalfunctionCode | _103 | _104 | 13 | 26372 | |
| 3-07 | Operation Mode (setting) | 58746629 | AirConModeCommand | _103 | _104 | 14 | 26373 | set |
| 3-07 | Operation Mode (status) | 54552326 | AirConModeStatus | _103 | _104 | 13 | 26374 | Fb |
| 3-07 | Airflow Rate (setting) | 58746631 | AirFlowRateCommand | _103 | _104 | 14 | 26375 | set |
| 3-07 | Airflow Rate (status) | 54552328 | AirFlowRateStatus | _103 | _104 | 13 | 26376 | Fb |
| 3-07 | Measured Room Temperature | 26377 | RoomTemp | _103 | _104 | 0 | 26377 | |
| 3-07 | Set Room Temperature | 8414986 | TempAdjust | _103 | _104 | 2 | 26378 | set |
| 3-07 | Filer Limit Sign | 12609291 | FilterSign | _103 | _104 | 3 | 26379 | |
| 3-07 | Filter Limit Sign Reset | 20997900 | FilterSignReset | _103 | _104 | 5 | 26380 | |
| 3-07 | Remote Control Operation (ON/OFF) | 20997901 | RemoteControlStart | _103 | _104 | 5 | 26381 | |
| 3-07 | Remote Control Operation (Operation Mode) | 20997902 | RemoteControlAirConModeSet | _103 | _104 | 5 | 26382 | |
| 3-07 | Remote Control Operation (Set Temperature) | 20997904 | RemoteControlTempAdjust | _103 | _104 | 5 | 26384 | |
| 3-07 | Remote Control Operation (Sub Group Address Control Reject) | 20997905 | CL_Rejection | _103 | _104 | 5 | 26385 | |
| 3-07 | Elec Total Power | 96495379 | ElecTotalPower | _103 | _104 | 23 | 26387 | |
| 3-07 | Communication Status | 12609300 | CommunicationStatus | _103 | _104 | 3 | 26388 | |
| 3-07 | System Forced OFF | 20997909 | SystemForcedOff | _103 | _104 | 5 | 26389 | |
| 3-07 | Air Direction (setting) | 8414998 | AirDirectionCommand | _103 | _104 | 2 | 26390 | |
| 3-07 | Air Direction (status) | 26391 | AirDirectionStatus | _103 | _104 | 0 | 26391 | |
| 3-07 | Forced Thermostat OFF (setting) | 16803608 | ForcedThermoOFFCommand | _103 | _104 | 4 | 26392 | |
| 3-07 | Forced Thermostat OFF (status) | 12609305 | ForcedThermoOFFStatus | _103 | _104 | 3 | 26393 | |
| 3-07 | Energy Efficiency Command (setting) | 16803610 | EnergyEfficiencyCommand | _103 | _104 | 4 | 26394 | |
| 3-07 | Energy Efficiency Command (status) | 12609307 | EnergyEfficiencyStatus | _103 | _104 | 3 | 26395 | |
| 3-07 | Thermostat Status | 12609308 | ThermoStatus | _103 | _104 | 3 | 26396 | |
| 3-07 | Compressor Status | 12609309 | CompressorStatus | _103 | _104 | 3 | 26397 | |
| 3-07 | Indoor Fan Status | 12609310 | IndoorFanStatus | _103 | _104 | 3 | 26398 | |
| 3-07 | Heater Operation Status | 12609311 | HeaterStatus | _103 | _104 | 3 | 26399 | |
| 3-07 | Ventilation Mode (setting) | 58746656 | VentilationModeCommand | _103 | _104 | 14 | 26400 | |
| 3-07 | Ventilation Mode (status) | 54552353 | VentilationModeStatus | _103 | _104 | 13 | 26401 | |
| 3-07 | Ventilation Amount (setting) | 58746658 | VentilationAmountCommand | _103 | _104 | 14 | 26402 | |
| 3-07 | Ventilation Amount (status) | 54552355 | VentilationAmountStatus | _103 | _104 | 13 | 26403 | |
| 3-08 | ON/OFF (setting) | 16803841 | StartStopCommand | _104 | _105 | 4 | 26625 | set |
| 3-08 | ON/OFF (status) | 12609538 | StartStopStatus | _104 | _105 | 3 | 26626 | Fb |
| 3-08 | Alarm Sign | 12609539 | Alarm | _104 | _105 | 3 | 26627 | |
| 3-08 | Error Code | 54552580 | MalfunctionCode | _104 | _105 | 13 | 26628 | |
| 3-08 | Operation Mode (setting) | 58746885 | AirConModeCommand | _104 | _105 | 14 | 26629 | set |
| 3-08 | Operation Mode (status) | 54552582 | AirConModeStatus | _104 | _105 | 13 | 26630 | Fb |
| 3-08 | Airflow Rate (setting) | 58746887 | AirFlowRateCommand | _104 | _105 | 14 | 26631 | set |
| 3-08 | Airflow Rate (status) | 54552584 | AirFlowRateStatus | _104 | _105 | 13 | 26632 | Fb |
| 3-08 | Measured Room Temperature | 26633 | RoomTemp | _104 | _105 | 0 | 26633 | |
| 3-08 | Set Room Temperature | 8415242 | TempAdjust | _104 | _105 | 2 | 26634 | set |
| 3-08 | Filer Limit Sign | 12609547 | FilterSign | _104 | _105 | 3 | 26635 | |
| 3-08 | Filter Limit Sign Reset | 20998156 | FilterSignReset | _104 | _105 | 5 | 26636 | |
| 3-08 | Remote Control Operation (ON/OFF) | 20998157 | RemoteControlStart | _104 | _105 | 5 | 26637 | |
| 3-08 | Remote Control Operation (Operation Mode) | 20998158 | RemoteControlAirConModeSet | _104 | _105 | 5 | 26638 | |
| 3-08 | Remote Control Operation (Set Temperature) | 20998160 | RemoteControlTempAdjust | _104 | _105 | 5 | 26640 | |
| 3-08 | Remote Control Operation (Sub Group Address Control Reject) | 20998161 | CL_Rejection | _104 | _105 | 5 | 26641 | |
| 3-08 | Elec Total Power | 96495635 | ElecTotalPower | _104 | _105 | 23 | 26643 | |
| 3-08 | Communication Status | 12609556 | CommunicationStatus | _104 | _105 | 3 | 26644 | |
| 3-08 | System Forced OFF | 20998165 | SystemForcedOff | _104 | _105 | 5 | 26645 | |
| 3-08 | Air Direction (setting) | 8415254 | AirDirectionCommand | _104 | _105 | 2 | 26646 | |
| 3-08 | Air Direction (status) | 26647 | AirDirectionStatus | _104 | _105 | 0 | 26647 | |
| 3-08 | Forced Thermostat OFF (setting) | 16803864 | ForcedThermoOFFCommand | _104 | _105 | 4 | 26648 | |
| 3-08 | Forced Thermostat OFF (status) | 12609561 | ForcedThermoOFFStatus | _104 | _105 | 3 | 26649 | |
| 3-08 | Energy Efficiency Command (setting) | 16803866 | EnergyEfficiencyCommand | _104 | _105 | 4 | 26650 | |
| 3-08 | Energy Efficiency Command (status) | 12609563 | EnergyEfficiencyStatus | _104 | _105 | 3 | 26651 | |
| 3-08 | Thermostat Status | 12609564 | ThermoStatus | _104 | _105 | 3 | 26652 | |
| 3-08 | Compressor Status | 12609565 | CompressorStatus | _104 | _105 | 3 | 26653 | |
| 3-08 | Indoor Fan Status | 12609566 | IndoorFanStatus | _104 | _105 | 3 | 26654 | |
| 3-08 | Heater Operation Status | 12609567 | HeaterStatus | _104 | _105 | 3 | 26655 | |
| 3-08 | Ventilation Mode (setting) | 58746912 | VentilationModeCommand | _104 | _105 | 14 | 26656 | |
| 3-08 | Ventilation Mode (status) | 54552609 | VentilationModeStatus | _104 | _105 | 13 | 26657 | |
| 3-08 | Ventilation Amount (setting) | 58746914 | VentilationAmountCommand | _104 | _105 | 14 | 26658 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 3-08 | Ventilation Amount (status) | 54552611 | VentilationAmountStatus | _104 | _105 | 13 | 26659 | |
| 3-09 | ON/OFF (setting) | 16804097 | StartStopCommand | _105 | _106 | 4 | 26881 | set |
| 3-09 | ON/OFF (status) | 12609794 | StartStopStatus | _105 | _106 | 3 | 26882 | Fb |
| 3-09 | Alarm Sign | 12609795 | Alarm | _105 | _106 | 3 | 26883 | |
| 3-09 | Error Code | 54552836 | MalfunctionCode | _105 | _106 | 13 | 26884 | |
| 3-09 | Operation Mode (setting) | 58747141 | AirConModeCommand | _105 | _106 | 14 | 26885 | set |
| 3-09 | Operation Mode (status) | 54552838 | AirConModeStatus | _105 | _106 | 13 | 26886 | Fb |
| 3-09 | Airflow Rate (setting) | 58747143 | AirFlowRateCommand | _105 | _106 | 14 | 26887 | set |
| 3-09 | Airflow Rate (status) | 54552840 | AirFlowRateStatus | _105 | _106 | 13 | 26888 | Fb |
| 3-09 | Measured Room Temperature | 26889 | RoomTemp | _105 | _106 | 0 | 26889 | |
| 3-09 | Set Room Temperature | 8415498 | TempAdjust | _105 | _106 | 2 | 26890 | set |
| 3-09 | Filer Limit Sign | 12609803 | FilterSign | _105 | _106 | 3 | 26891 | |
| 3-09 | Filter Limit Sign Reset | 20998412 | FilterSignReset | _105 | _106 | 5 | 26892 | |
| 3-09 | Remote Control Operation (ON/OFF) | 20998413 | RemoteControlStart | _105 | _106 | 5 | 26893 | |
| 3-09 | Remote Control Operation (Operation Mode) | 20998414 | RemoteControlAirConModeSet | _105 | _106 | 5 | 26894 | |
| 3-09 | Remote Control Operation (Set Temperature) | 20998416 | RemoteControlTempAdjust | _105 | _106 | 5 | 26896 | |
| 3-09 | Remote Control Operation (Sub Group Address Control Reject) | 20998417 | CL_Rejection | _105 | _106 | 5 | 26897 | |
| 3-09 | Elec Total Power | 96495891 | ElecTotalPower | _105 | _106 | 23 | 26899 | |
| 3-09 | Communication Status | 12609812 | CommunicationStatus | _105 | _106 | 3 | 26900 | |
| 3-09 | System Forced OFF | 20998421 | SystemForcedOff | _105 | _106 | 5 | 26901 | |
| 3-09 | Air Direction (setting) | 8415510 | AirDirectionCommand | _105 | _106 | 2 | 26902 | |
| 3-09 | Air Direction (status) | 26903 | AirDirectionStatus | _105 | _106 | 0 | 26903 | |
| 3-09 | Forced Thermostat OFF (setting) | 16804120 | ForcedThermoOFFCommand | _105 | _106 | 4 | 26904 | |
| 3-09 | Forced Thermostat OFF (status) | 12609817 | ForcedThermoOFFStatus | _105 | _106 | 3 | 26905 | |
| 3-09 | Energy Efficiency Command (setting) | 16804122 | EnergyEfficiencyCommand | _105 | _106 | 4 | 26906 | |
| 3-09 | Energy Efficiency Command (status) | 12609819 | EnergyEfficiencyStatus | _105 | _106 | 3 | 26907 | |
| 3-09 | Thermostat Status | 12609820 | ThermoStatus | _105 | _106 | 3 | 26908 | |
| 3-09 | Compressor Status | 12609821 | CompressorStatus | _105 | _106 | 3 | 26909 | |
| 3-09 | Indoor Fan Status | 12609822 | IndoorFanStatus | _105 | _106 | 3 | 26910 | |
| 3-09 | Heater Operation Status | 12609823 | HeaterStatus | _105 | _106 | 3 | 26911 | |
| 3-09 | Ventilation Mode (setting) | 58747168 | VentilationModeCommand | _105 | _106 | 14 | 26912 | |
| 3-09 | Ventilation Mode (status) | 54552865 | VentilationModeStatus | _105 | _106 | 13 | 26913 | |
| 3-09 | Ventilation Amount (setting) | 58747170 | VentilationAmountCommand | _105 | _106 | 14 | 26914 | |
| 3-09 | Ventilation Amount (status) | 54552867 | VentilationAmountStatus | _105 | _106 | 13 | 26915 | |
| 3-10 | ON/OFF (setting) | 16804353 | StartStopCommand | _106 | _107 | 4 | 27137 | set |
| 3-10 | ON/OFF (status) | 12610050 | StartStopStatus | _106 | _107 | 3 | 27138 | Fb |
| 3-10 | Alarm Sign | 12610051 | Alarm | _106 | _107 | 3 | 27139 | |
| 3-10 | Error Code | 54553092 | MalfunctionCode | _106 | _107 | 13 | 27140 | |
| 3-10 | Operation Mode (setting) | 58747397 | AirConModeCommand | _106 | _107 | 14 | 27141 | set |
| 3-10 | Operation Mode (status) | 54553094 | AirConModeStatus | _106 | _107 | 13 | 27142 | Fb |
| 3-10 | Airflow Rate (setting) | 58747399 | AirFlowRateCommand | _106 | _107 | 14 | 27143 | set |
| 3-10 | Airflow Rate (status) | 54553096 | AirFlowRateStatus | _106 | _107 | 13 | 27144 | Fb |
| 3-10 | Measured Room Temperature | 27145 | RoomTemp | _106 | _107 | 0 | 27145 | |
| 3-10 | Set Room Temperature | 8415754 | TempAdjust | _106 | _107 | 2 | 27146 | set |
| 3-10 | Filer Limit Sign | 12610059 | FilterSign | _106 | _107 | 3 | 27147 | |
| 3-10 | Filter Limit Sign Reset | 20998668 | FilterSignReset | _106 | _107 | 5 | 27148 | |
| 3-10 | Remote Control Operation (ON/OFF) | 20998669 | RemoteControlStart | _106 | _107 | 5 | 27149 | |
| 3-10 | Remote Control Operation (Operation Mode) | 20998670 | RemoteControlAirConModeSet | _106 | _107 | 5 | 27150 | |
| 3-10 | Remote Control Operation (Set Temperature) | 20998672 | RemoteControlTempAdjust | _106 | _107 | 5 | 27152 | |
| 3-10 | Remote Control Operation (Sub Group Address Control Reject) | 20998673 | CL_Rejection | _106 | _107 | 5 | 27153 | |
| 3-10 | Elec Total Power | 96496147 | ElecTotalPower | _106 | _107 | 23 | 27155 | |
| 3-10 | Communication Status | 12610068 | CommunicationStatus | _106 | _107 | 3 | 27156 | |
| 3-10 | System Forced OFF | 20998677 | SystemForcedOff | _106 | _107 | 5 | 27157 | |
| 3-10 | Air Direction (setting) | 8415766 | AirDirectionCommand | _106 | _107 | 2 | 27158 | |
| 3-10 | Air Direction (status) | 27159 | AirDirectionStatus | _106 | _107 | 0 | 27159 | |
| 3-10 | Forced Thermostat OFF (setting) | 16804376 | ForcedThermoOFFCommand | _106 | _107 | 4 | 27160 | |
| 3-10 | Forced Thermostat OFF (status) | 12610073 | ForcedThermoOFFStatus | _106 | _107 | 3 | 27161 | |
| 3-10 | Energy Efficiency Command (setting) | 16804378 | EnergyEfficiencyCommand | _106 | _107 | 4 | 27162 | |
| 3-10 | Energy Efficiency Command (status) | 12610075 | EnergyEfficiencyStatus | _106 | _107 | 3 | 27163 | |
| 3-10 | Thermostat Status | 12610076 | ThermoStatus | _106 | _107 | 3 | 27164 | |
| 3-10 | Compressor Status | 12610077 | CompressorStatus | _106 | _107 | 3 | 27165 | |
| 3-10 | Indoor Fan Status | 12610078 | IndoorFanStatus | _106 | _107 | 3 | 27166 | |
| 3-10 | Heater Operation Status | 12610079 | HeaterStatus | _106 | _107 | 3 | 27167 | |
| 3-10 | Ventilation Mode (setting) | 58747424 | VentilationModeCommand | _106 | _107 | 14 | 27168 | |
| 3-10 | Ventilation Mode (status) | 54553121 | VentilationModeStatus | _106 | _107 | 13 | 27169 | |
| 3-10 | Ventilation Amount (setting) | 58747426 | VentilationAmountCommand | _106 | _107 | 14 | 27170 | |
| 3-10 | Ventilation Amount (status) | 54553123 | VentilationAmountStatus | _106 | _107 | 13 | 27171 | |
| 3-11 | ON/OFF (setting) | 16804609 | StartStopCommand | _107 | _108 | 4 | 27393 | set |
| 3-11 | ON/OFF (status) | 12610306 | StartStopStatus | _107 | _108 | 3 | 27394 | Fb |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 3-11 | Alarm Sign | 12610307 | Alarm | _107 | _108 | 3 | 27395 | |
| 3-11 | Error Code | 54553348 | MalfunctionCode | _107 | _108 | 13 | 27396 | |
| 3-11 | Operation Mode (setting) | 58747653 | AirConModeCommand | _107 | _108 | 14 | 27397 | set |
| 3-11 | Operation Mode (status) | 54553350 | AirConModeStatus | _107 | _108 | 13 | 27398 | Fb |
| 3-11 | Airflow Rate (setting) | 58747655 | AirFlowRateCommand | _107 | _108 | 14 | 27399 | set |
| 3-11 | Airflow Rate (status) | 54553352 | AirFlowRateStatus | _107 | _108 | 13 | 27400 | Fb |
| 3-11 | Measured Room Temperature | 27401 | RoomTemp | _107 | _108 | 0 | 27401 | |
| 3-11 | Set Room Temperature | 8416010 | TempAdjust | _107 | _108 | 2 | 27402 | set |
| 3-11 | Filer Limit Sign | 12610315 | FilterSign | _107 | _108 | 3 | 27403 | |
| 3-11 | Filter Limit Sign Reset | 20998924 | FilterSignReset | _107 | _108 | 5 | 27404 | |
| 3-11 | Remote Control Operation (ON/OFF) | 20998925 | RemoteControlStart | _107 | _108 | 5 | 27405 | |
| 3-11 | Remote Control Operation (Operation Mode) | 20998926 | RemoteControlAirConModeSet | _107 | _108 | 5 | 27406 | |
| 3-11 | Remote Control Operation (Set Temperature) | 20998928 | RemoteControlTempAdjust | _107 | _108 | 5 | 27408 | |
| 3-11 | Remote Control Operation (Sub Group Address Control Reject) | 20998929 | CL_Rejection | _107 | _108 | 5 | 27409 | |
| 3-11 | Elec Total Power | 96496403 | ElecTotalPower | _107 | _108 | 23 | 27411 | |
| 3-11 | Communication Status | 12610324 | CommunicationStatus | _107 | _108 | 3 | 27412 | |
| 3-11 | System Forced OFF | 20998933 | SystemForcedOff | _107 | _108 | 5 | 27413 | |
| 3-11 | Air Direction (setting) | 8416022 | AirDirectionCommand | _107 | _108 | 2 | 27414 | |
| 3-11 | Air Direction (status) | 27415 | AirDirectionStatus | _107 | _108 | 0 | 27415 | |
| 3-11 | Forced Thermostat OFF (setting) | 16804632 | ForcedThermoOFFCommand | _107 | _108 | 4 | 27416 | |
| 3-11 | Forced Thermostat OFF (status) | 12610329 | ForcedThermoOFFStatus | _107 | _108 | 3 | 27417 | |
| 3-11 | Energy Efficiency Command (setting) | 16804634 | EnergyEfficiencyCommand | _107 | _108 | 4 | 27418 | |
| 3-11 | Energy Efficiency Command (status) | 12610331 | EnergyEfficiencyStatus | _107 | _108 | 3 | 27419 | |
| 3-11 | Thermostat Status | 12610332 | ThermoStatus | _107 | _108 | 3 | 27420 | |
| 3-11 | Compressor Status | 12610333 | CompressorStatus | _107 | _108 | 3 | 27421 | |
| 3-11 | Indoor Fan Status | 12610334 | IndoorFanStatus | _107 | _108 | 3 | 27422 | |
| 3-11 | Heater Operation Status | 12610335 | HeaterStatus | _107 | _108 | 3 | 27423 | |
| 3-11 | Ventilation Mode (setting) | 58747680 | VentilationModeCommand | _107 | _108 | 14 | 27424 | |
| 3-11 | Ventilation Mode (status) | 54553377 | VentilationModeStatus | _107 | _108 | 13 | 27425 | |
| 3-11 | Ventilation Amount (setting) | 58747682 | VentilationAmountCommand | _107 | _108 | 14 | 27426 | |
| 3-11 | Ventilation Amount (status) | 54553379 | VentilationAmountStatus | _107 | _108 | 13 | 27427 | |
| 3-12 | ON/OFF (setting) | 16804865 | StartStopCommand | _108 | _109 | 4 | 27649 | set |
| 3-12 | ON/OFF (status) | 12610562 | StartStopStatus | _108 | _109 | 3 | 27650 | Fb |
| 3-12 | Alarm Sign | 12610563 | Alarm | _108 | _109 | 3 | 27651 | |
| 3-12 | Error Code | 54553604 | MalfunctionCode | _108 | _109 | 13 | 27652 | |
| 3-12 | Operation Mode (setting) | 58747909 | AirConModeCommand | _108 | _109 | 14 | 27653 | set |
| 3-12 | Operation Mode (status) | 54553606 | AirConModeStatus | _108 | _109 | 13 | 27654 | Fb |
| 3-12 | Airflow Rate (setting) | 58747911 | AirFlowRateCommand | _108 | _109 | 14 | 27655 | set |
| 3-12 | Airflow Rate (status) | 54553608 | AirFlowRateStatus | _108 | _109 | 13 | 27656 | Fb |
| 3-12 | Measured Room Temperature | 27657 | RoomTemp | _108 | _109 | 0 | 27657 | |
| 3-12 | Set Room Temperature | 8416266 | TempAdjust | _108 | _109 | 2 | 27658 | set |
| 3-12 | Filer Limit Sign | 12610571 | FilterSign | _108 | _109 | 3 | 27659 | |
| 3-12 | Filter Limit Sign Reset | 20999180 | FilterSignReset | _108 | _109 | 5 | 27660 | |
| 3-12 | Remote Control Operation (ON/OFF) | 20999181 | RemoteControlStart | _108 | _109 | 5 | 27661 | |
| 3-12 | Remote Control Operation (Operation Mode) | 20999182 | RemoteControlAirConModeSet | _108 | _109 | 5 | 27662 | |
| 3-12 | Remote Control Operation (Set Temperature) | 20999184 | RemoteControlTempAdjust | _108 | _109 | 5 | 27664 | |
| 3-12 | Remote Control Operation (Sub Group Address Control Reject) | 20999185 | CL_Rejection | _108 | _109 | 5 | 27665 | |
| 3-12 | Elec Total Power | 96496659 | ElecTotalPower | _108 | _109 | 23 | 27667 | |
| 3-12 | Communication Status | 12610580 | CommunicationStatus | _108 | _109 | 3 | 27668 | |
| 3-12 | System Forced OFF | 20999189 | SystemForcedOff | _108 | _109 | 5 | 27669 | |
| 3-12 | Air Direction (setting) | 8416278 | AirDirectionCommand | _108 | _109 | 2 | 27670 | |
| 3-12 | Air Direction (status) | 27671 | AirDirectionStatus | _108 | _109 | 0 | 27671 | |
| 3-12 | Forced Thermostat OFF (setting) | 16804888 | ForcedThermoOFFCommand | _108 | _109 | 4 | 27672 | |
| 3-12 | Forced Thermostat OFF (status) | 12610585 | ForcedThermoOFFStatus | _108 | _109 | 3 | 27673 | |
| 3-12 | Energy Efficiency Command (setting) | 16804890 | EnergyEfficiencyCommand | _108 | _109 | 4 | 27674 | |
| 3-12 | Energy Efficiency Command (status) | 12610587 | EnergyEfficiencyStatus | _108 | _109 | 3 | 27675 | |
| 3-12 | Thermostat Status | 12610588 | ThermoStatus | _108 | _109 | 3 | 27676 | |
| 3-12 | Compressor Status | 12610589 | CompressorStatus | _108 | _109 | 3 | 27677 | |
| 3-12 | Indoor Fan Status | 12610590 | IndoorFanStatus | _108 | _109 | 3 | 27678 | |
| 3-12 | Heater Operation Status | 12610591 | HeaterStatus | _108 | _109 | 3 | 27679 | |
| 3-12 | Ventilation Mode (setting) | 58747936 | VentilationModeCommand | _108 | _109 | 14 | 27680 | |
| 3-12 | Ventilation Mode (status) | 54553633 | VentilationModeStatus | _108 | _109 | 13 | 27681 | |
| 3-12 | Ventilation Amount (setting) | 58747938 | VentilationAmountCommand | _108 | _109 | 14 | 27682 | |
| 3-12 | Ventilation Amount (status) | 54553635 | VentilationAmountStatus | _108 | _109 | 13 | 27683 | |
| 3-13 | ON/OFF (setting) | 16805121 | StartStopCommand | _109 | _110 | 4 | 27905 | set |
| 3-13 | ON/OFF (status) | 12610818 | StartStopStatus | _109 | _110 | 3 | 27906 | Fb |
| 3-13 | Alarm Sign | 12610819 | Alarm | _109 | _110 | 3 | 27907 | |
| 3-13 | Error Code | 54553860 | MalfunctionCode | _109 | _110 | 13 | 27908 | |
| 3-13 | Operation Mode (setting) | 58748165 | AirConModeCommand | _109 | _110 | 14 | 27909 | set |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 3-13 | Operation Mode (status) | 54553862 | AirConModeStatus | _109 | _110 | 13 | 27910 | Fb |
| 3-13 | Airflow Rate (setting) | 58748167 | AirFlowRateCommand | _109 | _110 | 14 | 27911 | set |
| 3-13 | Airflow Rate (status) | 54553864 | AirFlowRateStatus | _109 | _110 | 13 | 27912 | Fb |
| 3-13 | Measured Room Temperature | 27913 | RoomTemp | _109 | _110 | 0 | 27913 | |
| 3-13 | Set Room Temperature | 8416522 | TempAdjust | _109 | _110 | 2 | 27914 | set |
| 3-13 | Filer Limit Sign | 12610827 | FilterSign | _109 | _110 | 3 | 27915 | |
| 3-13 | Filter Limit Sign Reset | 20999436 | FilterSignReset | _109 | _110 | 5 | 27916 | |
| 3-13 | Remote Control Operation (ON/OFF) | 20999437 | RemoteControlStart | _109 | _110 | 5 | 27917 | |
| 3-13 | Remote Control Operation (Operation Mode) | 20999438 | RemoteControlAirConModeSet | _109 | _110 | 5 | 27918 | |
| 3-13 | Remote Control Operation (Set Temperature) | 20999440 | RemoteControlTempAdjust | _109 | _110 | 5 | 27920 | |
| 3-13 | Remote Control Operation (Sub Group Address Control Reject) | 20999441 | CL_Rejection | _109 | _110 | 5 | 27921 | |
| 3-13 | Elec Total Power | 96496915 | ElecTotalPower | _109 | _110 | 23 | 27923 | |
| 3-13 | Communication Status | 12610836 | CommunicationStatus | _109 | _110 | 3 | 27924 | |
| 3-13 | System Forced OFF | 20999445 | SystemForcedOff | _109 | _110 | 5 | 27925 | |
| 3-13 | Air Direction (setting) | 8416534 | AirDirectionCommand | _109 | _110 | 2 | 27926 | |
| 3-13 | Air Direction (status) | 27927 | AirDirectionStatus | _109 | _110 | 0 | 27927 | |
| 3-13 | Forced Thermostat OFF (setting) | 16805144 | ForcedThermoOFFCommand | _109 | _110 | 4 | 27928 | |
| 3-13 | Forced Thermostat OFF (status) | 12610841 | ForcedThermoOFFStatus | _109 | _110 | 3 | 27929 | |
| 3-13 | Energy Efficiency Command (setting) | 16805146 | EnergyEfficiencyCommand | _109 | _110 | 4 | 27930 | |
| 3-13 | Energy Efficiency Command (status) | 12610843 | EnergyEfficiencyStatus | _109 | _110 | 3 | 27931 | |
| 3-13 | Thermostat Status | 12610844 | ThermoStatus | _109 | _110 | 3 | 27932 | |
| 3-13 | Compressor Status | 12610845 | CompressorStatus | _109 | _110 | 3 | 27933 | |
| 3-13 | Indoor Fan Status | 12610846 | IndoorFanStatus | _109 | _110 | 3 | 27934 | |
| 3-13 | Heater Operation Status | 12610847 | HeaterStatus | _109 | _110 | 3 | 27935 | |
| 3-13 | Ventilation Mode (setting) | 58748192 | VentilationModeCommand | _109 | _110 | 14 | 27936 | |
| 3-13 | Ventilation Mode (status) | 54553889 | VentilationModeStatus | _109 | _110 | 13 | 27937 | |
| 3-13 | Ventilation Amount (setting) | 58748194 | VentilationAmountCommand | _109 | _110 | 14 | 27938 | |
| 3-13 | Ventilation Amount (status) | 54553891 | VentilationAmountStatus | _109 | _110 | 13 | 27939 | |
| 3-14 | ON/OFF (setting) | 16805377 | StartStopCommand | _110 | _111 | 4 | 28161 | set |
| 3-14 | ON/OFF (status) | 12611074 | StartStopStatus | _110 | _111 | 3 | 28162 | Fb |
| 3-14 | Alarm Sign | 12611075 | Alarm | _110 | _111 | 3 | 28163 | |
| 3-14 | Error Code | 54554116 | MalfunctionCode | _110 | _111 | 13 | 28164 | |
| 3-14 | Operation Mode (setting) | 58748421 | AirConModeCommand | _110 | _111 | 14 | 28165 | set |
| 3-14 | Operation Mode (status) | 54554118 | AirConModeStatus | _110 | _111 | 13 | 28166 | Fb |
| 3-14 | Airflow Rate (setting) | 58748423 | AirFlowRateCommand | _110 | _111 | 14 | 28167 | set |
| 3-14 | Airflow Rate (status) | 54554120 | AirFlowRateStatus | _110 | _111 | 13 | 28168 | Fb |
| 3-14 | Measured Room Temperature | 28169 | RoomTemp | _110 | _111 | 0 | 28169 | |
| 3-14 | Set Room Temperature | 8416778 | TempAdjust | _110 | _111 | 2 | 28170 | set |
| 3-14 | Filer Limit Sign | 12611083 | FilterSign | _110 | _111 | 3 | 28171 | |
| 3-14 | Filter Limit Sign Reset | 20999692 | FilterSignReset | _110 | _111 | 5 | 28172 | |
| 3-14 | Remote Control Operation (ON/OFF) | 20999693 | RemoteControlStart | _110 | _111 | 5 | 28173 | |
| 3-14 | Remote Control Operation (Operation Mode) | 20999694 | RemoteControlAirConModeSet | _110 | _111 | 5 | 28174 | |
| 3-14 | Remote Control Operation (Set Temperature) | 20999696 | RemoteControlTempAdjust | _110 | _111 | 5 | 28176 | |
| 3-14 | Remote Control Operation (Sub Group Address Control Reject) | 20999697 | CL_Rejection | _110 | _111 | 5 | 28177 | |
| 3-14 | Elec Total Power | 96497171 | ElecTotalPower | _110 | _111 | 23 | 28179 | |
| 3-14 | Communication Status | 12611092 | CommunicationStatus | _110 | _111 | 3 | 28180 | |
| 3-14 | System Forced OFF | 20999701 | SystemForcedOff | _110 | _111 | 5 | 28181 | |
| 3-14 | Air Direction (setting) | 8416790 | AirDirectionCommand | _110 | _111 | 2 | 28182 | |
| 3-14 | Air Direction (status) | 28183 | AirDirectionStatus | _110 | _111 | 0 | 28183 | |
| 3-14 | Forced Thermostat OFF (setting) | 16805400 | ForcedThermoOFFCommand | _110 | _111 | 4 | 28184 | |
| 3-14 | Forced Thermostat OFF (status) | 12611097 | ForcedThermoOFFStatus | _110 | _111 | 3 | 28185 | |
| 3-14 | Energy Efficiency Command (setting) | 16805402 | EnergyEfficiencyCommand | _110 | _111 | 4 | 28186 | |
| 3-14 | Energy Efficiency Command (status) | 12611099 | EnergyEfficiencyStatus | _110 | _111 | 3 | 28187 | |
| 3-14 | Thermostat Status | 12611100 | ThermoStatus | _110 | _111 | 3 | 28188 | |
| 3-14 | Compressor Status | 12611101 | CompressorStatus | _110 | _111 | 3 | 28189 | |
| 3-14 | Indoor Fan Status | 12611102 | IndoorFanStatus | _110 | _111 | 3 | 28190 | |
| 3-14 | Heater Operation Status | 12611103 | HeaterStatus | _110 | _111 | 3 | 28191 | |
| 3-14 | Ventilation Mode (setting) | 58748448 | VentilationModeCommand | _110 | _111 | 14 | 28192 | |
| 3-14 | Ventilation Mode (status) | 54554145 | VentilationModeStatus | _110 | _111 | 13 | 28193 | |
| 3-14 | Ventilation Amount (setting) | 58748450 | VentilationAmountCommand | _110 | _111 | 14 | 28194 | |
| 3-14 | Ventilation Amount (status) | 54554147 | VentilationAmountStatus | _110 | _111 | 13 | 28195 | |
| 3-15 | ON/OFF (setting) | 16805633 | StartStopCommand | _111 | _112 | 4 | 28417 | set |
| 3-15 | ON/OFF (status) | 12611330 | StartStopStatus | _111 | _112 | 3 | 28418 | Fb |
| 3-15 | Alarm Sign | 12611331 | Alarm | _111 | _112 | 3 | 28419 | |
| 3-15 | Error Code | 54554372 | MalfunctionCode | _111 | _112 | 13 | 28420 | |
| 3-15 | Operation Mode (setting) | 58748677 | AirConModeCommand | _111 | _112 | 14 | 28421 | set |
| 3-15 | Operation Mode (status) | 54554374 | AirConModeStatus | _111 | _112 | 13 | 28422 | Fb |
| 3-15 | Airflow Rate (setting) | 58748679 | AirFlowRateCommand | _111 | _112 | 14 | 28423 | set |
| 3-15 | Airflow Rate (status) | 54554376 | AirFlowRateStatus | _111 | _112 | 13 | 28424 | Fb |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 3-15 | Measured Room Temperature | 28425 | RoomTemp | _111 | _112 | 0 | 28425 | |
| 3-15 | Set Room Temperature | 8417034 | TempAdjust | _111 | _112 | 2 | 28426 | set |
| 3-15 | Filer Limit Sign | 12611339 | FilterSign | _111 | _112 | 3 | 28427 | |
| 3-15 | Filter Limit Sign Reset | 20999948 | FilterSignReset | _111 | _112 | 5 | 28428 | |
| 3-15 | Remote Control Operation (ON/OFF) | 20999949 | RemoteControlStart | _111 | _112 | 5 | 28429 | |
| 3-15 | Remote Control Operation (Operation Mode) | 20999950 | RemoteControlAirConModeSet | _111 | _112 | 5 | 28430 | |
| 3-15 | Remote Control Operation (Set Temperature) | 20999952 | RemoteControlTempAdjust | _111 | _112 | 5 | 28432 | |
| 3-15 | Remote Control Operation (Sub Group Address Control Reject) | 20999953 | CL_Rejection | _111 | _112 | 5 | 28433 | |
| 3-15 | Elec Total Power | 96497427 | ElecTotalPower | _111 | _112 | 23 | 28435 | |
| 3-15 | Communication Status | 12611348 | CommunicationStatus | _111 | _112 | 3 | 28436 | |
| 3-15 | System Forced OFF | 20999957 | SystemForcedOff | _111 | _112 | 5 | 28437 | |
| 3-15 | Air Direction (setting) | 8417046 | AirDirectionCommand | _111 | _112 | 2 | 28438 | |
| 3-15 | Air Direction (status) | 28439 | AirDirectionStatus | _111 | _112 | 0 | 28439 | |
| 3-15 | Forced Thermostat OFF (setting) | 16805656 | ForcedThermoOFFCommand | _111 | _112 | 4 | 28440 | |
| 3-15 | Forced Thermostat OFF (status) | 12611353 | ForcedThermoOFFStatus | _111 | _112 | 3 | 28441 | |
| 3-15 | Energy Efficiency Command (setting) | 16805658 | EnergyEfficiencyCommand | _111 | _112 | 4 | 28442 | |
| 3-15 | Energy Efficiency Command (status) | 12611355 | EnergyEfficiencyStatus | _111 | _112 | 3 | 28443 | |
| 3-15 | Thermostat Status | 12611356 | ThermoStatus | _111 | _112 | 3 | 28444 | |
| 3-15 | Compressor Status | 12611357 | CompressorStatus | _111 | _112 | 3 | 28445 | |
| 3-15 | Indoor Fan Status | 12611358 | IndoorFanStatus | _111 | _112 | 3 | 28446 | |
| 3-15 | Heater Operation Status | 12611359 | HeaterStatus | _111 | _112 | 3 | 28447 | |
| 3-15 | Ventilation Mode (setting) | 58748704 | VentilationModeCommand | _111 | _112 | 14 | 28448 | |
| 3-15 | Ventilation Mode (status) | 54554401 | VentilationModeStatus | _111 | _112 | 13 | 28449 | |
| 3-15 | Ventilation Amount (setting) | 58748706 | VentilationAmountCommand | _111 | _112 | 14 | 28450 | |
| 3-15 | Ventilation Amount (status) | 54554403 | VentilationAmountStatus | _111 | _112 | 13 | 28451 | |
| 4-00 | ON/OFF (setting) | 16805889 | StartStopCommand | _112 | _113 | 4 | 28673 | set |
| 4-00 | ON/OFF (status) | 12611586 | StartStopStatus | _112 | _113 | 3 | 28674 | Fb |
| 4-00 | Alarm Sign | 12611587 | Alarm | _112 | _113 | 3 | 28675 | |
| 4-00 | Error Code | 54554628 | MalfunctionCode | _112 | _113 | 13 | 28676 | |
| 4-00 | Operation Mode (setting) | 58748933 | AirConModeCommand | _112 | _113 | 14 | 28677 | set |
| 4-00 | Operation Mode (status) | 54554630 | AirConModeStatus | _112 | _113 | 13 | 28678 | Fb |
| 4-00 | Airflow Rate (setting) | 58748935 | AirFlowRateCommand | _112 | _113 | 14 | 28679 | set |
| 4-00 | Airflow Rate (status) | 54554632 | AirFlowRateStatus | _112 | _113 | 13 | 28680 | Fb |
| 4-00 | Measured Room Temperature | 28681 | RoomTemp | _112 | _113 | 0 | 28681 | |
| 4-00 | Set Room Temperature | 8417290 | TempAdjust | _112 | _113 | 2 | 28682 | set |
| 4-00 | Filer Limit Sign | 12611595 | FilterSign | _112 | _113 | 3 | 28683 | |
| 4-00 | Filter Limit Sign Reset | 21000204 | FilterSignReset | _112 | _113 | 5 | 28684 | |
| 4-00 | Remote Control Operation (ON/OFF) | 21000205 | RemoteControlStart | _112 | _113 | 5 | 28685 | |
| 4-00 | Remote Control Operation (Operation Mode) | 21000206 | RemoteControlAirConModeSet | _112 | _113 | 5 | 28686 | |
| 4-00 | Remote Control Operation (Set Temperature) | 21000208 | RemoteControlTempAdjust | _112 | _113 | 5 | 28688 | |
| 4-00 | Remote Control Operation (Sub Group Address Control Reject) | 21000209 | CL_Rejection | _112 | _113 | 5 | 28689 | |
| 4-00 | Elec Total Power | 96497683 | ElecTotalPower | _112 | _113 | 23 | 28691 | |
| 4-00 | Communication Status | 12611604 | CommunicationStatus | _112 | _113 | 3 | 28692 | |
| 4-00 | System Forced OFF | 21000213 | SystemForcedOff | _112 | _113 | 5 | 28693 | |
| 4-00 | Air Direction (setting) | 8417302 | AirDirectionCommand | _112 | _113 | 2 | 28694 | |
| 4-00 | Air Direction (status) | 28695 | AirDirectionStatus | _112 | _113 | 0 | 28695 | |
| 4-00 | Forced Thermostat OFF (setting) | 16805912 | ForcedThermoOFFCommand | _112 | _113 | 4 | 28696 | |
| 4-00 | Forced Thermostat OFF (status) | 12611609 | ForcedThermoOFFStatus | _112 | _113 | 3 | 28697 | |
| 4-00 | Energy Efficiency Command (setting) | 16805914 | EnergyEfficiencyCommand | _112 | _113 | 4 | 28698 | |
| 4-00 | Energy Efficiency Command (status) | 12611611 | EnergyEfficiencyStatus | _112 | _113 | 3 | 28699 | |
| 4-00 | Thermostat Status | 12611612 | ThermoStatus | _112 | _113 | 3 | 28700 | |
| 4-00 | Compressor Status | 12611613 | CompressorStatus | _112 | _113 | 3 | 28701 | |
| 4-00 | Indoor Fan Status | 12611614 | IndoorFanStatus | _112 | _113 | 3 | 28702 | |
| 4-00 | Heater Operation Status | 12611615 | HeaterStatus | _112 | _113 | 3 | 28703 | |
| 4-00 | Ventilation Mode (setting) | 58748960 | VentilationModeCommand | _112 | _113 | 14 | 28704 | |
| 4-00 | Ventilation Mode (status) | 54554657 | VentilationModeStatus | _112 | _113 | 13 | 28705 | |
| 4-00 | Ventilation Amount (setting) | 58748962 | VentilationAmountCommand | _112 | _113 | 14 | 28706 | |
| 4-00 | Ventilation Amount (status) | 54554659 | VentilationAmountStatus | _112 | _113 | 13 | 28707 | |
| 4-01 | ON/OFF (setting) | 16806145 | StartStopCommand | _113 | _114 | 4 | 28929 | set |
| 4-01 | ON/OFF (status) | 12611842 | StartStopStatus | _113 | _114 | 3 | 28930 | Fb |
| 4-01 | Alarm Sign | 12611843 | Alarm | _113 | _114 | 3 | 28931 | |
| 4-01 | Error Code | 54554884 | MalfunctionCode | _113 | _114 | 13 | 28932 | |
| 4-01 | Operation Mode (setting) | 58749189 | AirConModeCommand | _113 | _114 | 14 | 28933 | set |
| 4-01 | Operation Mode (status) | 54554886 | AirConModeStatus | _113 | _114 | 13 | 28934 | Fb |
| 4-01 | Airflow Rate (setting) | 58749191 | AirFlowRateCommand | _113 | _114 | 14 | 28935 | set |
| 4-01 | Airflow Rate (status) | 54554888 | AirFlowRateStatus | _113 | _114 | 13 | 28936 | Fb |
| 4-01 | Measured Room Temperature | 28937 | RoomTemp | _113 | _114 | 0 | 28937 | |
| 4-01 | Set Room Temperature | 8417546 | TempAdjust | _113 | _114 | 2 | 28938 | set |
| 4-01 | Filer Limit Sign | 12611851 | FilterSign | _113 | _114 | 3 | 28939 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 4-01 | Filter Limit Sign Reset | 21000460 | FilterSignReset | _113 | _114 | 5 | 28940 | |
| 4-01 | Remote Control Operation (ON/OFF) | 21000461 | RemoteControlStart | _113 | _114 | 5 | 28941 | |
| 4-01 | Remote Control Operation (Operation Mode) | 21000462 | RemoteControlAirConModeSet | _113 | _114 | 5 | 28942 | |
| 4-01 | Remote Control Operation (Set Temperature) | 21000464 | RemoteControlTempAdjust | _113 | _114 | 5 | 28944 | |
| 4-01 | Remote Control Operation (Sub Group Address Control Rejecti | 21000465 | CL_Rejection | _113 | _114 | 5 | 28945 | |
| 4-01 | Elec Total Power | 96497939 | ElecTotalPower | _113 | _114 | 23 | 28947 | |
| 4-01 | Communication Status | 12611860 | CommunicationStatus | _113 | _114 | 3 | 28948 | |
| 4-01 | System Forced OFF | 21000469 | SystemForcedOff | _113 | _114 | 5 | 28949 | |
| 4-01 | Air Direction (setting) | 8417558 | AirDirectionCommand | _113 | _114 | 2 | 28950 | |
| 4-01 | Air Direction (status) | 28951 | AirDirectionStatus | _113 | _114 | 0 | 28951 | |
| 4-01 | Forced Thermostat OFF (setting) | 16806168 | ForcedThermoOFFCommand | _113 | _114 | 4 | 28952 | |
| 4-01 | Forced Thermostat OFF (status) | 12611865 | ForcedThermoOFFStatus | _113 | _114 | 3 | 28953 | |
| 4-01 | Energy Efficiency Command (setting) | 16806170 | EnergyEfficiencyCommand | _113 | _114 | 4 | 28954 | |
| 4-01 | Energy Efficiency Command (status) | 12611867 | EnergyEfficiencyStatus | _113 | _114 | 3 | 28955 | |
| 4-01 | Thermostat Status | 12611868 | ThermoStatus | _113 | _114 | 3 | 28956 | |
| 4-01 | Compressor Status | 12611869 | CompressorStatus | _113 | _114 | 3 | 28957 | |
| 4-01 | Indoor Fan Status | 12611870 | IndoorFanStatus | _113 | _114 | 3 | 28958 | |
| 4-01 | Heater Operation Status | 12611871 | HeaterStatus | _113 | _114 | 3 | 28959 | |
| 4-01 | Ventilation Mode (setting) | 58749216 | VentilationModeCommand | _113 | _114 | 14 | 28960 | |
| 4-01 | Ventilation Mode (status) | 54554913 | VentilationModeStatus | _113 | _114 | 13 | 28961 | |
| 4-01 | Ventilation Amount (setting) | 58749218 | VentilationAmountCommand | _113 | _114 | 14 | 28962 | |
| 4-01 | Ventilation Amount (status) | 54554915 | VentilationAmountStatus | _113 | _114 | 13 | 28963 | |
| 4-02 | ON/OFF (setting) | 16806401 | StartStopCommand | _114 | _115 | 4 | 29185 | set |
| 4-02 | ON/OFF (status) | 12612098 | StartStopStatus | _114 | _115 | 3 | 29186 | Fb |
| 4-02 | Alarm Sign | 12612099 | Alarm | _114 | _115 | 3 | 29187 | |
| 4-02 | Error Code | 54555140 | MalfunctionCode | _114 | _115 | 13 | 29188 | |
| 4-02 | Operation Mode (setting) | 58749445 | AirConModeCommand | _114 | _115 | 14 | 29189 | set |
| 4-02 | Operation Mode (status) | 54555142 | AirConModeStatus | _114 | _115 | 13 | 29190 | Fb |
| 4-02 | Airflow Rate (setting) | 58749447 | AirFlowRateCommand | _114 | _115 | 14 | 29191 | set |
| 4-02 | Airflow Rate (status) | 54555144 | AirFlowRateStatus | _114 | _115 | 13 | 29192 | Fb |
| 4-02 | Measured Room Temperature | 29193 | RoomTemp | _114 | _115 | 0 | 29193 | |
| 4-02 | Set Room Temperature | 8417802 | TempAdjust | _114 | _115 | 2 | 29194 | set |
| 4-02 | Filer Limit Sign | 12612107 | FilterSign | _114 | _115 | 3 | 29195 | |
| 4-02 | Filter Limit Sign Reset | 21000716 | FilterSignReset | _114 | _115 | 5 | 29196 | |
| 4-02 | Remote Control Operation (ON/OFF) | 21000717 | RemoteControlStart | _114 | _115 | 5 | 29197 | |
| 4-02 | Remote Control Operation (Operation Mode) | 21000718 | RemoteControlAirConModeSet | _114 | _115 | 5 | 29198 | |
| 4-02 | Remote Control Operation (Set Temperature) | 21000720 | RemoteControlTempAdjust | _114 | _115 | 5 | 29200 | |
| 4-02 | Remote Control Operation (Sub Group Address Control Rejecti | 21000721 | CL_Rejection | _114 | _115 | 5 | 29201 | |
| 4-02 | Elec Total Power | 96498195 | ElecTotalPower | _114 | _115 | 23 | 29203 | |
| 4-02 | Communication Status | 12612116 | CommunicationStatus | _114 | _115 | 3 | 29204 | |
| 4-02 | System Forced OFF | 21000725 | SystemForcedOff | _114 | _115 | 5 | 29205 | |
| 4-02 | Air Direction (setting) | 8417814 | AirDirectionCommand | _114 | _115 | 2 | 29206 | |
| 4-02 | Air Direction (status) | 29207 | AirDirectionStatus | _114 | _115 | 0 | 29207 | |
| 4-02 | Forced Thermostat OFF (setting) | 16806424 | ForcedThermoOFFCommand | _114 | _115 | 4 | 29208 | |
| 4-02 | Forced Thermostat OFF (status) | 12612121 | ForcedThermoOFFStatus | _114 | _115 | 3 | 29209 | |
| 4-02 | Energy Efficiency Command (setting) | 16806426 | EnergyEfficiencyCommand | _114 | _115 | 4 | 29210 | |
| 4-02 | Energy Efficiency Command (status) | 12612123 | EnergyEfficiencyStatus | _114 | _115 | 3 | 29211 | |
| 4-02 | Thermostat Status | 12612124 | ThermoStatus | _114 | _115 | 3 | 29212 | |
| 4-02 | Compressor Status | 12612125 | CompressorStatus | _114 | _115 | 3 | 29213 | |
| 4-02 | Indoor Fan Status | 12612126 | IndoorFanStatus | _114 | _115 | 3 | 29214 | |
| 4-02 | Heater Operation Status | 12612127 | HeaterStatus | _114 | _115 | 3 | 29215 | |
| 4-02 | Ventilation Mode (setting) | 58749472 | VentilationModeCommand | _114 | _115 | 14 | 29216 | |
| 4-02 | Ventilation Mode (status) | 54555169 | VentilationModeStatus | _114 | _115 | 13 | 29217 | |
| 4-02 | Ventilation Amount (setting) | 58749474 | VentilationAmountCommand | _114 | _115 | 14 | 29218 | |
| 4-02 | Ventilation Amount (status) | 54555171 | VentilationAmountStatus | _114 | _115 | 13 | 29219 | |
| 4-03 | ON/OFF (setting) | 16806657 | StartStopCommand | _115 | _116 | 4 | 29441 | set |
| 4-03 | ON/OFF (status) | 12612354 | StartStopStatus | _115 | _116 | 3 | 29442 | Fb |
| 4-03 | Alarm Sign | 12612355 | Alarm | _115 | _116 | 3 | 29443 | |
| 4-03 | Error Code | 54555396 | MalfunctionCode | _115 | _116 | 13 | 29444 | |
| 4-03 | Operation Mode (setting) | 58749701 | AirConModeCommand | _115 | _116 | 14 | 29445 | set |
| 4-03 | Operation Mode (status) | 54555398 | AirConModeStatus | _115 | _116 | 13 | 29446 | Fb |
| 4-03 | Airflow Rate (setting) | 58749703 | AirFlowRateCommand | _115 | _116 | 14 | 29447 | set |
| 4-03 | Airflow Rate (status) | 54555400 | AirFlowRateStatus | _115 | _116 | 13 | 29448 | Fb |
| 4-03 | Measured Room Temperature | 29449 | RoomTemp | _115 | _116 | 0 | 29449 | |
| 4-03 | Set Room Temperature | 8418058 | TempAdjust | _115 | _116 | 2 | 29450 | set |
| 4-03 | Filer Limit Sign | 12612363 | FilterSign | _115 | _116 | 3 | 29451 | |
| 4-03 | Filter Limit Sign Reset | 21000972 | FilterSignReset | _115 | _116 | 5 | 29452 | |
| 4-03 | Remote Control Operation (ON/OFF) | 21000973 | RemoteControlStart | _115 | _116 | 5 | 29453 | |
| 4-03 | Remote Control Operation (Operation Mode) | 21000974 | RemoteControlAirConModeSet | _115 | _116 | 5 | 29454 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 4-03 | Remote Control Operation (Set Temperature) | 21000976 | RemoteControlTempAdjust | _115 | _116 | 5 | 29456 | |
| 4-03 | Remote Control Operation (Sub Group Address Control Rejecti | 21000977 | CL_Rejection | _115 | _116 | 5 | 29457 | |
| 4-03 | Elec Total Power | 96498451 | ElecTotalPower | _115 | _116 | 23 | 29459 | |
| 4-03 | Communication Status | 12612372 | CommunicationStatus | _115 | _116 | 3 | 29460 | |
| 4-03 | System Forced OFF | 21000981 | SystemForcedOff | _115 | _116 | 5 | 29461 | |
| 4-03 | Air Direction (setting) | 8418070 | AirDirectionCommand | _115 | _116 | 2 | 29462 | |
| 4-03 | Air Direction (status) | 29463 | AirDirectionStatus | _115 | _116 | 0 | 29463 | |
| 4-03 | Forced Thermostat OFF (setting) | 16806680 | ForcedThermoOFFCommand | _115 | _116 | 4 | 29464 | |
| 4-03 | Forced Thermostat OFF (status) | 12612377 | ForcedThermoOFFStatus | _115 | _116 | 3 | 29465 | |
| 4-03 | Energy Efficiency Command (setting) | 16806682 | EnergyEfficiencyCommand | _115 | _116 | 4 | 29466 | |
| 4-03 | Energy Efficiency Command (status) | 12612379 | EnergyEfficiencyStatus | _115 | _116 | 3 | 29467 | |
| 4-03 | Thermostat Status | 12612380 | ThermoStatus | _115 | _116 | 3 | 29468 | |
| 4-03 | Compressor Status | 12612381 | CompressorStatus | _115 | _116 | 3 | 29469 | |
| 4-03 | Indoor Fan Status | 12612382 | IndoorFanStatus | _115 | _116 | 3 | 29470 | |
| 4-03 | Heater Operation Status | 12612383 | HeaterStatus | _115 | _116 | 3 | 29471 | |
| 4-03 | Ventilation Mode (setting) | 58749728 | VentilationModeCommand | _115 | _116 | 14 | 29472 | |
| 4-03 | Ventilation Mode (status) | 54555425 | VentilationModeStatus | _115 | _116 | 13 | 29473 | |
| 4-03 | Ventilation Amount (setting) | 58749730 | VentilationAmountCommand | _115 | _116 | 14 | 29474 | |
| 4-03 | Ventilation Amount (status) | 54555427 | VentilationAmountStatus | _115 | _116 | 13 | 29475 | |
| 4-04 | ON/OFF (setting) | 16806913 | StartStopCommand | _116 | _117 | 4 | 29697 | set |
| 4-04 | ON/OFF (status) | 12612610 | StartStopStatus | _116 | _117 | 3 | 29698 | Fb |
| 4-04 | Alarm Sign | 12612611 | Alarm | _116 | _117 | 3 | 29699 | |
| 4-04 | Error Code | 54555652 | MalfunctionCode | _116 | _117 | 13 | 29700 | |
| 4-04 | Operation Mode (setting) | 58749957 | AirConModeCommand | _116 | _117 | 14 | 29701 | set |
| 4-04 | Operation Mode (status) | 54555654 | AirConModeStatus | _116 | _117 | 13 | 29702 | Fb |
| 4-04 | Airflow Rate (setting) | 58749959 | AirFlowRateCommand | _116 | _117 | 14 | 29703 | set |
| 4-04 | Airflow Rate (status) | 54555656 | AirFlowRateStatus | _116 | _117 | 13 | 29704 | Fb |
| 4-04 | Measured Room Temperature | 29705 | RoomTemp | _116 | _117 | 0 | 29705 | |
| 4-04 | Set Room Temperature | 8418314 | TempAdjust | _116 | _117 | 2 | 29706 | set |
| 4-04 | Filer Limit Sign | 12612619 | FilterSign | _116 | _117 | 3 | 29707 | |
| 4-04 | Filter Limit Sign Reset | 21001228 | FilterSignReset | _116 | _117 | 5 | 29708 | |
| 4-04 | Remote Control Operation (ON/OFF) | 21001229 | RemoteControlStart | _116 | _117 | 5 | 29709 | |
| 4-04 | Remote Control Operation (Operation Mode) | 21001230 | RemoteControlAirConModeSet | _116 | _117 | 5 | 29710 | |
| 4-04 | Remote Control Operation (Set Temperature) | 21001232 | RemoteControlTempAdjust | _116 | _117 | 5 | 29712 | |
| 4-04 | Remote Control Operation (Sub Group Address Control Rejecti | 21001233 | CL_Rejection | _116 | _117 | 5 | 29713 | |
| 4-04 | Elec Total Power | 96498707 | ElecTotalPower | _116 | _117 | 23 | 29715 | |
| 4-04 | Communication Status | 12612628 | CommunicationStatus | _116 | _117 | 3 | 29716 | |
| 4-04 | System Forced OFF | 21001237 | SystemForcedOff | _116 | _117 | 5 | 29717 | |
| 4-04 | Air Direction (setting) | 8418326 | AirDirectionCommand | _116 | _117 | 2 | 29718 | |
| 4-04 | Air Direction (status) | 29719 | AirDirectionStatus | _116 | _117 | 0 | 29719 | |
| 4-04 | Forced Thermostat OFF (setting) | 16806936 | ForcedThermoOFFCommand | _116 | _117 | 4 | 29720 | |
| 4-04 | Forced Thermostat OFF (status) | 12612633 | ForcedThermoOFFStatus | _116 | _117 | 3 | 29721 | |
| 4-04 | Energy Efficiency Command (setting) | 16806938 | EnergyEfficiencyCommand | _116 | _117 | 4 | 29722 | |
| 4-04 | Energy Efficiency Command (status) | 12612635 | EnergyEfficiencyStatus | _116 | _117 | 3 | 29723 | |
| 4-04 | Thermostat Status | 12612636 | ThermoStatus | _116 | _117 | 3 | 29724 | |
| 4-04 | Compressor Status | 12612637 | CompressorStatus | _116 | _117 | 3 | 29725 | |
| 4-04 | Indoor Fan Status | 12612638 | IndoorFanStatus | _116 | _117 | 3 | 29726 | |
| 4-04 | Heater Operation Status | 12612639 | HeaterStatus | _116 | _117 | 3 | 29727 | |
| 4-04 | Ventilation Mode (setting) | 58749984 | VentilationModeCommand | _116 | _117 | 14 | 29728 | |
| 4-04 | Ventilation Mode (status) | 54555681 | VentilationModeStatus | _116 | _117 | 13 | 29729 | |
| 4-04 | Ventilation Amount (setting) | 58749986 | VentilationAmountCommand | _116 | _117 | 14 | 29730 | |
| 4-04 | Ventilation Amount (status) | 54555683 | VentilationAmountStatus | _116 | _117 | 13 | 29731 | |
| 4-05 | ON/OFF (setting) | 16807169 | StartStopCommand | _117 | _118 | 4 | 29953 | set |
| 4-05 | ON/OFF (status) | 12612866 | StartStopStatus | _117 | _118 | 3 | 29954 | Fb |
| 4-05 | Alarm Sign | 12612867 | Alarm | _117 | _118 | 3 | 29955 | |
| 4-05 | Error Code | 54555908 | MalfunctionCode | _117 | _118 | 13 | 29956 | |
| 4-05 | Operation Mode (setting) | 58750213 | AirConModeCommand | _117 | _118 | 14 | 29957 | set |
| 4-05 | Operation Mode (status) | 54555910 | AirConModeStatus | _117 | _118 | 13 | 29958 | Fb |
| 4-05 | Airflow Rate (setting) | 58750215 | AirFlowRateCommand | _117 | _118 | 14 | 29959 | set |
| 4-05 | Airflow Rate (status) | 54555912 | AirFlowRateStatus | _117 | _118 | 13 | 29960 | Fb |
| 4-05 | Measured Room Temperature | 29961 | RoomTemp | _117 | _118 | 0 | 29961 | |
| 4-05 | Set Room Temperature | 8418570 | TempAdjust | _117 | _118 | 2 | 29962 | set |
| 4-05 | Filer Limit Sign | 12612875 | FilterSign | _117 | _118 | 3 | 29963 | |
| 4-05 | Filter Limit Sign Reset | 21001484 | FilterSignReset | _117 | _118 | 5 | 29964 | |
| 4-05 | Remote Control Operation (ON/OFF) | 21001485 | RemoteControlStart | _117 | _118 | 5 | 29965 | |
| 4-05 | Remote Control Operation (Operation Mode) | 21001486 | RemoteControlAirConModeSet | _117 | _118 | 5 | 29966 | |
| 4-05 | Remote Control Operation (Set Temperature) | 21001488 | RemoteControlTempAdjust | _117 | _118 | 5 | 29968 | |
| 4-05 | Remote Control Operation (Sub Group Address Control Rejecti | 21001489 | CL_Rejection | _117 | _118 | 5 | 29969 | |
| 4-05 | Elec Total Power | 96498963 | ElecTotalPower | _117 | _118 | 23 | 29971 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 4-05 | Communication Status | 12612884 | CommunicationStatus | _117 | _118 | 3 | 29972 | |
| 4-05 | System Forced OFF | 21001493 | SystemForcedOff | _117 | _118 | 5 | 29973 | |
| 4-05 | Air Direction (setting) | 8418582 | AirDirectionCommand | _117 | _118 | 2 | 29974 | |
| 4-05 | Air Direction (status) | 29975 | AirDirectionStatus | _117 | _118 | 0 | 29975 | |
| 4-05 | Forced Thermostat OFF (setting) | 16807192 | ForcedThermoOFFCommand | _117 | _118 | 4 | 29976 | |
| 4-05 | Forced Thermostat OFF (status) | 12612889 | ForcedThermoOFFStatus | _117 | _118 | 3 | 29977 | |
| 4-05 | Energy Efficiency Command (setting) | 16807194 | EnergyEfficiencyCommand | _117 | _118 | 4 | 29978 | |
| 4-05 | Energy Efficiency Command (status) | 12612891 | EnergyEfficiencyStatus | _117 | _118 | 3 | 29979 | |
| 4-05 | Thermostat Status | 12612892 | ThermoStatus | _117 | _118 | 3 | 29980 | |
| 4-05 | Compressor Status | 12612893 | CompressorStatus | _117 | _118 | 3 | 29981 | |
| 4-05 | Indoor Fan Status | 12612894 | IndoorFanStatus | _117 | _118 | 3 | 29982 | |
| 4-05 | Heater Operation Status | 12612895 | HeaterStatus | _117 | _118 | 3 | 29983 | |
| 4-05 | Ventilation Mode (setting) | 58750240 | VentilationModeCommand | _117 | _118 | 14 | 29984 | |
| 4-05 | Ventilation Mode (status) | 54555937 | VentilationModeStatus | _117 | _118 | 13 | 29985 | |
| 4-05 | Ventilation Amount (setting) | 58750242 | VentilationAmountCommand | _117 | _118 | 14 | 29986 | |
| 4-05 | Ventilation Amount (status) | 54555939 | VentilationAmountStatus | _117 | _118 | 13 | 29987 | |
| 4-06 | ON/OFF (setting) | 16807425 | StartStopCommand | _118 | _119 | 4 | 30209 | set |
| 4-06 | ON/OFF (status) | 12613122 | StartStopStatus | _118 | _119 | 3 | 30210 | Fb |
| 4-06 | Alarm Sign | 12613123 | Alarm | _118 | _119 | 3 | 30211 | |
| 4-06 | Error Code | 54556164 | MalfunctionCode | _118 | _119 | 13 | 30212 | |
| 4-06 | Operation Mode (setting) | 58750469 | AirConModeCommand | _118 | _119 | 14 | 30213 | set |
| 4-06 | Operation Mode (status) | 54556166 | AirConModeStatus | _118 | _119 | 13 | 30214 | Fb |
| 4-06 | Airflow Rate (setting) | 58750471 | AirFlowRateCommand | _118 | _119 | 14 | 30215 | set |
| 4-06 | Airflow Rate (status) | 54556168 | AirFlowRateStatus | _118 | _119 | 13 | 30216 | Fb |
| 4-06 | Measured Room Temperature | 30217 | RoomTemp | _118 | _119 | 0 | 30217 | |
| 4-06 | Set Room Temperature | 8418826 | TempAdjust | _118 | _119 | 2 | 30218 | set |
| 4-06 | Filer Limit Sign | 12613131 | FilterSign | _118 | _119 | 3 | 30219 | |
| 4-06 | Filter Limit Sign Reset | 21001740 | FilterSignReset | _118 | _119 | 5 | 30220 | |
| 4-06 | Remote Control Operation (ON/OFF) | 21001741 | RemoteControlStart | _118 | _119 | 5 | 30221 | |
| 4-06 | Remote Control Operation (Operation Mode) | 21001742 | RemoteControlAirConModeSet | _118 | _119 | 5 | 30222 | |
| 4-06 | Remote Control Operation (Set Temperature) | 21001744 | RemoteControlTempAdjust | _118 | _119 | 5 | 30224 | |
| 4-06 | Remote Control Operation (Sub Group Address Control Reject) | 21001745 | CL_Rejection | _118 | _119 | 5 | 30225 | |
| 4-06 | Elec Total Power | 96499219 | ElecTotalPower | _118 | _119 | 23 | 30227 | |
| 4-06 | Communication Status | 12613140 | CommunicationStatus | _118 | _119 | 3 | 30228 | |
| 4-06 | System Forced OFF | 21001749 | SystemForcedOff | _118 | _119 | 5 | 30229 | |
| 4-06 | Air Direction (setting) | 8418838 | AirDirectionCommand | _118 | _119 | 2 | 30230 | |
| 4-06 | Air Direction (status) | 30231 | AirDirectionStatus | _118 | _119 | 0 | 30231 | |
| 4-06 | Forced Thermostat OFF (setting) | 16807448 | ForcedThermoOFFCommand | _118 | _119 | 4 | 30232 | |
| 4-06 | Forced Thermostat OFF (status) | 12613145 | ForcedThermoOFFStatus | _118 | _119 | 3 | 30233 | |
| 4-06 | Energy Efficiency Command (setting) | 16807450 | EnergyEfficiencyCommand | _118 | _119 | 4 | 30234 | |
| 4-06 | Energy Efficiency Command (status) | 12613147 | EnergyEfficiencyStatus | _118 | _119 | 3 | 30235 | |
| 4-06 | Thermostat Status | 12613148 | ThermoStatus | _118 | _119 | 3 | 30236 | |
| 4-06 | Compressor Status | 12613149 | CompressorStatus | _118 | _119 | 3 | 30237 | |
| 4-06 | Indoor Fan Status | 12613150 | IndoorFanStatus | _118 | _119 | 3 | 30238 | |
| 4-06 | Heater Operation Status | 12613151 | HeaterStatus | _118 | _119 | 3 | 30239 | |
| 4-06 | Ventilation Mode (setting) | 58750496 | VentilationModeCommand | _118 | _119 | 14 | 30240 | |
| 4-06 | Ventilation Mode (status) | 54556193 | VentilationModeStatus | _118 | _119 | 13 | 30241 | |
| 4-06 | Ventilation Amount (setting) | 58750498 | VentilationAmountCommand | _118 | _119 | 14 | 30242 | |
| 4-06 | Ventilation Amount (status) | 54556195 | VentilationAmountStatus | _118 | _119 | 13 | 30243 | |
| 4-07 | ON/OFF (setting) | 16807681 | StartStopCommand | _119 | _120 | 4 | 30465 | set |
| 4-07 | ON/OFF (status) | 12613378 | StartStopStatus | _119 | _120 | 3 | 30466 | Fb |
| 4-07 | Alarm Sign | 12613379 | Alarm | _119 | _120 | 3 | 30467 | |
| 4-07 | Error Code | 54556420 | MalfunctionCode | _119 | _120 | 13 | 30468 | |
| 4-07 | Operation Mode (setting) | 58750725 | AirConModeCommand | _119 | _120 | 14 | 30469 | set |
| 4-07 | Operation Mode (status) | 54556422 | AirConModeStatus | _119 | _120 | 13 | 30470 | Fb |
| 4-07 | Airflow Rate (setting) | 58750727 | AirFlowRateCommand | _119 | _120 | 14 | 30471 | set |
| 4-07 | Airflow Rate (status) | 54556424 | AirFlowRateStatus | _119 | _120 | 13 | 30472 | Fb |
| 4-07 | Measured Room Temperature | 30473 | RoomTemp | _119 | _120 | 0 | 30473 | |
| 4-07 | Set Room Temperature | 8419082 | TempAdjust | _119 | _120 | 2 | 30474 | set |
| 4-07 | Filer Limit Sign | 12613387 | FilterSign | _119 | _120 | 3 | 30475 | |
| 4-07 | Filter Limit Sign Reset | 21001996 | FilterSignReset | _119 | _120 | 5 | 30476 | |
| 4-07 | Remote Control Operation (ON/OFF) | 21001997 | RemoteControlStart | _119 | _120 | 5 | 30477 | |
| 4-07 | Remote Control Operation (Operation Mode) | 21001998 | RemoteControlAirConModeSet | _119 | _120 | 5 | 30478 | |
| 4-07 | Remote Control Operation (Set Temperature) | 21002000 | RemoteControlTempAdjust | _119 | _120 | 5 | 30480 | |
| 4-07 | Remote Control Operation (Sub Group Address Control Reject) | 21002001 | CL_Rejection | _119 | _120 | 5 | 30481 | |
| 4-07 | Elec Total Power | 96499475 | ElecTotalPower | _119 | _120 | 23 | 30483 | |
| 4-07 | Communication Status | 12613396 | CommunicationStatus | _119 | _120 | 3 | 30484 | |
| 4-07 | System Forced OFF | 21002005 | SystemForcedOff | _119 | _120 | 5 | 30485 | |
| 4-07 | Air Direction (setting) | 8419094 | AirDirectionCommand | _119 | _120 | 2 | 30486 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 4-07 | Air Direction (status) | 30487 | AirDirectionStatus | _119 | _120 | 0 | 30487 | |
| 4-07 | Forced Thermostat OFF (setting) | 16807704 | ForcedThermoOFFCommand | _119 | _120 | 4 | 30488 | |
| 4-07 | Forced Thermostat OFF (status) | 12613401 | ForcedThermoOFFStatus | _119 | _120 | 3 | 30489 | |
| 4-07 | Energy Efficiency Command (setting) | 16807706 | EnergyEfficiencyCommand | _119 | _120 | 4 | 30490 | |
| 4-07 | Energy Efficiency Command (status) | 12613403 | EnergyEfficiencyStatus | _119 | _120 | 3 | 30491 | |
| 4-07 | Thermostat Status | 12613404 | ThermoStatus | _119 | _120 | 3 | 30492 | |
| 4-07 | Compressor Status | 12613405 | CompressorStatus | _119 | _120 | 3 | 30493 | |
| 4-07 | Indoor Fan Status | 12613406 | IndoorFanStatus | _119 | _120 | 3 | 30494 | |
| 4-07 | Heater Operation Status | 12613407 | HeaterStatus | _119 | _120 | 3 | 30495 | |
| 4-07 | Ventilation Mode (setting) | 58750752 | VentilationModeCommand | _119 | _120 | 14 | 30496 | |
| 4-07 | Ventilation Mode (status) | 54556449 | VentilationModeStatus | _119 | _120 | 13 | 30497 | |
| 4-07 | Ventilation Amount (setting) | 58750754 | VentilationAmountCommand | _119 | _120 | 14 | 30498 | |
| 4-07 | Ventilation Amount (status) | 54556451 | VentilationAmountStatus | _119 | _120 | 13 | 30499 | |
| 4-08 | ON/OFF (setting) | 16807937 | StartStopCommand | _120 | _121 | 4 | 30721 | set |
| 4-08 | ON/OFF (status) | 12613634 | StartStopStatus | _120 | _121 | 3 | 30722 | Fb |
| 4-08 | Alarm Sign | 12613635 | Alarm | _120 | _121 | 3 | 30723 | |
| 4-08 | Error Code | 54556676 | MalfunctionCode | _120 | _121 | 13 | 30724 | |
| 4-08 | Operation Mode (setting) | 58750981 | AirConModeCommand | _120 | _121 | 14 | 30725 | set |
| 4-08 | Operation Mode (status) | 54556678 | AirConModeStatus | _120 | _121 | 13 | 30726 | Fb |
| 4-08 | Airflow Rate (setting) | 58750983 | AirFlowRateCommand | _120 | _121 | 14 | 30727 | set |
| 4-08 | Airflow Rate (status) | 54556680 | AirFlowRateStatus | _120 | _121 | 13 | 30728 | Fb |
| 4-08 | Measured Room Temperature | 30729 | RoomTemp | _120 | _121 | 0 | 30729 | |
| 4-08 | Set Room Temperature | 8419338 | TempAdjust | _120 | _121 | 2 | 30730 | set |
| 4-08 | Filer Limit Sign | 12613643 | FilterSign | _120 | _121 | 3 | 30731 | |
| 4-08 | Filter Limit Sign Reset | 21002252 | FilterSignReset | _120 | _121 | 5 | 30732 | |
| 4-08 | Remote Control Operation (ON/OFF) | 21002253 | RemoteControlStart | _120 | _121 | 5 | 30733 | |
| 4-08 | Remote Control Operation (Operation Mode) | 21002254 | RemoteControlAirConModeSet | _120 | _121 | 5 | 30734 | |
| 4-08 | Remote Control Operation (Set Temperature) | 21002256 | RemoteControlTempAdjust | _120 | _121 | 5 | 30736 | |
| 4-08 | Remote Control Operation (Sub Group Address Control Reject) | 21002257 | CL_Rejection | _120 | _121 | 5 | 30737 | |
| 4-08 | Elec Total Power | 96499731 | ElecTotalPower | _120 | _121 | 23 | 30739 | |
| 4-08 | Communication Status | 12613652 | CommunicationStatus | _120 | _121 | 3 | 30740 | |
| 4-08 | System Forced OFF | 21002261 | SystemForcedOff | _120 | _121 | 5 | 30741 | |
| 4-08 | Air Direction (setting) | 8419350 | AirDirectionCommand | _120 | _121 | 2 | 30742 | |
| 4-08 | Air Direction (status) | 30743 | AirDirectionStatus | _120 | _121 | 0 | 30743 | |
| 4-08 | Forced Thermostat OFF (setting) | 16807960 | ForcedThermoOFFCommand | _120 | _121 | 4 | 30744 | |
| 4-08 | Forced Thermostat OFF (status) | 12613657 | ForcedThermoOFFStatus | _120 | _121 | 3 | 30745 | |
| 4-08 | Energy Efficiency Command (setting) | 16807962 | EnergyEfficiencyCommand | _120 | _121 | 4 | 30746 | |
| 4-08 | Energy Efficiency Command (status) | 12613659 | EnergyEfficiencyStatus | _120 | _121 | 3 | 30747 | |
| 4-08 | Thermostat Status | 12613660 | ThermoStatus | _120 | _121 | 3 | 30748 | |
| 4-08 | Compressor Status | 12613661 | CompressorStatus | _120 | _121 | 3 | 30749 | |
| 4-08 | Indoor Fan Status | 12613662 | IndoorFanStatus | _120 | _121 | 3 | 30750 | |
| 4-08 | Heater Operation Status | 12613663 | HeaterStatus | _120 | _121 | 3 | 30751 | |
| 4-08 | Ventilation Mode (setting) | 58751008 | VentilationModeCommand | _120 | _121 | 14 | 30752 | |
| 4-08 | Ventilation Mode (status) | 54556705 | VentilationModeStatus | _120 | _121 | 13 | 30753 | |
| 4-08 | Ventilation Amount (setting) | 58751010 | VentilationAmountCommand | _120 | _121 | 14 | 30754 | |
| 4-08 | Ventilation Amount (status) | 54556707 | VentilationAmountStatus | _120 | _121 | 13 | 30755 | |
| 4-09 | ON/OFF (setting) | 16808193 | StartStopCommand | _121 | _122 | 4 | 30977 | set |
| 4-09 | ON/OFF (status) | 12613890 | StartStopStatus | _121 | _122 | 3 | 30978 | Fb |
| 4-09 | Alarm Sign | 12613891 | Alarm | _121 | _122 | 3 | 30979 | |
| 4-09 | Error Code | 54556932 | MalfunctionCode | _121 | _122 | 13 | 30980 | |
| 4-09 | Operation Mode (setting) | 58751237 | AirConModeCommand | _121 | _122 | 14 | 30981 | set |
| 4-09 | Operation Mode (status) | 54556934 | AirConModeStatus | _121 | _122 | 13 | 30982 | Fb |
| 4-09 | Airflow Rate (setting) | 58751239 | AirFlowRateCommand | _121 | _122 | 14 | 30983 | set |
| 4-09 | Airflow Rate (status) | 54556936 | AirFlowRateStatus | _121 | _122 | 13 | 30984 | Fb |
| 4-09 | Measured Room Temperature | 30985 | RoomTemp | _121 | _122 | 0 | 30985 | |
| 4-09 | Set Room Temperature | 8419594 | TempAdjust | _121 | _122 | 2 | 30986 | set |
| 4-09 | Filer Limit Sign | 12613899 | FilterSign | _121 | _122 | 3 | 30987 | |
| 4-09 | Filter Limit Sign Reset | 21002508 | FilterSignReset | _121 | _122 | 5 | 30988 | |
| 4-09 | Remote Control Operation (ON/OFF) | 21002509 | RemoteControlStart | _121 | _122 | 5 | 30989 | |
| 4-09 | Remote Control Operation (Operation Mode) | 21002510 | RemoteControlAirConModeSet | _121 | _122 | 5 | 30990 | |
| 4-09 | Remote Control Operation (Set Temperature) | 21002512 | RemoteControlTempAdjust | _121 | _122 | 5 | 30992 | |
| 4-09 | Remote Control Operation (Sub Group Address Control Reject) | 21002513 | CL_Rejection | _121 | _122 | 5 | 30993 | |
| 4-09 | Elec Total Power | 96499987 | ElecTotalPower | _121 | _122 | 23 | 30995 | |
| 4-09 | Communication Status | 12613908 | CommunicationStatus | _121 | _122 | 3 | 30996 | |
| 4-09 | System Forced OFF | 21002517 | SystemForcedOff | _121 | _122 | 5 | 30997 | |
| 4-09 | Air Direction (setting) | 8419606 | AirDirectionCommand | _121 | _122 | 2 | 30998 | |
| 4-09 | Air Direction (status) | 30999 | AirDirectionStatus | _121 | _122 | 0 | 30999 | |
| 4-09 | Forced Thermostat OFF (setting) | 16808216 | ForcedThermoOFFCommand | _121 | _122 | 4 | 31000 | |
| 4-09 | Forced Thermostat OFF (status) | 12613913 | ForcedThermoOFFStatus | _121 | _122 | 3 | 31001 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 4-09 | Energy Efficiency Command (setting) | 16808218 | EnergyEfficiencyCommand | _121 | _122 | 4 | 31002 | |
| 4-09 | Energy Efficiency Command (status) | 12613915 | EnergyEfficiencyStatus | _121 | _122 | 3 | 31003 | |
| 4-09 | Thermostat Status | 12613916 | ThermoStatus | _121 | _122 | 3 | 31004 | |
| 4-09 | Compressor Status | 12613917 | CompressorStatus | _121 | _122 | 3 | 31005 | |
| 4-09 | Indoor Fan Status | 12613918 | IndoorFanStatus | _121 | _122 | 3 | 31006 | |
| 4-09 | Heater Operation Status | 12613919 | HeaterStatus | _121 | _122 | 3 | 31007 | |
| 4-09 | Ventilation Mode (setting) | 58751264 | VentilationModeCommand | _121 | _122 | 14 | 31008 | |
| 4-09 | Ventilation Mode (status) | 54556961 | VentilationModeStatus | _121 | _122 | 13 | 31009 | |
| 4-09 | Ventilation Amount (setting) | 58751266 | VentilationAmountCommand | _121 | _122 | 14 | 31010 | |
| 4-09 | Ventilation Amount (status) | 54556963 | VentilationAmountStatus | _121 | _122 | 13 | 31011 | |
| 4-10 | ON/OFF (setting) | 16808449 | StartStopCommand | _122 | _123 | 4 | 31233 | set |
| 4-10 | ON/OFF (status) | 12614146 | StartStopStatus | _122 | _123 | 3 | 31234 | Fb |
| 4-10 | Alarm Sign | 12614147 | Alarm | _122 | _123 | 3 | 31235 | |
| 4-10 | Error Code | 54557188 | MalfunctionCode | _122 | _123 | 13 | 31236 | |
| 4-10 | Operation Mode (setting) | 58751493 | AirConModeCommand | _122 | _123 | 14 | 31237 | set |
| 4-10 | Operation Mode (status) | 54557190 | AirConModeStatus | _122 | _123 | 13 | 31238 | Fb |
| 4-10 | Airflow Rate (setting) | 58751495 | AirFlowRateCommand | _122 | _123 | 14 | 31239 | set |
| 4-10 | Airflow Rate (status) | 54557192 | AirFlowRateStatus | _122 | _123 | 13 | 31240 | Fb |
| 4-10 | Measured Room Temperature | 31241 | RoomTemp | _122 | _123 | 0 | 31241 | |
| 4-10 | Set Room Temperature | 8419850 | TempAdjust | _122 | _123 | 2 | 31242 | set |
| 4-10 | Filer Limit Sign | 12614155 | FilterSign | _122 | _123 | 3 | 31243 | |
| 4-10 | Filter Limit Sign Reset | 21002764 | FilterSignReset | _122 | _123 | 5 | 31244 | |
| 4-10 | Remote Control Operation (ON/OFF) | 21002765 | RemoteControlStart | _122 | _123 | 5 | 31245 | |
| 4-10 | Remote Control Operation (Operation Mode) | 21002766 | RemoteControlAirConModeSet | _122 | _123 | 5 | 31246 | |
| 4-10 | Remote Control Operation (Set Temperature) | 21002768 | RemoteControlTempAdjust | _122 | _123 | 5 | 31248 | |
| 4-10 | Remote Control Operation (Sub Group Address Control Reject) | 21002769 | CL_Rejection | _122 | _123 | 5 | 31249 | |
| 4-10 | Elec Total Power | 96500243 | ElecTotalPower | _122 | _123 | 23 | 31251 | |
| 4-10 | Communication Status | 12614164 | CommunicationStatus | _122 | _123 | 3 | 31252 | |
| 4-10 | System Forced OFF | 21002773 | SystemForcedOff | _122 | _123 | 5 | 31253 | |
| 4-10 | Air Direction (setting) | 8419862 | AirDirectionCommand | _122 | _123 | 2 | 31254 | |
| 4-10 | Air Direction (status) | 31255 | AirDirectionStatus | _122 | _123 | 0 | 31255 | |
| 4-10 | Forced Thermostat OFF (setting) | 16808472 | ForcedThermoOFFCommand | _122 | _123 | 4 | 31256 | |
| 4-10 | Forced Thermostat OFF (status) | 12614169 | ForcedThermoOFFStatus | _122 | _123 | 3 | 31257 | |
| 4-10 | Energy Efficiency Command (setting) | 16808474 | EnergyEfficiencyCommand | _122 | _123 | 4 | 31258 | |
| 4-10 | Energy Efficiency Command (status) | 12614171 | EnergyEfficiencyStatus | _122 | _123 | 3 | 31259 | |
| 4-10 | Thermostat Status | 12614172 | ThermoStatus | _122 | _123 | 3 | 31260 | |
| 4-10 | Compressor Status | 12614173 | CompressorStatus | _122 | _123 | 3 | 31261 | |
| 4-10 | Indoor Fan Status | 12614174 | IndoorFanStatus | _122 | _123 | 3 | 31262 | |
| 4-10 | Heater Operation Status | 12614175 | HeaterStatus | _122 | _123 | 3 | 31263 | |
| 4-10 | Ventilation Mode (setting) | 58751520 | VentilationModeCommand | _122 | _123 | 14 | 31264 | |
| 4-10 | Ventilation Mode (status) | 54557217 | VentilationModeStatus | _122 | _123 | 13 | 31265 | |
| 4-10 | Ventilation Amount (setting) | 58751522 | VentilationAmountCommand | _122 | _123 | 14 | 31266 | |
| 4-10 | Ventilation Amount (status) | 54557219 | VentilationAmountStatus | _122 | _123 | 13 | 31267 | |
| 4-11 | ON/OFF (setting) | 16808705 | StartStopCommand | _123 | _124 | 4 | 31489 | set |
| 4-11 | ON/OFF (status) | 12614402 | StartStopStatus | _123 | _124 | 3 | 31490 | Fb |
| 4-11 | Alarm Sign | 12614403 | Alarm | _123 | _124 | 3 | 31491 | |
| 4-11 | Error Code | 54557444 | MalfunctionCode | _123 | _124 | 13 | 31492 | |
| 4-11 | Operation Mode (setting) | 58751749 | AirConModeCommand | _123 | _124 | 14 | 31493 | set |
| 4-11 | Operation Mode (status) | 54557446 | AirConModeStatus | _123 | _124 | 13 | 31494 | Fb |
| 4-11 | Airflow Rate (setting) | 58751751 | AirFlowRateCommand | _123 | _124 | 14 | 31495 | set |
| 4-11 | Airflow Rate (status) | 54557448 | AirFlowRateStatus | _123 | _124 | 13 | 31496 | Fb |
| 4-11 | Measured Room Temperature | 31497 | RoomTemp | _123 | _124 | 0 | 31497 | |
| 4-11 | Set Room Temperature | 8420106 | TempAdjust | _123 | _124 | 2 | 31498 | set |
| 4-11 | Filer Limit Sign | 12614411 | FilterSign | _123 | _124 | 3 | 31499 | |
| 4-11 | Filter Limit Sign Reset | 21003020 | FilterSignReset | _123 | _124 | 5 | 31500 | |
| 4-11 | Remote Control Operation (ON/OFF) | 21003021 | RemoteControlStart | _123 | _124 | 5 | 31501 | |
| 4-11 | Remote Control Operation (Operation Mode) | 21003022 | RemoteControlAirConModeSet | _123 | _124 | 5 | 31502 | |
| 4-11 | Remote Control Operation (Set Temperature) | 21003024 | RemoteControlTempAdjust | _123 | _124 | 5 | 31504 | |
| 4-11 | Remote Control Operation (Sub Group Address Control Reject) | 21003025 | CL_Rejection | _123 | _124 | 5 | 31505 | |
| 4-11 | Elec Total Power | 96500499 | ElecTotalPower | _123 | _124 | 23 | 31507 | |
| 4-11 | Communication Status | 12614420 | CommunicationStatus | _123 | _124 | 3 | 31508 | |
| 4-11 | System Forced OFF | 21003029 | SystemForcedOff | _123 | _124 | 5 | 31509 | |
| 4-11 | Air Direction (setting) | 8420118 | AirDirectionCommand | _123 | _124 | 2 | 31510 | |
| 4-11 | Air Direction (status) | 31511 | AirDirectionStatus | _123 | _124 | 0 | 31511 | |
| 4-11 | Forced Thermostat OFF (setting) | 16808728 | ForcedThermoOFFCommand | _123 | _124 | 4 | 31512 | |
| 4-11 | Forced Thermostat OFF (status) | 12614425 | ForcedThermoOFFStatus | _123 | _124 | 3 | 31513 | |
| 4-11 | Energy Efficiency Command (setting) | 16808730 | EnergyEfficiencyCommand | _123 | _124 | 4 | 31514 | |
| 4-11 | Energy Efficiency Command (status) | 12614427 | EnergyEfficiencyStatus | _123 | _124 | 3 | 31515 | |
| 4-11 | Thermostat Status | 12614428 | ThermoStatus | _123 | _124 | 3 | 31516 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 4-11 | Compressor Status | 12614429 | CompressorStatus | _123 | _124 | 3 | 31517 | |
| 4-11 | Indoor Fan Status | 12614430 | IndoorFanStatus | _123 | _124 | 3 | 31518 | |
| 4-11 | Heater Operation Status | 12614431 | HeaterStatus | _123 | _124 | 3 | 31519 | |
| 4-11 | Ventilation Mode (setting) | 58751776 | VentilationModeCommand | _123 | _124 | 14 | 31520 | |
| 4-11 | Ventilation Mode (status) | 54557473 | VentilationModeStatus | _123 | _124 | 13 | 31521 | |
| 4-11 | Ventilation Amount (setting) | 58751778 | VentilationAmountCommand | _123 | _124 | 14 | 31522 | |
| 4-11 | Ventilation Amount (status) | 54557475 | VentilationAmountStatus | _123 | _124 | 13 | 31523 | |
| 4-12 | ON/OFF (setting) | 16808961 | StartStopCommand | _124 | _125 | 4 | 31745 | set |
| 4-12 | ON/OFF (status) | 12614658 | StartStopStatus | _124 | _125 | 3 | 31746 | Fb |
| 4-12 | Alarm Sign | 12614659 | Alarm | _124 | _125 | 3 | 31747 | |
| 4-12 | Error Code | 54557700 | MalfunctionCode | _124 | _125 | 13 | 31748 | |
| 4-12 | Operation Mode (setting) | 58752005 | AirConModeCommand | _124 | _125 | 14 | 31749 | set |
| 4-12 | Operation Mode (status) | 54557702 | AirConModeStatus | _124 | _125 | 13 | 31750 | Fb |
| 4-12 | Airflow Rate (setting) | 58752007 | AirFlowRateCommand | _124 | _125 | 14 | 31751 | set |
| 4-12 | Airflow Rate (status) | 54557704 | AirFlowRateStatus | _124 | _125 | 13 | 31752 | Fb |
| 4-12 | Measured Room Temperature | 31753 | RoomTemp | _124 | _125 | 0 | 31753 | |
| 4-12 | Set Room Temperature | 8420362 | TempAdjust | _124 | _125 | 2 | 31754 | set |
| 4-12 | Filer Limit Sign | 12614667 | FilterSign | _124 | _125 | 3 | 31755 | |
| 4-12 | Filter Limit Sign Reset | 21003276 | FilterSignReset | _124 | _125 | 5 | 31756 | |
| 4-12 | Remote Control Operation (ON/OFF) | 21003277 | RemoteControlStart | _124 | _125 | 5 | 31757 | |
| 4-12 | Remote Control Operation (Operation Mode) | 21003278 | RemoteControlAirConModeSet | _124 | _125 | 5 | 31758 | |
| 4-12 | Remote Control Operation (Set Temperature) | 21003280 | RemoteControlTempAdjust | _124 | _125 | 5 | 31760 | |
| 4-12 | Remote Control Operation (Sub Group Address Control Reject) | 21003281 | CL_Rejection | _124 | _125 | 5 | 31761 | |
| 4-12 | Elec Total Power | 96500755 | ElecTotalPower | _124 | _125 | 23 | 31763 | |
| 4-12 | Communication Status | 12614676 | CommunicationStatus | _124 | _125 | 3 | 31764 | |
| 4-12 | System Forced OFF | 21003285 | SystemForcedOff | _124 | _125 | 5 | 31765 | |
| 4-12 | Air Direction (setting) | 8420374 | AirDirectionCommand | _124 | _125 | 2 | 31766 | |
| 4-12 | Air Direction (status) | 31767 | AirDirectionStatus | _124 | _125 | 0 | 31767 | |
| 4-12 | Forced Thermostat OFF (setting) | 16808984 | ForcedThermoOFFCommand | _124 | _125 | 4 | 31768 | |
| 4-12 | Forced Thermostat OFF (status) | 12614681 | ForcedThermoOFFStatus | _124 | _125 | 3 | 31769 | |
| 4-12 | Energy Efficiency Command (setting) | 16808986 | EnergyEfficiencyCommand | _124 | _125 | 4 | 31770 | |
| 4-12 | Energy Efficiency Command (status) | 12614683 | EnergyEfficiencyStatus | _124 | _125 | 3 | 31771 | |
| 4-12 | Thermostat Status | 12614684 | ThermoStatus | _124 | _125 | 3 | 31772 | |
| 4-12 | Compressor Status | 12614685 | CompressorStatus | _124 | _125 | 3 | 31773 | |
| 4-12 | Indoor Fan Status | 12614686 | IndoorFanStatus | _124 | _125 | 3 | 31774 | |
| 4-12 | Heater Operation Status | 12614687 | HeaterStatus | _124 | _125 | 3 | 31775 | |
| 4-12 | Ventilation Mode (setting) | 58752032 | VentilationModeCommand | _124 | _125 | 14 | 31776 | |
| 4-12 | Ventilation Mode (status) | 54557729 | VentilationModeStatus | _124 | _125 | 13 | 31777 | |
| 4-12 | Ventilation Amount (setting) | 58752034 | VentilationAmountCommand | _124 | _125 | 14 | 31778 | |
| 4-12 | Ventilation Amount (status) | 54557731 | VentilationAmountStatus | _124 | _125 | 13 | 31779 | |
| 4-13 | ON/OFF (setting) | 16809217 | StartStopCommand | _125 | _126 | 4 | 32001 | set |
| 4-13 | ON/OFF (status) | 12614914 | StartStopStatus | _125 | _126 | 3 | 32002 | Fb |
| 4-13 | Alarm Sign | 12614915 | Alarm | _125 | _126 | 3 | 32003 | |
| 4-13 | Error Code | 54557956 | MalfunctionCode | _125 | _126 | 13 | 32004 | |
| 4-13 | Operation Mode (setting) | 58752261 | AirConModeCommand | _125 | _126 | 14 | 32005 | set |
| 4-13 | Operation Mode (status) | 54557958 | AirConModeStatus | _125 | _126 | 13 | 32006 | Fb |
| 4-13 | Airflow Rate (setting) | 58752263 | AirFlowRateCommand | _125 | _126 | 14 | 32007 | set |
| 4-13 | Airflow Rate (status) | 54557960 | AirFlowRateStatus | _125 | _126 | 13 | 32008 | Fb |
| 4-13 | Measured Room Temperature | 32009 | RoomTemp | _125 | _126 | 0 | 32009 | |
| 4-13 | Set Room Temperature | 8420618 | TempAdjust | _125 | _126 | 2 | 32010 | set |
| 4-13 | Filer Limit Sign | 12614923 | FilterSign | _125 | _126 | 3 | 32011 | |
| 4-13 | Filter Limit Sign Reset | 21003532 | FilterSignReset | _125 | _126 | 5 | 32012 | |
| 4-13 | Remote Control Operation (ON/OFF) | 21003533 | RemoteControlStart | _125 | _126 | 5 | 32013 | |
| 4-13 | Remote Control Operation (Operation Mode) | 21003534 | RemoteControlAirConModeSet | _125 | _126 | 5 | 32014 | |
| 4-13 | Remote Control Operation (Set Temperature) | 21003536 | RemoteControlTempAdjust | _125 | _126 | 5 | 32016 | |
| 4-13 | Remote Control Operation (Sub Group Address Control Reject) | 21003537 | CL_Rejection | _125 | _126 | 5 | 32017 | |
| 4-13 | Elec Total Power | 96501011 | ElecTotalPower | _125 | _126 | 23 | 32019 | |
| 4-13 | Communication Status | 12614932 | CommunicationStatus | _125 | _126 | 3 | 32020 | |
| 4-13 | System Forced OFF | 21003541 | SystemForcedOff | _125 | _126 | 5 | 32021 | |
| 4-13 | Air Direction (setting) | 8420630 | AirDirectionCommand | _125 | _126 | 2 | 32022 | |
| 4-13 | Air Direction (status) | 32023 | AirDirectionStatus | _125 | _126 | 0 | 32023 | |
| 4-13 | Forced Thermostat OFF (setting) | 16809240 | ForcedThermoOFFCommand | _125 | _126 | 4 | 32024 | |
| 4-13 | Forced Thermostat OFF (status) | 12614937 | ForcedThermoOFFStatus | _125 | _126 | 3 | 32025 | |
| 4-13 | Energy Efficiency Command (setting) | 16809242 | EnergyEfficiencyCommand | _125 | _126 | 4 | 32026 | |
| 4-13 | Energy Efficiency Command (status) | 12614939 | EnergyEfficiencyStatus | _125 | _126 | 3 | 32027 | |
| 4-13 | Thermostat Status | 12614940 | ThermoStatus | _125 | _126 | 3 | 32028 | |
| 4-13 | Compressor Status | 12614941 | CompressorStatus | _125 | _126 | 3 | 32029 | |
| 4-13 | Indoor Fan Status | 12614942 | IndoorFanStatus | _125 | _126 | 3 | 32030 | |
| 4-13 | Heater Operation Status | 12614943 | HeaterStatus | _125 | _126 | 3 | 32031 | |

| | | | | | | | | |
|------|---|----------|----------------------------|------|------|----|-------|-----|
| 4-13 | Ventilation Mode (setting) | 58752288 | VentilationModeCommand | _125 | _126 | 14 | 32032 | |
| 4-13 | Ventilation Mode (status) | 54557985 | VentilationModeStatus | _125 | _126 | 13 | 32033 | |
| 4-13 | Ventilation Amount (setting) | 58752290 | VentilationAmountCommand | _125 | _126 | 14 | 32034 | |
| 4-13 | Ventilation Amount (status) | 54557987 | VentilationAmountStatus | _125 | _126 | 13 | 32035 | |
| 4-14 | ON/OFF (setting) | 16809473 | StartStopCommand | _126 | _127 | 4 | 32257 | set |
| 4-14 | ON/OFF (status) | 12615170 | StartStopStatus | _126 | _127 | 3 | 32258 | Fb |
| 4-14 | Alarm Sign | 12615171 | Alarm | _126 | _127 | 3 | 32259 | |
| 4-14 | Error Code | 54558212 | MalfunctionCode | _126 | _127 | 13 | 32260 | |
| 4-14 | Operation Mode (setting) | 58752517 | AirConModeCommand | _126 | _127 | 14 | 32261 | set |
| 4-14 | Operation Mode (status) | 54558214 | AirConModeStatus | _126 | _127 | 13 | 32262 | Fb |
| 4-14 | Airflow Rate (setting) | 58752519 | AirFlowRateCommand | _126 | _127 | 14 | 32263 | set |
| 4-14 | Airflow Rate (status) | 54558216 | AirFlowRateStatus | _126 | _127 | 13 | 32264 | Fb |
| 4-14 | Measured Room Temperature | 32265 | RoomTemp | _126 | _127 | 0 | 32265 | |
| 4-14 | Set Room Temperature | 8420874 | TempAdjust | _126 | _127 | 2 | 32266 | set |
| 4-14 | Filer Limit Sign | 12615179 | FilterSign | _126 | _127 | 3 | 32267 | |
| 4-14 | Filter Limit Sign Reset | 21003788 | FilterSignReset | _126 | _127 | 5 | 32268 | |
| 4-14 | Remote Control Operation (ON/OFF) | 21003789 | RemoteControlStart | _126 | _127 | 5 | 32269 | |
| 4-14 | Remote Control Operation (Operation Mode) | 21003790 | RemoteControlAirConModeSet | _126 | _127 | 5 | 32270 | |
| 4-14 | Remote Control Operation (Set Temperature) | 21003792 | RemoteControlTempAdjust | _126 | _127 | 5 | 32272 | |
| 4-14 | Remote Control Operation (Sub Group Address Control Reject) | 21003793 | CL_Rejection | _126 | _127 | 5 | 32273 | |
| 4-14 | Elec Total Power | 96501267 | ElecTotalPower | _126 | _127 | 23 | 32275 | |
| 4-14 | Communication Status | 12615188 | CommunicationStatus | _126 | _127 | 3 | 32276 | |
| 4-14 | System Forced OFF | 21003797 | SystemForcedOff | _126 | _127 | 5 | 32277 | |
| 4-14 | Air Direction (setting) | 8420886 | AirDirectionCommand | _126 | _127 | 2 | 32278 | |
| 4-14 | Air Direction (status) | 32279 | AirDirectionStatus | _126 | _127 | 0 | 32279 | |
| 4-14 | Forced Thermostat OFF (setting) | 16809496 | ForcedThermoOFFCommand | _126 | _127 | 4 | 32280 | |
| 4-14 | Forced Thermostat OFF (status) | 12615193 | ForcedThermoOFFStatus | _126 | _127 | 3 | 32281 | |
| 4-14 | Energy Efficiency Command (setting) | 16809498 | EnergyEfficiencyCommand | _126 | _127 | 4 | 32282 | |
| 4-14 | Energy Efficiency Command (status) | 12615195 | EnergyEfficiencyStatus | _126 | _127 | 3 | 32283 | |
| 4-14 | Thermostat Status | 12615196 | ThermoStatus | _126 | _127 | 3 | 32284 | |
| 4-14 | Compressor Status | 12615197 | CompressorStatus | _126 | _127 | 3 | 32285 | |
| 4-14 | Indoor Fan Status | 12615198 | IndoorFanStatus | _126 | _127 | 3 | 32286 | |
| 4-14 | Heater Operation Status | 12615199 | HeaterStatus | _126 | _127 | 3 | 32287 | |
| 4-14 | Ventilation Mode (setting) | 58752544 | VentilationModeCommand | _126 | _127 | 14 | 32288 | |
| 4-14 | Ventilation Mode (status) | 54558241 | VentilationModeStatus | _126 | _127 | 13 | 32289 | |
| 4-14 | Ventilation Amount (setting) | 58752546 | VentilationAmountCommand | _126 | _127 | 14 | 32290 | |
| 4-14 | Ventilation Amount (status) | 54558243 | VentilationAmountStatus | _126 | _127 | 13 | 32291 | |
| 4-15 | ON/OFF (setting) | 16809729 | StartStopCommand | _127 | _128 | 4 | 32513 | set |
| 4-15 | ON/OFF (status) | 12615426 | StartStopStatus | _127 | _128 | 3 | 32514 | Fb |
| 4-15 | Alarm Sign | 12615427 | Alarm | _127 | _128 | 3 | 32515 | |
| 4-15 | Error Code | 54558468 | MalfunctionCode | _127 | _128 | 13 | 32516 | |
| 4-15 | Operation Mode (setting) | 58752773 | AirConModeCommand | _127 | _128 | 14 | 32517 | set |
| 4-15 | Operation Mode (status) | 54558470 | AirConModeStatus | _127 | _128 | 13 | 32518 | Fb |
| 4-15 | Airflow Rate (setting) | 58752775 | AirFlowRateCommand | _127 | _128 | 14 | 32519 | set |
| 4-15 | Airflow Rate (status) | 54558472 | AirFlowRateStatus | _127 | _128 | 13 | 32520 | Fb |
| 4-15 | Measured Room Temperature | 32521 | RoomTemp | _127 | _128 | 0 | 32521 | |
| 4-15 | Set Room Temperature | 8421130 | TempAdjust | _127 | _128 | 2 | 32522 | set |
| 4-15 | Filer Limit Sign | 12615435 | FilterSign | _127 | _128 | 3 | 32523 | |
| 4-15 | Filter Limit Sign Reset | 21004044 | FilterSignReset | _127 | _128 | 5 | 32524 | |
| 4-15 | Remote Control Operation (ON/OFF) | 21004045 | RemoteControlStart | _127 | _128 | 5 | 32525 | |
| 4-15 | Remote Control Operation (Operation Mode) | 21004046 | RemoteControlAirConModeSet | _127 | _128 | 5 | 32526 | |
| 4-15 | Remote Control Operation (Set Temperature) | 21004048 | RemoteControlTempAdjust | _127 | _128 | 5 | 32528 | |
| 4-15 | Remote Control Operation (Sub Group Address Control Reject) | 21004049 | CL_Rejection | _127 | _128 | 5 | 32529 | |
| 4-15 | Elec Total Power | 96501523 | ElecTotalPower | _127 | _128 | 23 | 32531 | |
| 4-15 | Communication Status | 12615444 | CommunicationStatus | _127 | _128 | 3 | 32532 | |
| 4-15 | System Forced OFF | 21004053 | SystemForcedOff | _127 | _128 | 5 | 32533 | |
| 4-15 | Air Direction (setting) | 8421142 | AirDirectionCommand | _127 | _128 | 2 | 32534 | |
| 4-15 | Air Direction (status) | 32535 | AirDirectionStatus | _127 | _128 | 0 | 32535 | |
| 4-15 | Forced Thermostat OFF (setting) | 16809752 | ForcedThermoOFFCommand | _127 | _128 | 4 | 32536 | |
| 4-15 | Forced Thermostat OFF (status) | 12615449 | ForcedThermoOFFStatus | _127 | _128 | 3 | 32537 | |
| 4-15 | Energy Efficiency Command (setting) | 16809754 | EnergyEfficiencyCommand | _127 | _128 | 4 | 32538 | |
| 4-15 | Energy Efficiency Command (status) | 12615451 | EnergyEfficiencyStatus | _127 | _128 | 3 | 32539 | |
| 4-15 | Thermostat Status | 12615452 | ThermoStatus | _127 | _128 | 3 | 32540 | |
| 4-15 | Compressor Status | 12615453 | CompressorStatus | _127 | _128 | 3 | 32541 | |
| 4-15 | Indoor Fan Status | 12615454 | IndoorFanStatus | _127 | _128 | 3 | 32542 | |
| 4-15 | Heater Operation Status | 12615455 | HeaterStatus | _127 | _128 | 3 | 32543 | |
| 4-15 | Ventilation Mode (setting) | 58752800 | VentilationModeCommand | _127 | _128 | 14 | 32544 | |
| 4-15 | Ventilation Mode (status) | 54558497 | VentilationModeStatus | _127 | _128 | 13 | 32545 | |
| 4-15 | Ventilation Amount (setting) | 58752802 | VentilationAmountCommand | _127 | _128 | 14 | 32546 | |

| | | | | | | |
|------|-----------------------------|----------|-----------------------------|------|----|-------|
| 4-15 | Ventilation Amount (status) | 54558499 | VentilationAmountStatus_127 | _128 | 13 | 32547 |
|------|-----------------------------|----------|-----------------------------|------|----|-------|